

SECTION 18
TRANSITION TO THE WARRANTY PERIOD
BENEFICIAL USE OF WATER

18.0 BENEFICIAL USE OF WATER

Upon receiving the approval of the Director of Water Utility on the "Execution of Conveyance of Water System Agreement and Bond Release" interoffice memorandum, beneficial use of water from the developer-installed main extension will be allowed.

No water use, unless specific permission is granted from the Director of Water Utility, may be drafted from any service, fire hydrant, or appurtenance, until approval for beneficial use of water is granted. Service laterals and service gate valves will remain locked-off and appropriately tagged. Construction meters on newly installed, yet undedicated (unaccepted) fire hydrants are not permitted.

18.1 EXCEPTIONS

- Emergency use of water for the purpose of fire protection is allowed, regardless if the main extension and/or fire hydrant are accepted or pending acceptance.
- Written permission for beneficial use of water is granted by the Director of Water Utility for reasons specified.