

NOTES:

2 EA 1 EA

1 EA

1. ANY BACKFLOW RELATED INSTALLATION AND/OR REPLACEMENT, INCLUDING PARTS, SHALL ADHERE TO THE MOST CURRENT UNIVERSITY OF SOUTHERN CALIFORNIA (USC) FOUNDATION FOR CROSS-CONNECTION CONTROL AND HYDRAULIC RESEARCH STANDARDS.

_" CLASS 350 DUCTILE IRON PIPE SPOOL

_" X ___" DUCTILE IRON MJ TEE (RESTRAINED)

WATER SAMPLING STATION PER SBMWD STD. DWG. W.6.1

" D.I. ADAPTER (FL X MJ)

2. SWAB INTERIOR OF PIPE, VALVES, AND FITTINGS, AND SWAB INTERIOR OF EXISTING MAINS TO WHICH NEW PIPING WILL BE CONNECTED (BOTH UPSTREAM AND DOWNSTREAM OF THE NEW BACKFLOW ASSEMBLY) WITH A 5% SODIUM HYPOCHLORITE SOLUTION. AFTER DISINFECTION, FLUSH WITH POTABLE WATER AGAIN UNTIL WATER IS FREE OF CHLORINE ODOR.

REVISION DATE: 12/5/2012

		SAN BERNARDINO MUNICIPAL WATER DEPARTMENT		DRAWING	
F.D.L.	DEC. 12				NUMBER
G.B.	APRIL 11	INTERTIE TO NEIGHBORING AGENCIES			SBMWD
D.D.M.	MAR. 11	ABOVE GRADE)A/4 7	
REVISION	DATE	ADDROVED MA	DATE		W4.7
SCALE: NONE		APPROVED WARREN HUANG, P.E.		07/04/2019	