	Appendices	

10.2.2 Protests to Wastewater Change Petition WW0059

This page intentionally left blank

# State of California State Water Resources Control Board DIVISION OF WATER RIGHTS

# P.O. Box 2000, Sacramento, CA 95812-2000

Info: (916) 341-5300, FAX: (916) 341-5400, Web: http://www.waterrights.ca.gov

# PROTEST - (Petitions)

# BASED ON ENVIRONMENTAL OR PUBLIC INTEREST CONSIDERATIONS Protests based on Injury to Vested Rights should be completed on other side of this form

APPLICATION WW0059 PERMIT LICENSE
I, (We,) East Valley Water District  Name of protestant
of P.O. Box 3427 San Bernardino, CA 92413 have read carefully  Post Office address of protestant
a notice relative to a petition for Ochange or Oextension of time.
under APPLICATION WW0059 of City of San Bernardino Municipal Water Department  State name of petitioner
to appropriate water from Rapid Infiltration and Extraction Facility  Name of source
It is desired to protest against the approval thereof because to the best of our information and belief:
the proposed change/extension will  (1) not be within the State Water Resources Control Board's (SWRCB) jurisdiction  (2) not best serve the public interest  (3) be contrary to law  (4) have an adverse environmental impact
State facts, which support the foregoing allegations See Attachment A
Under what conditions may this protest be disregarded and dismissed? See Attachment B  State conditions that will relieve protest, or if none, so state
A true copy of this protest has been served upon the petitioner by e-mail with consent of Petitioner's counsel.  Personally or by mail
Date 7/29/2010 Protestant(s) or Authorized Representative sign here

Protests MUST be filed within the time allowed by the SWRCB as stated in the notice relative to the change or such further time as may be allowed.

(NOTE: Attach supplemental sheets as necessary)

# State of California State Water Resources Control Board

## DIVISION OF WATER RIGHTS

P.O. Box 2000, Sacramento, CA 95812-2000 Info: (916) 341-5300, FAX: (916) 341-5400, Web: http://www.waterrights.ca.gov

# ${\bf PROTEST-(Petitions)}$

## BASED ON INJURY TO VESTED RIGHTS

Protests based on Environmental or Public Interest Considerations should be completed on other side of this form

APPLICATION WW0059	PERMITLICENSE
I, (We,) East Valley Water District	
N. N.	me of protestant
of P.O. Box 3427 San Bernardino, CA 92413	have read carefully eaddress of protestant
a notice relative to a petition for Ochange or Oc	
under APPLICATION www0059 of City of San Berna	rdino Municipal Water Department State name of petitioner
to appropriate water from Rapid Infiltration and Extraction	n Facility Name of source
	pecause to the best of our information and belief the
proposed change will result in injury to us as me or us	follows: See Attachment C State the injury which will result to you (see NOTE below)
divort which right is based on: See Attachment C	e source from which petitioner is diverting, or proposes to
Please provide application, permit or license number your use of water, or state 'none' The predecessors in interest from this source is as follows:	ers or statement of diversion and use numbers, which cover e extent of present and past use of water by protestant or his vs: See Attachment C
	, time of year when diversion made, the use to which water is put
Where is YOUR DIVERSION POINT located?	1/4 of
	ream from petitioner's point of diversion? YES O NO O
Under what conditions may this protest be disregat	ded and dismissed? See Attachment B  State conditions which will relieve protest, or if none, so state.
A true copy of this protest has been served upon th	petitioner by e-mail with consent of Petitioner's counsel.
Date: 7/29/2010	personally or by mail  Protestant(s) or Authorized Representative sign here
further time as may be allowed.	SWRCB as stated in the notice relative to the change or such

PRO-PET (1-00)

### Attachments to Protest by

### East Valley Water District

#### Against

WW0059 - Wastewater Change Petition Proposed by City of San Bernardino Municipal Water Department

#### Attachment A

The proposed petition to change the City of San Bernardino's discharge of treated wastewater into the Santa Ana River may not best serve the public interest for the following reasons:

On January 7, 1958, Protestant EAST VALLEY WATER DISTRICT ("EVWD") entered into a joint powers agreement with Petitioner CITY OF SAN BERNARDINO ("CITY") for the construction and operation of the City Sewage Treatment Plant. Under the terms thereof, EVWD delivers its wastewater to the City Sewage Treatment Plant for collection and secondary treatment. Approximately 26 mgd of the effluent is then sent to the Rapid Infiltration and Extraction ("RIX") Facility operated by the CITY and the City of Colton for tertiary treatment and ultimate discharge into the Santa Ana River. The CITY has engaged in various efforts to market its portion of the recycled flows from the RIX Facility to potential buyers and use the proceeds generated thereby to offset the operation, maintenance, and expansion cost of the City Sewage Treatment Plant and reduce the financial burden of EVWD in connection therewith. If the pending Petition for Change filed by the CITY reflects an intent or desire of the CITY to deviate from such plans, then said Petition will operate to interfere with the sound management of water resources within the Bunker Hill basin and impair the economic resources of EVWD and its rate-paying customers.

For these reasons, as well as the potential that the Petition could alter flows in the Santa Ana River, the Petition would also be contrary to law and the legal rights of affected parties, and have an adverse impact on the environment.

#### Attachment B

The protest may be withdrawn if the CITY and EVWD reach agreement on the disposal of the treated water in question, consistent with existing rights and responsibilities and agreements in place between them. EVWD is actively seeking resolution of its issues.

### Attachment C

CITY's proposed change has the potential to interfere with EVWD's use and enjoyment of resources available from the Bunker Hill basin.

EVWDK002,DOC





# United States Department of the Interior

### FISH AND WILDLIFE SERVICE

Ecological Services
Carlsbad Fish and Wildlife Office
6010 Hidden Valley Road, Suite 101
Carlsbad, California 92011

In Reply Refer To: FWS-SB-10B0630-10TA0875

State Water Resources Control Board Division of Water Rights P. O. Box 2000 Sacramento, California 95812-2000

Attention:

Ms. Kathleen Groody

Subject:

Protest of Revised Wastewater Change Petition WW0059, City of San Bernardino

Municipal Water Department, City of San Bernardino, San Bernardino County,

California

Dear Ms. Groody,

The U.S. Fish and Wildlife Service provides this letter in protest of the above-referenced petition which addresses Change of Place of Use, Change of Purpose of Use, and Reduction in Discharge Quantity by the City of San Bernardino Municipal Water Department (SBMWD). The SBMWD currently discharges wastewater into the Santa Ana River from 2 separate facilities: 1) the San Bernardino Water Reclamation Plant (SBWRP) which discharges secondary wastewater; and 2) the Rapid Infiltration and Extraction (RIX) facility which discharges tertiary wastewater and is located downstream from the SBWRP. The SBMWD proposes to reuse recycled water within its service area and to market surplus recycled water to water agencies outside of this service area.


We offer the following information in keeping with our responsibilities under the Endangered Species Act of 1973 (Act), as amended (16 U.S.C. 1531 et seq.), and in keeping with our agency's mission to work "with others to conserve, protect, and enhance fish, wildlife, and plants and their habitats for the continuing benefit of the American people."

We base our protest on our review of the Revised Notice of Wastewater Change Petition WW0059 (Revised Petition), Environmental Information for Petitions and Attachment A (March 2010), and Petition for Change documents (April 2010). We previously reviewed the RIX Facility Recycled Water Sales Program, Program Environmental Impact Report (Vol. 1) and Technical Appendices (Vol. 2) (March 2003) and the Final RIX Facility Recycled Water Sales Program, Program Environmental Impact Report (January 2005). We have enclosed the 2003 joint letter-response from our agency and the California Department of Fish and Game regarding the Program Environmental Impact Report for your reference.





DNS CC: R.Katz 0. Head C. Shumaker



It is our understanding that SBMWD proposes the following changes to its existing recycled water program: 1) to convey secondary wastewater to various groundwater basins within its service area to allow for 290 acres of groundwater recharge; 2) to sidestream secondary wastewater for irrigation uses within its service area; and 3) to tertiary-treat remaining secondary wastewater at the RIX facility for both discharge into the Santa Ana River and conveyance to the Inland Empire Utility Agency service area. The Revised Petition states that the proposed project would result in a change in place of use and purpose of use of up to 31,500 acre-feet (ac-ft) of water annually or 28 million gallons per day (mgd) of the SBMWD's current maximum discharge limit of 44,822 ac-ft annually or 40 mgd. If read correctly, this implies that a maximum of only 13,322 ac-ft of treated wastewater would be available for discharge annually. However, there is insufficient detail in the documents for us to fully understand potential changes to actual discharge regimes; e.g., a comparison of actual discharges and proposed maximum discharge would be helpful and the proportion of secondary wastewater that would be used for irrigation and the proportion of tertiary wastewater that would be either discharged into the Santa Ana River or sold outside of the SBMWD service area were unspecified.

The federally-threatened Santa Ana sucker (Catostomus santaanae, "SAS") and least Bell's vireo (Vireo bellii pusillus, "LBV") both occur in the vicinity of the RIX facility. Habitat for both of these species is maintained by discharge from the RIX facility outside of the rainy season. During the rainy season, the SBMWD discharges secondary effluent from the SBWRP facility rather than discharging tertiary effluent from the RIX facility. The SAS in particular, is dependent upon discharges from the RIX facility to maintain suitable habitat for spawning and foraging (California Regional Water Quality Control Board 1995, Chadwick & Associates, Inc. 1992). Hence, we are particularly concerned about the potential adverse impacts to these listed species. Critical habitat for the SAS was proposed by our agency on December 9, 2009 (74 FR 65056-65087) and encompasses the reach of the Santa Ana River into which both facilities discharge. Critical habitat for the SAS is anticipated to become final in December of this year. If there is any Federal involvement in the proposed action, impacts to critical habitat as well as to federally-listed species should also be considered pursuant to § 7 the Act.

In the April 2010 Environmental Information for Petitions, the SBMWD states that the proposed actions would not adversely impact fish, wildlife, or riparian habitat (item 10); however, we could find no supporting information and note that the SBMWD states that a new environmental document would be prepared to evaluate the details of this specific project (item 4). If this document has already been prepared, we were unable to locate it. If it has not already been done, we strongly recommend that a thorough environmental review of the proposed action be provided for public comment prior to any action being taken on this Petition. The previously-circulated Program Environmental Impact Reports are outdated; the proposed action differs from the previously-evaluated project proposal and the reduction in wastewater discharge requested in the Revised Petition greatly exceeds that evaluated in the Program Environmental Impact Reports.

The proposed action would also involve the conveyance of wastewater to other off-site facilities. However, no information was provided regarding the methods of conveyance (e.g., use of existing facilities, construction of new or upgraded pipelines, pump stations). Hence, we recommend that further evaluation of this project include details regarding the conveyance of wastewater within and outside of the SBMWD's service area and potential impacts to federally-listed species and/or critical habitats, if any, of this aspect of the proposed program.

We appreciate the opportunity to respond to the Revised Petition. If you should have any comments or questions regarding this information contact Nancy Ferguson of this office at (760) 431-9440, extension 244.

Sincerely,

Kennon & Corey

Assistant Field Supervisor

Encl: (1)

#### Literature Referenced:

California Regional Water Quality Control Board, Santa Ana Region. 1995. Water Quality Control Plan, Santa Ana River Basin (8).

Chadwick & Associates, Inc. 1992. Santa Ana River Use-Attainability Analysis. Volume 2: Aquatic Biology, Habitat, and Toxicity Analysis. Prepared for the Santa Ana Watershed Project Authority, Riverside, California. pp. 111.

cc:

Stacey Aldstadt, San Bernardino Municipal Water Department, San Bernardino, California M ark Adelson, Regional Water Quality Control Board, Santa Ana Region, Riverside, California Jeff Brandt, California Department of Fish and Game, Ontario, California



U.S. Fish and Wildlife Service Carlsbad Fish and Wildlife Office 6010 Hidden Valley Road Carlsbad, California 92008 (760) 431-9440 FAX (760) 431-5902 + 9618



CA Dept. of Fish & Game 4775 Bird Farm Road Chino Hills, California 91709 (909) 597-4144 FAX (909) 597-0067

In Reply Refer To: FWS-SB-3061.3

APR 2 9 2003

Stacey Aldstadt, Deputy General Manager City of San Bernardino Municipal Water Department 300 North D Street San Bernardino, California 92418

Re:

Comments on the Program Environmental Impact Report for the Regional Rapid Infiltration and Extraction Facility Recycled Water Sales Program - SCH #99101088

Dear Ms. Alstadt:

The U.S. Fish and Wildlife Service (Service) and the California Department of Fish and Game (Department), hereafter collectively referred to as the Wildlife Agencies, offer the following comments and recommendations regarding project-associated biological impacts based on our review of the Programmatic Environmental Impact Report (PEIR) for the Regional Rapid Infiltration and Extraction (RIX) Facility Recycled Water Sales Program (Program). The PEIR proposes to divert up to 25.2 cubic feet per second (cfs) [16.27 million gallons per day (mgd) or 18,000 acre feet per year (afy)] of the RIX facility's current discharge to potential users in San Bernardino, Riverside, and Orange Counties. The proposed diversion is equivalent to approximately 40 percent of maximum discharge (62 cfs) of the RIX facility and approximately 33 to 46 percent of the current discharge (55 to 76 cfs). Your agency states that the Program will ensure that the RIX Facility continues to discharge 40 cfs (25.8 mgd) or discharge a volume equivalent to the volume produced prior to the establishment of RIX Facility operations during spawning period.

The primary concern and mandate of the Service is the protection of public fish and wildlife resources and their habitats. The Service has legal responsibility for the welfare of migratory birds, anadromous fish, and endangered animals and plants occurring in the United States. The Service is also responsible for administering the Endangered Species Act of 1973, as amended (16 U.S.C. 1531 et seq.).

The Department is responding as a Trustee Agency, pursuant to the California Environmental Quality Act (CEQA) Guidelines Section 15386, and as a Responsible Agency regarding any discretionary actions pursuant to CEQA Guidelines Section 15381. The Department as a Trustee Agency has jurisdiction by law over natural resources affected by a project which are held in trust for the people of the State of California. The Department, as a Responsible Agency, is required to actively participate in the CEQA process and review and use the Lead Agency's CEQA

documents when taking any discretionary action (CEQA Guidelines Sec 15096), such as the issuance of a Streambed Alteration Agreement or a California Endangered Species Act (CESA) Incidental Take Permit.

We are concerned that the reduced discharge of effluent and construction activities that may result from the proposed Program may affect the federally endangered Delhi Sands flower-loving fly (Rhaphiomidas terminatus abdominalis, "DSF") and the San Bernardino kangaroo rat (Dipodomys merriami parvus, "SBKR"), the federally threatened Santa Ana sucker (Catostomus santaanae, "sucker") and coastal California gnatcatcher (Polioptila californica californica, "gnatcatcher"), the federally and State endangered southwestern willow flycatcher (Empidonax traillii extimus, "flycatcher"), the federally and State threatened least Bell's vireo (Vireo bellii pusillus, "vireo"), and the State endangered western yellow-billed cuckoo (Coccyzus americanus occidentalis, "cuckoo"). The Department is also concerned that the proposed Program will also impact aquatic and sensitive riparian species. Many sensitive species that are listed by the Department as Species of Special Concern are known to occur within the Santa Ana River and may be affected by the project including the Santa Ana sucker, Santa Ana speckled dace (Rhinichthys osculus), arroyo chub (Gila orcutti), western spadefoot toad (Scaphiopus hammondii), southwestern pond turtle (Clemmys marmorata pallida), Belding's savannah sparrow (Passerculus sandwichensis beldingi), tri-colored blackbird (Agelaius tricolor), yellow-breasted chat (Icteria virens), white-faced ibis (Plegadis chihi), white-tailed kite (Elanus leucurus), Swainson's hawk (Buteo swainsoni) and ferruginous hawk (Buteo regalis).

The Wildlife Agencies are concerned that neither of the options for discharge under the proposed Program will provide sufficient habitat to maintain current populations of the sucker. The Santa Ana River supports habitat for the sucker for approximately 34 miles. For approximately seven to ten of these miles, 80 percent of the water is supplied by discharges from the RIX Facility. Reviewing data from Chadwick Ecological Consultants provided in the PEIR, it appears that suckers were rarely observed before 1998 between the RIX outlet and the Metropolitan Water District (MWD) pipeline in the Santa Ana River (Sites labeled SAR3, SAR4 and SAR5). Since the RIX Facility began discharging in 1996, habitat in this stretch of the Santa Ana River has improved and currently supports a significant population of the sucker. We are concerned that a 40 percent reduction in this discharge could eliminate and/or degrade significant portions of sucker habitat. As stated in the PEIR, data do not exist to determine whether the proposed discharge flow of 40 cfs would be sufficient to maintain the sucker in this stretch of the Santa Ana River. In fact, the survey data for the sucker indicate that water quality and/or discharge quantity, which ranged from 37 to 49 cfs, prior to the establishment of the RIX Facility were insufficient to support sucker populations between the RIX Facility and the downstream MWD pipeline. Maintenance of flow in this area is particularly important because the RIX Facility provides a majority of the flow during the non-rainfall season. Therefore, we recommend that you address the quality and quantity of discharge required to maintain existing habitat for the sucker in a revised PEIR or similar document.

In addition, comparison of 1990 and 2002 aerial photographs indicated that the stream has increased significantly in length during this time because of the development of "meanders" and braided conditions. Therefore, we recommend that you determine, if possible, the minimum flow

volume required to support the sucker within the Santa Ana River between the RIX Facility outlet and the MWD pipeline in a braided river configuration rather than as a straight streambed. We also suggest that you consider potential effects to sucker that may result from decreased water flow such increased parasitic infection, effects from increased water temperature such as subsequent metabolic and behavioral changes, changes in water quality, and changes in predator and prey abundance and behavior, and develop measures to offset these potential impacts.

The PEIR states that your agency will ensure that the RIX Facility continue to discharge 40 cfs during the spawning period. We note that the spawning period for the sucker appears to be variable and spawning has been detected as late as July in recent years in the Santa Ana River. Therefore, any measures designed to protect the spawning period of the sucker should be focused between March 1 and July 30. In addition, the nursery period is especially important to fish as it is often the period when they are most susceptible to injury, starvation, and death. Therefore, it is important to not only address the spawning period to enable reproductive success, it is also important to address the nursery period that occurs from March 15 through October 30 to enable recruitment success.

We are also concerned that the reduction in flow from the RIX Facility may have an adverse effect on the riparian habitat that currently exists within the Santa Ana River upon which several previously listed federally and/or State listed and sensitive species are dependent. We recommend that you provide further clarification as to how discharge from the City of Riverside, City of Corona, and the Inland Empire Utilities Agency would be sufficient to support 6,245 acres of riparian habitat downstream of the Riverside Narrows (as stated on Page 4.7-3). This clarification should provide the assumptions and method of calculation for the analysis for the water consumption needs of riparian vegetation, including: 1) the amount of water that percolates into the underlying aquifer, 2) the depth and volume of the underlying aquifer, 3) the amount of water that is being used by existing vegetation, and 4) the amount of water that is removed due to evaporation. In addition, we recommend that you provide a rationale for the water consumption values used for this analysis (i.e., what is the basis for the 5 percent downward adjustment).

We would also like a similar clarification of the assumptions and calculations used to indicate that the riparian habitat that exists between the RIX Facility and the MWD pipeline would be sustained on the proposed reduced discharges. Vireos have been detected in the vicinity of the MWD pipeline. Although flood control activity likely limits the growth of riparian habitat in some areas, the Martha Mclean Anza Narrows Park immediately upstream of the MWD pipeline supports more than 400 acres of riparian habitat that may be suitable for vireo.

We suggest that you incorporate an adaptive management strategy and long-term monitoring program for the area of the Santa Ana River between the RIX Facility and the MWD pipeline that would include periodic assessments of the amount of riparian habitat, depth of the underlying aquifer, depth of root systems for young and mature vegetation within the River, and vegetation surveys. We also encourage you to work with other water use agencies within the Santa Ana River watershed to implement a similar program downstream of the MWD pipeline.

We also request that an analysis of effects to federally and State listed species that exist within the Santa Ana River floodplain be conducted prior to approval of specific Program-related projects that include ground disturbing activities. These species include the gnatcatcher, DSF, vireo, SBKR, flycatcher, and cuckoo. Each of these species occupy habitats that are adjacent to or within the Santa Ana River and may be affected by projects proposed within or adjacent to their habitats.

The Department is concerned that the cumulative effects analysis was not adequate. On page 3-15 under "Related Projects" the PEIR refers to an application submitted by the Orange County Water District to the State Water Resources Control Board to obtain water rights to the flows of all water reaching Prado Basin. The Department recommends referencing the four pending applications for water rights within the Santa Ana Watershed submitted to the State Water Resources Control Board by the Chino Basin Watermaster, San Bernardino Municipal Water District and Western Municipal Water District, San Bernardino Valley Water Conservation District, and the City of Riverside. The Department recommends the revised PEIR discuss potential cumulative impacts to biological resources that may result from the reduction of water by all reasonably foreseeable actions in the Santa Ana River, including the current water right applications. The Department believes a significant reduction in water in the Santa Ana River will likely have a devastating effect upon existing populations of sensitive fish species.

The Wildlife Agencies are also concerned that the cumulative effect of additional water withdrawals will substantially decrease habitat that supports the sucker, vireo, and flycatcher. The Wildlife Agencies recommend that any proposed projects that will be using a portion of the RIX Facility water currently being discharged be considered in the cumulative effects analysis be included in a revised PEIR.

We encourage your agency to work with other water use agencies within the Santa Ana River watershed to assist in maintaining and restoring habitat for federally and State listed and sensitive species. We look forward to continuing our work with your agency and are available to assist you in addressing project effects to federally and State listed and sensitive species and their habitats. If you have any questions or comments regarding this letter, please contact Lucy Caskey (Service) at (760) 431-9440, extension 249 or Leslie MacNair (Department) at (949) 458-1754.

Sincerely.

Karen A Goebel

Assistant Field Supervisor

U. S. Fish and Wildlife Service

Leslie MacNair

Staff Environmental Scientist

Jeslie Machan

Habitat Conservation Planning - Region 6

California Department of Fish and Game

cc: Regional Water Quality Control Board, Santa Ana Region State Clearinghouse, Sacramento



### State of California State Water Resources Control Board

### **DIVISION OF WATER RIGHTS**

2010 JUN - 9 P.O. Box 2000, Sacramento, CA 95812-2000 P.O. Box 2000, Sacramento, CA 95812-2000 P.O. Box 2000, Sacramento, CA 95812-2000 P.O. Box 2000, Sacramento, CA 95812-2000

ORIGINAL

## **PROTEST – APPLICATION**

Based on Environmental Considerations, Public Interest, Public Trust, and Other Issues. (Protests based on INJURY TO PRIOR RIGHTS should be completed on other side of form)

	APPLICATION WW0059							
1.	I, (We) Lisa Belenky, Senior Attorney, Center for Biological Diversity							
	Name of Protestant(s) of 351 California Street, Suite 600, San Francisco, CA 94104 , (415 ) 632-5307 have read carefully a copy							
	Mailing address and zip code of protestant(S)  of, or a notice relative to, Application WW0059  Telephone Number  of City of San Bernardino Municipal Water Department							
	Name of applicant to appropriate from _change waste water place and purpose of use and reduce discharge to the							
	Name of source at a point Santa Ana River. The Protested application is a wastewater change petition, seeking to change the place of use,							
	purpose of use, and reduce discharge quantity of treated wastewater.							
2.	I, (We) protest the above application on:  ENVIRONMENTAL ISSUES, ETC.:  The appropriation will not best conserve the public interest, will have an adverse environmental impact and/or will adversely affect a public trust use of a navigable waterway. *  a. Public interest protests should clearly indicate how the appropriation will affect the public.  b. Environmental protest should identify specific impacts and provide supporting recitals on issues such as: plants, animals or fish affected, erosion, pollution, aesthetics, etc.  c. Public trust protests must identify the navigable waters to be affected and how the project will impact public trust values.  Protests of a general nature (not project specific) or opposed to constitutional or legislated state policy will not be accepted. A request for information or for studies to be conducted is not a protest.							
	OTHER ISSUES, ETC.: The appropriation will be contrary to law, will require access rights, will not be in the State Water Resources Control Board's jurisdiction, or concerns other issues.  Facts and, if applicable, points of law which support the foregoing allegations are as follows: The Center for Biological Diversity is concerned that the proposed actions have the potential to significantly impact aquatic and riparian species and habitats							
including the federally-listed Santa Ana sucker. The Center reserves the right to provide specific facts and points of								
	to the Board regarding these issues until after environmental review has been prepared and circulated to the							
	public for review.							
3.	Under what conditions may this protest be disregarded and dismissed?							
	As the petition states, additional environmental review is needed to fully assess the potential impacts of the petitioned							
	actions on the environment. At this time, the protestant does not have sufficient information to determine							
	the conditions under which this protest could be resolved.							
4.	A true copy of this protest has been served upon the applicant by mail  Personally or by mail							
a	For the purpose of filing a protest, navigable waters include streams and lakes that may be seasonally navigable in small recreational exterioral.  Protestant(s) or authorized representative sign here Lisa Belenky, Senior Attorney, Center for Biological Diversity							
Dat	Street address							
Note	es: Attach supplemental sheets as necessary. Protests must be filed within the time specified in the notice of application  San Francisco, CA 94104  City and State (415 ) 632-5307							
	Telephone number							



### State of California State Water Resources Control Board

### **DIVISION OF WATER RIGHTS**

P.O. Box 2000, Sacramento, CA 95812-2000

Info: (916) 341-5300, FAX: (916) 341-5400, Web: http://www.waterrights.ca.gov

# **PROTEST – (Petitions)**

DIV. OF WATER KI

### BASED ON ENVIRONMENTAL OR PUBLIC INTEREST CONSIDERATIONS

Protests based on Injury to Vested Rights should be completed on other side of this form

APPLICATION WW0059	PERMIT	LICENSE _	
I, (We,) City of Riverside, San Bernardino Valley Municip	oal Water District, Wes	stern Municipal Water District	of Riverside County
	Name of protestant		74
of _380 East Vanderbilt Way, San Bernardino, CA 92408			_ have read carefully
Post Office address of	protestant		
a notice relative to a petition for Ochange or O	extension of time	ò.	
under APPLICATION WW0059 of City of San Be			
	St	ate name of petitioner	
to appropriate water from Rapid Infiltration and Extra			
	Na	ame of source	
It is desired to protest against the approval thereo	of because to the bo	est of our information my or our	and belief:
the proposed change/extension will (1) not be within the State Water Resources Cont (2) not best serve the public interest (3) be contrary to law (4) have an adverse environmental impact	rol Board's (SWR	CB) jurisdiction	
State facts, which support the foregoing allegation	ns See attachment A		
			-
Under what conditions may this protest be disreg	arded and dismiss	ed? See attachment B	
		State conditions that will relieve	e protest, or if none, so state
A true copy of this protest has been served upon	the petitioner by e	-mail with consent of Petitions	er's counsel.
		Personally or by m	ail
Date July 29, 2010	1/2		
	Protestant(s) or Authorized	Representative sign here	

Protests MUST be filed within the time allowed by the SWRCB as stated in the notice relative to the change or such further time as may be allowed.

(NOTE: Attach supplemental sheets as necessary)

### State of California

### **State Water Resources Control Board**

### **DIVISION OF WATER RIGHTS**

**P.O. Box 2000, Sacramento, CA 95812-2000** Info: (916) 341-5300, FAX: (916) 341-5400, Web: http://www.waterrights.ca.gov

# **PROTEST – (Petitions)**

### BASED ON INJURY TO VESTED RIGHTS

Protests based on Environmental or Public Interest Considerations should be completed on other side of this form

APPLICATION WW0059 PERMIT LICENSE LICENSE
I, (We,) City of Riverside, San Bernardino Valley Municipal Water District, Western Municipal Water District of Riverside County
Name of protestant  of 380 East Vanderbilt Way, San Bernardino, CA 92408 have read carefully
Post Office address of protestant
a notice relative to a petition for Ochange or Oextension of time.
under APPLICATION WW0059 of City of San Bernardino Municipal Water Department  State name of petitioner
to appropriate water from Rapid Infiltration and Extraction Facility
Name of source
It is desired to protest against the approval thereof because to the best of our information and belief the
proposed change will result in injury to us as follows: See attachment C
me or us  State the injury which will result to you (see NOTE below)
Protestant claims a right to the use of water from the source from which petitioner is diverting, or proposes to divert, which right is based on:  See attachment C  Prior to application, notice posted, use begun prior to 12/19/14, riparian claim, or other right
Please provide application, permit or license numbers or statement of diversion and use numbers, which cover your use of water, or state 'none' The extent of present and past use of water by protestant or his predecessors in interest from this source is as follows: See attachment C
State approximate date first use made, amount used, time of year when diversion made, the use to which water is put
Where is YOUR DIVERSION POINT located?
T, R, B. & M. Is this point downstream from petitioner's point of diversion? YES O NO O If Yes, explain:
Under what conditions may this protest be disregarded and dismissed? See attachment B  State conditions which will relieve protest, or if none, so state.
A true copy of this protest has been served upon the petitioner by e-mail with consent of Petitioner's counsel.
Date: July 29, 2010
Protests MUST be filed within the time allowed by the SWRCB as stated in the notice relative to the change or such

(NOTE: Attach supplemental sheets as necessary)

further time as may be allowed.

### **Attachments to Protest by**

City of Riverside, San Bernardino Valley Municipal Water District and Western Municipal Water District of Riverside County

### Against

WW0059 – Wastewater Change Petition Proposed by City of San Bernardino Municipal Water Department

### Attachment A

The proposed petition to change the City of San Bernardino's discharge of treated wastewater into the Santa Ana River will not serve the public interest because it will interfere with the implementation of the *Orange County* Judgment and sound conjunctive management of the Riverside Basin. It will be contrary to law for the same reasons. It will have an adverse impact on the environment because it will reduce flows in the Santa Ana River.

### Attachment B

Petitioner must reach an agreement with Protestants City of Riverside, San Bernardino Valley Municipal Water District and Western Municipal Water District of Riverside County to protect those agencies' respective interests. Protestants acknowledge that this Protest will need to be supplemented if those negotiations are not successful and acknowledge that the Petition may need to be modified if those negotiations are successful. Accordingly, Protestants respectfully request that this matter, the consideration of WW0059, be held in abeyance for six months to allow negotiations to be held with Petitioner.

#### Attachment C

Petitioner's change in the place of use of its wastewater has the potential to injure the water rights of Protestants, which include but are not limited to post-1914 appropriative rights and adjudicated rights to groundwater, and to interfere with a number of different court judgments.



State of California

### Memorandum

Date:

July 22, 2010

To:

By Facsimile and U.S. Mail

Ms. Kathleen Groody **Environmental Scientist** Division of Water Rights

State Water Resources Control Board

P.O. Box 2000

Sacramento, CA 95812-2000

From:

Mr. Jeff Brandt

Senior Environmental Scientist Department of Fish and Game

Inland Deserts Region

3602 Inland Empire Blvd., Suite C-220

Ontario, CA 91764

Subject: (REVISED) Protest of Wastewater Change Petition WW0059 for the Change of Place of Use. Change of Purpose of Use, and Reduction of Discharge Quantity by the City of San Bernardino Municipal Water Department for its treated wastewater

The Department of Fish and Game ("Department") respectfully submits this protest to the above-referenced petition ("petition") and requests the State Water Resources Control Board ("Board") to accept this protest based on the information provided herein. The Department is filing this protest in its capacity as a trustee agency for the state's fish and wildlife resources under the Fish and Game Code (Fish & G. Code, § 1802) and the California Environmental Quality Act ("CEQA") (Pub. Resources Code, § 21070; Cal. Code Regs., Tit. 14, § 15386). Also, the Department could be required to act as a responsible agency under CEQA if the project will require a streambed alteration agreement under Fish and Game Code Section 1600 et seq. and/or take authorization under the California Endangered Species Act ("CESA") (Fish & G. Code, § 2050 et seq.).

### Summary

The Department is protesting the petition because based on the limited information currently in its possession or control, the changes the petitioner, the City of San Bernardino Municipal Water Department ("SBMWD"), is proposing could adversely affect the fish and wildlife resources identified below. At this time, without more information regarding whether the changes proposed by SBMWD could adversely affect fish and wildlife resources, the Department is unable to determine whether there are any measures that if made conditions of approval by the Board would adequately

STATE WATER RESOURCES CONTROL ROARD

10 JUL 26 AM 10: 00

DIV. OF WATER RIGHTS SACRAMENTO

Ms. Kathleen Groody Protest of Wastewater Change Petition 0059 July 22, 2010 Page 2 of 8

protect fish and wildlife resources. In order to make this determination, SBMWD should complete the studies described below as part of a study plan approved by the Department before the Board takes any action on the petition. If the SBMWD is unwilling to do so, the Board should require those studies in accordance with its authority under Water Code sections 1701.1, 1701.2, and 1701.3 and any other applicable authority. Based on the results of those studies, the information in the petition, and any documents SBMWD prepares or has prepared to comply with CEQA, the Department would be able to recommend the Board either that it deny the petition or approve it with specific conditions necessary to protect fish and wildlife resources.

### **Project Description**

SBMWD has petitioned the Board to change the place of use, change the purpose of use, and reduce the quantity of discharge of the SBMWD's tertiary treated wastewater (also referred to as "recycled water") (collectively, "project") from its Rapid Infiltration and Extraction Facility (RIX facility) located at 1990 Agua Mansa Road, Colton, CA. At the present time, the RIX facility discharges 61.9 cfs of tertiary treated wastewater into Rialto Channel, which flows along the northeastern side of the facility and into the Santa Ana River. The changes proposed by SBMWD will reduce the amount of tertiary treated wastewater discharged into Rialto Channel and thus the Santa Ana River by 43.5 cfs (with an annual reduction in discharges of up to 31,500 acre-feet), which will reduce the total discharge from 61.9 cfs to 18.4 cfs. The 43.5 cfs of-tertiary treated wastewater that is not discharged into Rialto Channel is proposed to be used for irrigation of 290 acres within the Inland Empire Utilities Agency service area, land within the SBMWD service area, and regional partners west of the RIX facility; and groundwater recharge within the Waterman Basins, East Twin Creek Basins, Devils Canyon Basins, and Sweetwater Basin.

SBMWD is proposing these changes to maximize the use of its recycled water and increase its water supply reliability while decreasing its dependence on imported water supplies.

### **Basis of Protest**

Watershed and habitat protection are vital to the Department's management of California's diverse fish, wildlife, and plant resources.

The Santa Ana River Watershed drains approximately 3,200 square miles and provides habitat for at least 1,400 species of plants, 200 species of birds, 50 species of mammals, 13 species of reptiles, 7 species of amphibians, and 15 species of fish. Rialto Channel is a tributary to the Santa Ana River above Prado Dam. Rialto Channel originates from the San Bernardino County Flood Control District (SBCFCD) Cactus Flood Control Basins located north of North Etiwanda Avenue, east of North Cedar Avenue/North Ayala Drive, south of State Route 210, and west of North Cactus Avenue in the City of Rialto. The Rialto Channel is essentially a continuation of the Cactus

Ms. Kathleen Groody
Protest of Wastewater Change Petition 0059
July 22, 2010
Page 3 of 8

Flood Control Channel, which originates near the City of Fontana and flows south into Cactus Flood Control Basin #5. Rialto Channel flows south from Cactus Flood Control Basin #1 for approximately 5.5 miles to where it meets the Santa Ana River approximately 2 miles north of the San Bernardino County/Riverside County line. The majority of Rialto Channel is concrete-lined. However, from where Rialto Channel crosses under Agua Mansa Road and flows south along the northeastern side of the RIX facility for approximately 0.32 miles, the drainage has a soft bottom and is bounded by earthen material and concrete riprap along the upper portions of its embankments. This section of the channel is vegetated with mature riparian vegetation along both banks, which forms a dense canopy over the channel. The vegetation is dominated by native plant species, including willow (*Salix* spp.), Fremont cottonwood (*Populus fremontii*), and mule fat (*Baccharis salicifolia*). The RIX facility discharges treated wastewater into Rialto Channel immediately south of Agua Mansa Road, which provides a perennial source of water in the vegetated section of the channel extending to the Santa Ana River.

As described above, the section of Rialto Channel downstream of the discharge point to where it meets the Santa Ana River supports mature riparian habitat. This section of Rialto Channel also provides aquatic habitat. The Santa Ana River immediately downstream of the confluence with Rialto Channel supports mature riparian habitat and aquatic habitat as well. Riparian and aquatic habitats within the vegetated section of Rialto Channel, and the Santa Ana River and its tributaries downstream of the confluence with Rialto Channel support several sensitive species listed as threatened or endangered under CESA and the federal Endangered Species Act ("ESA"), and California species of special concern (SSC), including, but not limited to: arroyo chub (*Gila orcutti*), Cooper's hawk (*Accipiter cooperii*), least Bell's vireo (*Vireo bellii pusillus*), Santa Ana sucker (*Catostomus santaanae*), southwestern pond turtle (*Clemmys tigris multiscutatus*), southwestern willow flycatcher (*Empidonax trailii extimus*), western yellow-billed cuckoo (*Coccyzus americanus occidentalis*), white-tailed kite (*Elanus leucurus*), yellow warbler (*Dendroica petechia*), and yellow-breasted chat (*Icteria virens*).

The streambed of Rialto Channel downstream of the RIX facility discharge point consists mostly of gravel, cobbles, and rocks. This substrate combined with the existing perennial flow in the drainage (as a result of the discharge from RIX) and riparian tree canopy, is regarded by many local experts, including the Department and other resources agencies and conservation entities, as high quality habitat for the Santa Ana sucker (SAS), a federally-listed threatened fish species and state-listed fish species of special concern. In fact, many local experts and surveying agencies consistently report the presence of SAS in Rialto Channel between the discharge point and the confluence with the Santa Ana River. It is assumed that SAS migrate from the Santa Ana River into Rialto Channel for refuge or to spawn because of the quality of habitat present in the drainage. Arroyo chub have also been identified within the aquatic habitat in Rialto Channel and the Santa Ana River downstream.

Ms. Kathleen Groody
Protest of Wastewater Change Petition 0059
July 22, 2010
Page 4 of 8

Rialto Channel below the discharge point and the Santa Ana River downstream of the confluence with Rialto Channel contain riparian habitat that supports several sensitive bird species. SBCFCD has been monitoring the nesting activity and success of least Bell's vireo (LBV) and southwestern willow flycatcher (SWFL), both state- and federally-listed endangered bird species, within the Santa Ana River between the Tippecanoe Avenue overpass in San Bernardino downstream to the San Bernardino/Riverside county line since 2001. During the past several years, SBCFCD has documented numerous LBV territories with successful nesting (i.e., LBV fledglings observed) with the riparian habitat in the Santa Ana River from its confluence with Rialto Channel downstream approximately two miles to the San Bernardino/Riverside County line. During the 2008 nesting season, SBCFCD documented eight LBV territories containing 6 nests with one successful nest yielding two fledglings within the Santa Ana River from its confluence with Rialto Channel to the county line. As of early July 2010, SBCFCD has identified eight LBV territories within the riparian habitat in the Santa Ana River from its confluence with Rialto Channel downstream approximately two miles to the San Bernardino/Riverside County line. One of the eight LBV territories was identified at the confluence of Rialto Channel and the Santa Ana River. SBCFCD has reported at least three successful nests (i.e., LBV fledglings observed) thus far within the eight territories for the 2010 nesting season. The possibility of additional successful nests for the 2010 nesting season is highly likely due to the fact that LBV do not commonly leave their territories until September. For the 2010 nesting season thus far, SBCFCD has also reported observations of two migrant SWFL within the Santa Ana River between the confluence with Rialto Channel and the county line.

The Department is concerned that SBMWD's proposal to reduce the quantity of treated wastewater discharged from the RIX facility to the Rialto Channel from 61.9 cfs to 18.4 cfs will adversely impact the riparian and aquatic habitats present in the Rialto Channel below the discharge point and the Santa Ana River immediately downstream, which consequently may adversely impact the species that are dependent upon those habitats. Specifically, the reduction in discharge quantity of treated wastewater will decrease the amount of water available to sustain both the riparian and aquatic habitats within the Rialto Channel and the Santa Ana River downstream. A reduction in water availability in the aquatic habitat in Rialto Channel and the Santa Ana River downstream may: 1) reduce the quality of the habitat for SAS and other fish that utilize these areas for spawning, rearing, and refuge; and 2) hydrologically disconnect Rialto Channel from the Santa Ana River, ultimately affecting the movement of SAS and other fish from the Santa Ana River into Rialto Channel. A reduction in water availability for the riparian habitat in Rialto Channel and the Santa Ana River downstream may: 1) provide unfavorable hydrological conditions for native plant species in these areas, ultimately reducing the density, quality, and type of riparian habitat available for nesting birds, and fish species seeking canopy cover for spawning, rearing, or refuge; and 2) disconnect the riparian corridor in the Santa Ana River from the riparian corridor in Rialto Channel, ultimately impacting the movement and nesting behaviors of birds, and the movement, spawning, rearing, and refuge behaviors of the SAS and other fish species. Overall, the Department is concerned that the proposed reduction in discharge will reduce or eliminate the riparian and aquatic habitats present within Rialto

Ms. Kathleen Groody
Protest of Wastewater Change Petition 0059
July 22, 2010
Page 5 of 8

Channel below the discharge point and in the Santa Ana River downstream, and ultimately reduce the presence and long-term viability of sensitive species such as LBV and SAS.

SBMWD's petition does not include a hydrologic study, biological report, or other information that identifies and analyzes the impacts that the proposed reduction in discharge will have on the riparian and aquatic habitats within Rialto Channel below the discharge point and the Santa Ana River downstream or the species dependent on these habitats. In addition, SBMWD's petition does not provide a habitat map or plant and animal species compendium for Rialto Channel or the Santa Ana River downstream.

### Recommendations

As discussed above, the Department needs more information to determine the impacts the project could have on fish and wildlife resources in the project area. SBMWD stated the following in the *Fish and Wildlife Concerns* section of the petition: "There are no expected adverse impacts to fish, wildlife, or riparian habitat as a result of the implementation of this project". With respect to CEQA, SBMWD stated the following in its petition: "In 2003, the (District) prepared and certified a Program Environmental Impact Report titled 'RIX Facility Recycled Water Sales Program' that evaluated reducing the discharge from the RIX facility to the Santa Ana River, please see Attachment B. The project described in the PEIR is similar to the project described in this Petition for Change; however, there are differences and thus a new environmental document will be prepared to evaluate the details of this specific project." The Department has reviewed Attachment B. The reduction in discharge quantity from the RIX Facility into Rialto Channel as discussed in Attachment B, "RIX Facility Recycled Water Sales Program, Program Environmental Impact Report" dated 2003 (PEIR), is a reduction from 61.9 cfs to a minimum of 38.7 cfs, for a total reduction of 23.2 cfs. In SBMWD's petition, the proposed reduction in discharge quantity is a reduction from 61.9 cfs to 18.4 cfs, for a total reduction of 43.5 cfs. The reduction in discharge quantity proposed by SBMWD in the petition is nearly double that proposed and evaluated in the 2003 PEIR. Thus, as SBMWD stated in the petition, there are "differences" in the two proposals and "new environmental documents should be prepared to evaluate the details of this specific project." Furthermore, the Department does not concur with SBMWD's determination that "there are no expected adverse impacts to fish, wildlife, or riparian habitat as a result of the implementation of this project", as the proposal to reduce the quantity of discharge from the RIX Facility to Rialto Channel from 61.9 cfs to 18.4 cfs has not been evaluated by SBMWD under CEQA.

SBMWD has yet to determine whether the reduction in discharge quantity of tertiary treated wastewater from the RIX facility to Rialto Channel will have an adverse affect on biological resources. In short, the information on the project's potential impacts to fish and wildlife resources currently in the possession and control of the Department is very limited at this time. As a result, at this time, the Department cannot

Ms. Kathleen Groody Protest of Wastewater Change Petition 0059 July 22, 2010 Page 6 of 8

identify specific terms and conditions to dismiss this protest. However, the Department can recommend studies SBMWD should complete (perhaps as part of its analysis of the project under CEQA) that will generate information sufficient for the Department to recommend specific terms and conditions to protect fish and wildlife resources. Further, SBMWD is or could be required to undertake those studies (described below under "Study Plan") under Water Code sections 1701.1, 1701.2, and 1701.3. In the meantime, the Board should not take any action to approve or otherwise act on SBMWD's petition.

### Study Plan

Where a project could affect the hydrologic regime of a watershed, the necessary elements to successfully maintain the downstream biological diversity needs to be identified to facilitate sound management decisions. Based on the general information SBMWD provided, a site-specific study to determine appropriate flow-related terms and conditions is needed. The study plan should include, at a minimum, the following:

- 1. Identification of minimum flows necessary to maintain the health and perpetuation of aquatic resources in Rialto Channel below the discharge point and the Santa Ana River downstream.
- 2. A hydrologic study to determine if the production of the watershed is sufficient to reduce the discharge flows as proposed without having significant adverse impacts to riparian and aquatic resources of Rialto Channel and the Santa Ana River downstream.
- 3. A habitat-based stream needs assessment that incorporates habitat, species, and life history criteria specific to Rialto Channel and the Santa Ana River downstream.
- 4. A complete updated (within the last two years) assessment of the flora and fauna within, adjacent to, and downstream of Rialto Channel, with particular emphasis on identifying endangered, threatened, and sensitive species and sensitive habitats, which includes protocol surveys (United States Fish and Wildlife Service and/or Department protocols) for the presence of threatened or endangered plant and animal species and species of special concern conducted on the entire project site, places of discharge (including downstream reaches affected by the discharge), and places of use. The Department's California Natural Diversity Data Base ("CNDDB") in Sacramento should be contacted at (916) 327-5960 to obtain current information on any previously reported sensitive species and habitat, including Significant Natural Areas identified under Chapter 12 in the Fish and Game Code. (The Department notes that the CNDDB may have limited data for the project area, but any lack of data does not mean that sensitive resources do not occur in the project area.)
- 5. A quantification of the loss of biological resources that will occur as a result of the reduction of discharge in Rialto Channel and the Santa Ana River downstream and

Ms. Kathleen Groody Protest of Wastewater Change Petition 0059 July 22, 2010 Page 7 of 8

an evaluation of the impacts to resources based on the proposed amount of water flow that will be present as a result of the reduction of discharge. The CEQA document should contain a thorough discussion of direct, indirect, and cumulative impacts expected to adversely affect biological resources, with specific measures to offset such impacts. Project impacts should be analyzed relative to their effects on offsite habitats. Specifically, this should include nearby rivers, streams, or lakes located downstream of the project (including the entire floodplain for the waterway), public lands, open space, mitigation sites, adjacent natural habitats, and riparian ecosystems. Impacts to and maintenance of wildlife corridor/movement areas, including access to undisturbed habitat in adjacent areas, should be fully evaluated and provided.

- 6. A specific proposal to provide minimum flows in Rialto Channel for maintenance of any existing riparian and aquatic habitat, fish, and wildlife resources.
- 7. A mitigation plan to replace lost plant, fish, and/or wildlife resources including, but not limited to, the species or habitats described above and in the CNDDB. This plan must include a survey which quantifies the loss of resources that will occur as a result of this project. It must also specify measures that will be taken to offset impacts to resources and outline specific mitigation and monitoring programs.

If after the Department receives the above-described information it can identify terms and conditions that if adopted by the Board as enforceable conditions of petition approval will mitigate any adverse impacts the project could have on habitat and fish and wildlife resources, it will recommend those to SBMWD and the Board. For example, such terms and conditions might include, but not be limited to, the following:

- 1. Maintain sufficient quantity and quality of flow in Rialto Channel to ensure the unimpeded passage of fish from the Santa Ana River upstream to Rialto Channel and to maintain in good condition any riparian and aquatic resources that are likely to exist in the Santa Ana River downstream under current flows.
  - 2. Implement Department-approved mitigation plans.
- 3. Allow access for Department personnel to monitor compliance with Department- and Board-imposed terms and conditions.
- 4. Require SBMWD to notify the Department and, if necessary, obtain a streambed alteration agreement pursuant to Fish and Game Code Section 1600 *et seg.* for the proposed reduction in flow in Rialto Channel.
- 5. Require SBMWD to obtain take authorization under CESA if the proposed reduction in flow in Rialto Channel could result in "take" of CESA-listed species.

Ms. Kathleen Groody Protest of Wastewater Change Petition 0059 July 22, 2010 Page 8 of 8

The Department will be serving SBMWD a copy of this protest by mailing a duplicate copy to SBMWD, in accordance with Water Code section 1703.2, subdivision (e).

If you have any questions regarding this protest, please contact Ms. Anna Milloy, Environmental Scientist, by telephone at (909) 987-8176, by email at amilloy@dfg.ca.gov, or by mail at the above letterhead address.

cc: Ms. Stacy R. Aldstadt
Deputy General Manager
City of San Bernardino Municipal Water Department
300 N. D. Street, 5<sup>th</sup> Floor
San Bernardino, CA 92418

Ms. Anna Milloy, Ontario; Mr. Jeff Brandt, Ontario Department of Fish and Game

Ms. Nancy Ferguson U.S. Fish and Wildlife Service, Carlsbad

Mr. Lee Reader Santa Ana Watershed Association

Ms. Shelli Lamb Riverside-Corona Resource Conservation District 10.2.3 Memorandum of Understanding Regarding the Resolution of Protests to Wastewater Change Petition WW0059

This page intentionally left blank

### Memorandum of Understanding Regarding the Resolution of Protests to Wastewater Change Petition WW0059

This Memorandum of Understanding ("MOU") is made and entered into on February 22, 2011 ("Effective Date"), by and between the City of San Bernardino Municipal Water Department (the "Department"), the City of Riverside, through its Public Utilities Department ("Riverside"), San Bernardino Valley Municipal Water District ("Valley District"), and Western Municipal Water District of Riverside County ("Western"). Each of the Parties to this MOU is hereinafter sometimes referred to as a "Party" and are collectively referred to as the "Parties."

### Recitals

- A. On April 23, 2010, the Department filed a Petition for Change regarding treated wastewater with the State Water Resources Control Board ("SWRCB") pursuant to Water Code section 1211. The SWRCB accepted and noticed the City's petition as Wastewater Change Petition WW0059 (the "Petition").
- B. On or about July 29, 2010, Riverside, Valley District and Western (collectively "Protestants") filed a protest with the SWRCB alleging that the Petition infringed upon prior vested rights and was not in the public interest.
- C. Department and Protestants wish to cooperate to: (1) explore and pursue potential opportunities to jointly plan, permit, design, construct, and operate the Department's proposed "Clean Water Factory San Bernardino" (the "Project") at the earliest possible time and at the least possible cost to the public; and (2) allow for the Project to retain the greatest possible quantity of treated wastewater in the San Bernardino Basin Area ("SBBA").
- D. The Parties wish to memorialize their mutual understandings and agreements in this MOU so as to provide a firm foundation for future cooperation, and to allow Protestants to withdraw their protests to the Petition.

NOW, THEREFORE, in consideration of the foregoing Recitals and the mutual covenants and conditions contained herein, the parties agree as follows:

1. It is the intent of the Parties to develop a cooperative and collaborative arrangement that will: (i) enable the Parties to jointly plan, design, permit, construct and operate the Project for water conservation purposes pursuant to the water conservation provisions of the 1969 *Orange County* Judgment; and (ii) consistent with that intent, reduce the

MOU for Resolution of Protests Wastewater Change Petition WW-0059 February 2011 Page 1 of 4

- discharge of treated wastewater into the Santa Ana River to the greatest extent possible so as to replenish the SBBA and/or provide water for direct use.
- 2. The Parties shall immediately commence good faith discussions to explore and pursue potential opportunities to jointly plan, design, permit, construct and operate the Project at the earliest possible time and at the least possible cost to the public. These potential opportunities shall include, but shall not be limited to, the formation of a joint powers authority and/or development and execution of a joint exercise of powers agreement wherein the Parties would specify their respective rights, obligations, duties and liabilities related to jointly planning, designing, permitting, constructing, and operating the Project. Specifically, the Parties agree to the following framework principles:
  - a. The 1969 agreement between Valley District and the Department will remain in full force and effect until and unless Valley District and all of the other Parties execute a written agreement establishing an alternative way for Valley District to meet its obligations under the 1969 *Orange County* Judgment. The Parties will immediately begin discussions aimed at developing such an alternative that will enable greater quantities of treated wastewater to be used within the SBBA or to replenish the SBBA.
  - b. No wastewater treated by the Department shall be sold or delivered, directly or via an exchange/transfer, outside the boundaries of the Santa Ana River watershed, as defined in the *Orange County* Judgment.
  - c. No wastewater treated by the Department shall be sold or delivered, directly or via an exchange/transfer within the boundaries of the Santa Ana River watershed as defined in the *Orange County* Judgment but outside the SBBA without the prior written consent of all of the Parties.
- 3. The Parties agree to comply with the framework principles set forth above, regardless of whether the Parties are able to reach agreement on how to jointly plan, design, permit, construct and operate the Project.
- 4. Not later than ten business days after the effective date of this MOU, the Protestants shall file with the SWRCB a letter, in substantially the form attached hereto as Appendix \_\_\_, withdrawing their respective protests to the Petition, and supporting the SWRCB's granting of the Petition.
- 5. This MOU shall not operate to validate or invalidate, modify or affect any Party's water rights. Each Party to this MOU reserves any and all claims and causes of action respecting its water rights claims, any and all defenses against any water rights claims made by any other entity, and any claims arising from contamination or water quality degradation. Further nothing

MOU for Resolution of Protests Wastewater Change Petition WW-0059 February 2011 Page 2 of 4 in this MOU is intended to modify or affect in any way any prior agreements or judgments affecting the Parties, save as expressly stated in this MOU.

IN WITNESS WHEREOF, the parties hereto have executed this MOU as of the day and year first written above.

CITY OF RIVERSIDE, a California charter city and municipal corporation

City Manage

Attest:

City Clerk

Approved as to Form:

By: Susan

Deputy City Attorney

CITY OF SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

By: Toni Callicott, President

**Board of Water Commissioners** 

MOU for Resolution of Protests Wastewater Change Petition WW-0059 February 2011 Page 3 of 4 in this MOU is intended to modify or affect in any way any prior agreements or judgments affecting the Parties, save as expressly stated in this MOU.

IN WITNESS WHEREOF, the parties hereto have executed this MOU as of the day and year first written above.

CITY OF SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Hacy Aldstadt for

By:

į

Toni Callicott, President

**Board of Water Commissioners** 

MOU for Resolution of Protests Wastewater Change Petition WW-0059 February 2011 Page 3 of 4 SAN BERNARDINO VALLEY MUNICIPAL WATER DISTRICT

By: C. Patrick Milligan, President Board of Directors

WESTERN MUNICIPAL WATER DISTRICT OF RIVERSIDE COUNTY

By:


Brenda Dennstedt, President

Board of Directors



10.2.4 Preliminary Design Report

This page intentionally left blank



# Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

# **SUMMARY REPORT**



**RBF Consulting** 

14725 Alton Parkway Irvine, California 92618



Black & Veatch

15615 Alton Parkway Irvine, California 92618

July 2012

July 2012 i Summary Report



# CLEAN WATER FACTORY RECYCLED/ADVANCED WATER CONVEYANCE SYSTEM

## **Engineering Analysis Summary Report**



#### CITY OF SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

General Manager:

Stacey Aldstadt

Engineering Manager:

Greg Gage

Director of Water Reclamation:


John Claus

Director, Water Utility:

Matt Litchfield, P.E.

#### **ENGINEERING TEAM**

Principal Engineer: Lead Engineer: Project Engineers: Michael P. Rudinica, P.E., RBF Consulting Steven N. Foellmi, P.E., Black & Veatch Timothy M. Smith, P.E., Black & Veatch John M. Nagle, P.E., RBF Consulting David A. Cover, P.E., Black & Veatch Sam V. Valdez, P.E., RBF Consulting





# **TABLE OF CONTENTS**

EXEC	CUTIVE SUMMARY	ES-1
1.0	BACKGROUND INFORMATION	1-1
1.1	PLANNING INVESTIGATION REPORT (WILDERMUTH)	1-1
1.2	BUNKER HILL GROUNDWATER BASIN	
1.3	ENVIRONMENTAL IMPACT REPORT/ENVIRONMENTAL IMPACT STUDY	1-4
1.4	CONVEYANCE SYSTEM TERMINOLOGY	1-5
1.5	ABBREVIATIONS AND ACRONYMS	1-6
2.0	EXISTING FACILITIES	2-1
2.1	SAN BERNARDINO WATER RECLAMATION PLANT	2-1
2.2	RAPID INJECTION AND EXTRACTION (RIX) FACILITY	2-1
2.3	WATERMAN BASINS/EAST TWIN CREEK SPREADING GROUNDS	2-1
3.0	PROPOSED FACILITIES	3-1
3.1	CONVEYANCE SCENARIOS	3-1
4.0	POTENTIAL DIRECT USE CUSTOMERS AND RECYCLED WATER DEMAN	DS.4-1
4.1	DIRECT USE CUSTOMERS	4-1
4.2	RECYCLED WATER CRITERIA AND DEMANDS	4-2
5.0	PRELIMINARY FACILITY SIZING	5-1
5.1	ADVANCED TREATED WATER CONVEYANCE FACILITIES OVERVIEW	5-2
5.2	RECYCLED WATER CONVEYANCE FACILITIES OVERVIEW	5-3
5.3	CONVEYANCE SCENARIOS FACILITY SIZING	5-3
	5.3.1 Conveyance Scenario 1	5-4
	5.3.2 Conveyance Scenario 2	5-4
	5.3.3 Conveyance Scenario 3	5-6
	5.3.4 Conveyance Scenario 4	
	5.3.5 Conveyance Scenario 5	
	5.3.6 Conveyance Scenario 6	5-10
6.0	PRELIMINARY HYDRAULIC ANALYSIS	6-1
6.1	ADVANCED TREATED WATER CONVEYANCE FACILITIES	6-1
6.2	RECYCLED WATER CONVEYANCE FACILITIES	6-2
7.0	FACILITY REQUIREMENTS	7 <b>-1</b>
7.1	TYPICAL STORAGE RESERVOIR SITE	7-1
7.2	TYPICAL PUMPING STATION SITE	7-1
7.3	TYPICAL COMBINED STORAGE RESERVOIR/PUMPING STATION SITE	7-2

8.0	PIPEL	INE ALIGNMENT ANALYSIS	8-1
8.1	OVER	VIEW	8-1
8.2	POTE	NTIAL CORRIDORS/SEGMENTS	8-1
8.3	AGEN	ICY REQUIREMENTS	8-2
8.4	REGU	ILATORY REQUIREMENTS	8-3
8.5		NMENT EVALUATION CRITERIA	
	8.5.1	Right of Way	8-4
	8.5.2	Agency Coordination/Permitting	8-4
	8.5.3	Direct Use Customers	
	8.5.4	Community Impacts/Duration	8-4
	8.5.5	Traffic	
	8.5.6	Utilities	8-5
	8.5.7	Special Crossings	8-5
	8.5.8	Constructability	8-5
	8.5.9	Land Condition	8-5
	8.5.10	Construction Costs	8-6
	8.5.11	Operation and Maintenance Costs	8-6
8.6		NMENT SEGMENT SCREENING	
8.7	ALIG	NMENT DESCRIPTIONS	8-6
	8.7.1	Pipeline Alignment Option 1	8-6
	8.7.2	Pipeline Alignment Option 2	
	8.7.3	Pipeline Alignment Option 3	
	8.7.4	Pipeline Alignment Option 4	8-9
	8.7.5	Distribution Pipeline System	
8.8	ALIG	NMENT CROSS-SECTIONS	8-10
8.9	SPECI	IAL CROSSINGS	8-10
8.10	ALIG	NMENT EVALUATION RATING	8-11
	8.10.1	Alignment Option 1	8-16
	8.10.2	Alignment Option 2	8-16
	8.10.3	Alignment Option 3	8-16
	8.10.4	Alignment Option 4	8-16
8.11	SUMN	MARY	8-16
8.12	COST	ESTIMATES	8-17
9.0	PUMI	P STATION/STORAGE RESERVOIR ANALYSIS	9-1
9.1	TYPIC	CAL SITE REQUIREMENTS	9-1
9.2		RNATIVE SITES	
9.3	PUMI	STATION/STORAGE RESERVOIR EVALUATION CRITERIA	9-2
	9.3.1	Property	
	9.3.2	Agency Coordination/Permitting	
	9.3.3	Flexibility for Future Expansion	
	9.3.4	Community/Visual Impacts	
	9.3.5	Access	

	9.3.6 Utilities	9-4
	9.3.7 Power Supply	9-4
	9.3.8 Constructability	9-4
	9.3.9 Land Condition	9-4
	9.3.10 Construction Costs	9-4
	9.3.11 Operation and Maintenance C	osts9-5
9.4	PUMP STATION/STORAGE RESERV	OIR SITE RANKING9-5
	9.4.1 Pump Station/Storage Reservo	ir Site A9-8
	9.4.2 Pump Station/Storage Reservo	ir Site B9-8
	9.4.3 Pump Station/Storage Reservo	ir Site C9-8
		ir Site D9-9
	9.4.5 Pump Station/Storage Reservo	ir Site E9-9
		ir Site F9-9
	•	ir Site G9-9
9.5		9-9
9.6	FACILITY POWER REQUIREMENTS	9-10
9.7	COST ESTIMATES	9-10
10.0	CONVEYANCE SYSTEM SCENARI	OS10-1
10.1	OVERVIEW	
10.2	SCENARIOS	10-1
	10.2.1 Conveyance Scenario 1	10-1
	10.2.2 Conveyance Scenario 2	10-1
	10.2.3 Conveyance Scenario 3	
	10.2.4 Conveyance Scenario 4	
	10.2.5 Conveyance Scenario 5	
	10.2.6 Conveyance Scenario 6	
10.3	EVALUATION CRITERIA	10-2
	10.3.1 Water Supply	10-3
	10.3.2 Operation	10-3
	10.3.3 Treatment Facilities Location	10-3
	10.3.4 Flexibility for Future Expansion	n10-3
	10.3.5 Construction Costs	
	10.3.6 Operation and Maintenance C	osts10-4
10.4	CONVEYANCE SCENARIO RANKII	NGS10-4
	10.4.1 Conveyance Scenario 1	
	10.4.2 Conveyance Scenario 2	
	10.4.3 Conveyance Scenario 3	
	10.4.4 Conveyance Scenario 4	
	10.4.5 Conveyance Scenario 5	
	,	
10.5	SUMMARY	
10.6	COST ESTIMATES	

 $\mathbf{v}$ 

11.0 CO	NCLUSION	11-1
List of Tal	bles	
Table 1-1	Key Parameters	1-3
	Conveyance Scenarios	
- 11		

10.010 1 1		
Table 3-1	Conveyance Scenarios	3-4
Table 4-1	Existing Irrigation Water Demand	4-2
Table 4-2	Water Demand Factors	4-3
Table 4-3	Water Demand Peaking Factors	4-4
Table 4-4	Water Demands	4-5
Table 5-1	Design Criteria	5-1
Table 8-1	Pipeline Alignment Option 1	8-7
Table 8-2	Pipeline Alignment Option 2	8-7
Table 8-3	Pipeline Alignment Option 3	8-8
Table 8-4	Distribution Pipeline Summary	8-9
Table 8-5	Definition of Rating System	8-12
Table 8-6	Definition of Weighting System	8-12
Table 8-7	Pipeline Alignment Options Criteria Weighting	8-13
Table 8-8	Pipeline Alignment Options Evaluation and Ranking	8-14
Table 8-9	Pipeline Alignment Options Feasibility-Level Cost Estimates	8-17
Table 9-1	Definition of Rating System	9-5
Table 9-2	Definition of Weighting System	9-5
Table 9-3	Pump Station/Storage Reservoir Site Options Criteria Weighting	9-6
Table 9-4	Pump Station/Storage Reservoir Site Options Evaluation and Ranking	9-7
Table 9-5	Pump Station/Storage Reservoir Site Feasibility-Level Cost Estimate	9-11
Table 10-1	Definition of Rating System	10-4
Table 10-2	Definition of Weighting System	10-5
Table 10-3	Conveyance Scenario Criteria Weighting	10-5
Table 10-4	Conveyance Scenarios Evaluation and Ranking	10-7
Table 10-5	Conveyance Scenarios Evaluation and Ranking (per Acre-Foot)	10-9
Table 10-6	Reduced RIX Facility Treatment Costs	10-10
Table 10-7	Conveyance Scenario Site Feasibility-Level Cost Estimate	10-13

# **List of Figures**

Location of Clean Water Factory and Related Facilities	1-9	
San Bernardino Basin Area		
San Bernardino Basin Area		
Recycled/Advanced Conveyance Scenarios – Scenario 1	3-5	
Recycled/Advanced Conveyance Scenarios – Scenario 2	3-6	
Recycled/Advanced Conveyance Scenarios – Scenario 3	3-7	
Recycled/Advanced Conveyance Scenarios – Scenario 4	3-8	
Recycled/Advanced Conveyance Scenarios – Scenario 5	3-9	
Recycled/Advanced Conveyance Scenarios – Scenario 6	3-10	
Recycled Water System – Potential Direct Use Areas – Sheet 1	4-6	
Recycled Water System – Potential Direct Use Areas – Sheet 2	4-7	
Recycled Water System – Potential Direct Use Areas – Sheet 3	4-8	
Recycled Water System – Potential Direct Use Areas – Sheet 4	4-9	
Recycled Water System – Potential Direct Use Areas – Sheet 5	4-10	
Conveyance Scenarios Facility Sizing – Scenario 1	5-13	
Conveyance Scenarios Facility Sizing – Scenario 2	5-14	
Conveyance Scenarios Facility Sizing – Scenario 3	5-15	
Conveyance Scenarios Facility Sizing – Scenario 4	5-16	
Conveyance Scenarios Facility Sizing – Scenario 5	5-17	
Conveyance Scenarios Facility Sizing – Scenario 6	5-18	
Hydraulic Profile – Pipeline 1-1: Advanced Treated Water	6-4	
Hydraulic Profile - Pipeline 2-1 and 2-2: Advanced Treated Water	6-5	
Hydraulic Profile - Pipeline 3-1 and 3-2: Recycled Water	6-6	
Figure 6-3 Hydraulic Profile – Pipeline 3-1 and 3-2: Recycled Water Figure 6-4 Hydraulic Profile – Pipeline 3-3: Advanced Treated Water		
Hydraulic Profile - Pipeline 4-1 and 4-2: Recycled Water	6-8	
Hydraulic Profile - Pipeline 4-3 and 4-4: Advanced Treated Water	6-9	
Hydraulic Profile – Pipeline 5-1: Recycled Water	6-10	
Hydraulic Profile - Pipeline 6-1 and 6-2: Recycled Water	6-11	
Hydraulic Profile – Pipeline 5-1 and 6-1: Brine Water	6-12	
Separate Reservoir and Pump Station Sites	7-4	
Combined Reservoir and Pump Station Sites	7-5	
Alignment Options – Sheet 1	8-18	
Alignment Options – Sheet 2	8-19	
Alignment Option 1 - Distribution Pipelines – Sheet 1	8-20	
Figure 8-4 Alignment Option 1 - Distribution Pipelines – Sheet 2		
	San Bernardino Basin Area RWQCB Basin Management Zone Locations and Water Quality Object Recycled/Advanced Conveyance Scenarios – Scenario 1 Recycled/Advanced Conveyance Scenarios – Scenario 2 Recycled/Advanced Conveyance Scenarios – Scenario 3 Recycled/Advanced Conveyance Scenarios – Scenario 4 Recycled/Advanced Conveyance Scenarios – Scenario 5 Recycled/Advanced Conveyance Scenarios – Scenario 6 Recycled Water System – Potential Direct Use Areas – Sheet 1 Recycled Water System – Potential Direct Use Areas – Sheet 2 Recycled Water System – Potential Direct Use Areas – Sheet 3 Recycled Water System – Potential Direct Use Areas – Sheet 4 Recycled Water System – Potential Direct Use Areas – Sheet 5 Conveyance Scenarios Facility Sizing – Scenario 1 Conveyance Scenarios Facility Sizing – Scenario 2 Conveyance Scenarios Facility Sizing – Scenario 2 Conveyance Scenarios Facility Sizing – Scenario 3 Conveyance Scenarios Facility Sizing – Scenario 5 Conveyance Scenarios Facility Sizing – Scenario 6  Hydraulic Profile – Pipeline 1-1: Advanced Treated Water Hydraulic Profile – Pipeline 3-1 and 3-2: Recycled Water Hydraulic Profile – Pipeline 3-3: Advanced Treated Water Hydraulic Profile – Pipeline 3-3: Advanced Treated Water Hydraulic Profile – Pipeline 3-3: Advanced Treated Water Hydraulic Profile – Pipeline 3-3 and 4-4: Advanced Treated Water Hydraulic Profile – Pipeline 4-3 and 4-4: Recycled Water Hydraulic Profile – Pipeline 4-3 and 4-4: Advanced Treated Water Hydraulic Profile – Pipeline 5-1: Recycled Water Hydraulic Profile – Pipeline 5-1 and 6-2: Recycled Water Hydraulic Profile – Pipeline 5-1 and 6-1: Brine Water  Separate Reservoir and Pump Station Sites  Combined Reservoir and Pump Station Sites  Combined Reservoir and Pump Station Sites  Alignment Options – Sheet 1  Alignment Options – Sheet 2  Alignment Options – Sheet 1	

Figure 8-5	Alignment Option 2 & 4 - Distribution Pipelines - Sheet 1	8-22
Figure 8-6	Alignment Option 2 & 4 - Distribution Pipelines – Sheet 2	8-23
Figure 8-7	Alignment Option 3 - Distribution Pipelines – Sheet 1	8-24
Figure 8-8	Alignment Option 3 - Distribution Pipelines - Sheet 2	8-25
Figure 8-9	Cross-Section 1A	8-26
Figure 8-10	Cross-Section 1B	8-27
Figure 8-11	Cross-Section 1C	8-28
Figure 8-12	Cross-Section 1D	8-29
Figure 8-13	Cross-Section 1E	8-30
Figure 8-14	Cross-Section 1F	8-31
Figure 8-15	Caltrans Crossing 1G	8-32
Figure 8-16	Cross-Section 1H	8-33
Figure 8-17	Cross-Section 1I	8-34
Figure 8-18	Cross-Section 1J	8-35
Figure 8-19	Cross-Section 1K	8-36
Figure 8-20	Cross-Section 1L, 2K, 3K	8-37
Figure 8-21	Cross-Section 2A, 3A	8-38
Figure 8-22	Cross-Section 2B, 3B	8-39
Figure 8-23	Cross-Section 2C, 3C	8-40
Figure 8-24	Cross-Section 2D, 3D	
Figure 8-25	Cross-Section 2E, 3E	8-42
Figure 8-26	Cross-Section 2F	8-43
Figure 8-27	Cross-Section 2G	8-44
Figure 8-28	Caltrans Crossing 2H	8-45
Figure 8-29	Cross-Section 2I	8-46
Figure 8-30	Cross-Section 2J	8-47
Figure 8-31	Cross-Section 3F	
Figure 8-32	Caltrans Crossing 3G	
Figure 8-33	Caltrans I-210 Crossing Cross Sections	
Figure 8-34	Cross-Section 3I	
Figure 8-35	Cross-Section 3J	8-52
Figure 8-36	Pipeline Alignment Options Evaluation	8-14
Figure 9-1	Pump Station/Storage Reservoir Site Option A	9-12
Figure 9-2	Pump Station/Storage Reservoir Site Option B	9-13
Figure 9-3	Pump Station/Storage Reservoir Site Option C	9-14
Figure 9-4	Pump Station/Storage Reservoir Site Option D	9-15
Figure 9-5	Pump Station/Storage Reservoir Site Option E	9-16
Figure 9-6	Pump Station/Storage Reservoir Site Option F	9-17
Figure 9-7	Pump Station/Storage Reservoir Site Option G	9-18
Figure 9-8	Pump Station/Storage Reservoir Site Options Evaluation	9-8
Figure 10-1	Conveyance Scenarios Evaluation	10-8

### **List of Appendices**

### Appendix A

Table A-1 Summary of Potential Direct Use Areas

Table A-2 Conveyance Scenario Pipeline Length Summary

#### Appendix B

Table B-1 Preliminary Hydraulic Analysis

#### Appendix C

Table C-1 Pump Station SummaryTable C-2 Storage Reservoir Summary

Table C-3 Combined Pump Station/Storage Reservoir Summary

#### Appendix D

Table D-1 Pipeline Alignment Option Cost Estimates

Table D-2 Pump Station/Storage Reservoir Site Option Cost Estimates

Table D-3 Conveyance Scenario Cost Estimates

Table D-4 Energy Costs

#### Appendix E

Table E-1 Alignment Option 1 – Distribution Pipelines
 Table E-2 Alignment Options 2 & 4 – Distribution Pipelines
 Table E-3 Alignment Option 3 – Distribution Pipelines

#### Appendix F

SBMWD Drawing Number W6.14 – Water and Sewer Separation Standards

July 2012 ix Summary Report

#### **EXECUTIVE SUMMARY**

The City of San Bernardino Municipal Water Department (SBMWD) is evaluating the feasibility of the Clean Water Factory (CWF) Project. This Summary Report (Report) provides the basis for overall evaluation of the CWF recycled/advanced water conveyance system engineering analysis including conveyance facility requirements and potential recycled water customers. The data herein will be used in the development of the CWF Project Environmental Impact Report (EIR)/Environmental Impact Statement (EIS).

This summary gives a brief overview of the information presented in the Report.

- Background Information (Section 1). This section describes the findings and conclusions of a Recycled Water Planning Investigation Report (Recycled Water Report) prepared for SBMWD in 2010 and the applicability to the currently defined CWF Project. Also provided are brief descriptions of the Bunker Hill Groundwater Basin, a discussion of the on-going environmental documentation, definition of conveyance system terminology, and a list of abbreviations and acronyms used in this Report.
- Existing Facilities (Section 2). This section describes the major existing facilities within the area impacted by the proposed CWF Project: the San Bernardino Water Reclamation Plant (SBWRP), the Rapid Injection and Extraction Facility (RIX), and the Waterman Basins/East Twin Creek Spreading Grounds collectively known as the Recharge Basins.
- Proposed Facilities (Section 3). Six Conveyance Scenarios were developed to analyze
  possible configurations of conveyance facilities for the CWF Project. This section gives a
  brief description of each scenario, including pipelines, pump stations, storage reservoirs,
  and associated facilities required. A schematic is developed for each scenario.
- Potential Direct Use Customers and Recycled Water Demands (Section 4). The Recycled Water Report identified 19 potential irrigation customers. This section expands the list of potential direct use customers to 60 and calculates estimated recycled water demands. Water demand factors are presented for each land use category: golf courses, parks, schools, nursery, cemeteries, public use, and Caltrans. Maps are developed indicating potential recycled water customers in proximity to potential CWF Project facilities.
- Preliminary Facility Sizing (Section 5). This section presents preliminary sizing for recycled water and advanced treated water facilities including transmission pipelines, pump stations, and storage reservoirs. General criteria are described, followed by criteria for the six Conveyance Scenarios developed in Section 3.
- Preliminary Hydraulic Analysis (Section 6). This section presents a hydraulic analysis conducted to evaluate pressures, total head loss, and pumping requirements for the

July 2012 ES-1 Summary Report

- various alignment options for the six Conveyance Scenarios. Hydraulic profiles are presented using the criteria described in Section 5.
- Facility Requirements (Section 7). To assist the SBMWD in determining facility space
  and land acquisition requirements, this section develops typical site layouts for a
  reservoir site, a pump station site, and a site which combines both facilities.
- **Pipeline Alignment Analysis (Section 8).** This section presents a Conveyance Facility Corridor that provides a relatively direct route from the SBWRP to the Recharge Basins. Four preferred Alignment Options are developed using criteria described in Section 5. Evaluation criteria are developed and each alignment option is rated and ranked. Cost estimates for the four Alignment Options are also presented.
- Pump Station/Storage Reservoir Analysis (Section 9). This section presents an analysis to evaluate seven potential Pump Station/Storage Reservoir Sites within the Conveyance Facility Corridor. Typical site requirements are identified and layouts are presented for each potential site. Facility power requirements are determined and connections to existing power lines are identified. Results are presented from an evaluation of the preferred Pump Station/Storage Reservoir Sites considering evaluation factors and rating and ranking each site. Cost estimates for the seven Pump Station/Storage Reservoir Site options are also presented.
- Conveyance System Scenarios (Section 10). The overall analysis of six potential
  Conveyance Scenarios with various configurations of pipelines and Pump
  Station/Storage Reservoir Sites within a Conveyance Facility Corridor between the
  SBWRP and the Recharge Basins is presented. Results are presented from an evaluation
  of the Conveyance Scenarios considering evaluation factors and rating and ranking each
  scenario. Cost estimates for the six Conveyance Scenarios are presented including cost
  per acre-foot.
- **Conclusion (Section 11).** Conclusions are presented for the comprehensive feasibility-level analysis of conveyance facilities associated with the CWF Project that will be used in the development of the project's EIR/EIS.
- Appendix A through F. Supporting information is presented on Potential Direct Use Areas, Conveyance Scenario Pipeline Lengths, Preliminary Hydraulic Analysis, Pump Station and Storage Reservoir Information, Cost Estimates, Distribution Pipelines, and Pipeline Separation Standards.

July 2012 ES-2 Summary Report

#### 1.0 BACKGROUND INFORMATION

This section summarizes the findings and conclusions of the 2010 Recycled Water Report and the applicability to the currently defined CWF Project. This section also describes the location and water quality objectives of the Bunker Hill Groundwater Basin (Bunker Hill Basin), discusses environmental documentation, defines conveyance system terminology, and lists abbreviations and acronyms used herein.

#### 1.1 PLANNING INVESTIGATION REPORT (WILDERMUTH)

In November 2010, a Recycled Water Planning Investigation Report (Recycled Water Report) was prepared by Wildermuth Environmental, Inc. (Wildermuth) for the SBMWD. This document was prepared to determine the feasibility of using recycled and advanced treated water to augment SBMWD's water supply. The overall location of the CWF and related facilities developed in the Recycled Water Report are shown on Figure 1-1 and the San Bernardino Basin Area is shown on Figure 1-2.

The SBMWD's water supply is entirely from the Bunker Hill Basin. Water availability has been affected by the extended drought in California, water supply constraints from State Water Project (SWP) facilities that are used by the San Bernardino Valley Municipal Water District (Valley District) to recharge the Bunker Hill Basin, and groundwater supply use. The SBMWD is required to reduce per capita water demands to be in compliance with Senate Bill SBX-7 (10 percent reduction in per capita water demands by 2015 and 20 percent by 2020). The SBMWD is developing solutions to meet its future water needs, including using recycled water for delivery to recycled water customers and recharging the Bunker Hill Basin with recycled and/or advanced treated water.

Addition of tertiary and advanced treatment processes at the SBMWD's existing San Bernardino Water Reclamation Plant (SBWRP) was evaluated to provide additional recycled water and/or advanced treated water. The SBWRP currently treats 22 million gallons per day (mgd) to secondary treatment standards, which are conveyed via a pipeline to the Rapid Infiltration and Extraction (RIX) Facility for tertiary treatment and discharge to the Santa Ana River. The SBWRP has a rated capacity of 33 mgd with projected treatment demands of up to 35 mgd by the year 2030 requiring some expansion. Secondary treated water at the SBWRP could be treated to the tertiary level using conventional filtration and disinfection processes, including chlorination or ultraviolet (UV), and then delivered to potential recycled water customers for

<sup>&</sup>lt;sup>1</sup> The terms recycled water and advanced treated water are used in this Summary Report. Recycled or tertiary treated water refers to water treated to Title 22 standards for use in non-potable application such as irrigation and industrial uses, Recycled or tertiary water is also known as disinfected secondary-2.2 recycled water or Non-Potable Reuse (NPR) water or direct use water. Advanced treated water refers to water treated using advanced treatment processes including MBR, MF, UF, NF, RO, AOP, and/or other treatment technology to produce nearly pure water meeting California Department of Public Health standards. Advanced water is also known as Indirect Potable Reuse (IPR) water that utilizes a natural environmental barrier (i.e. groundwater basin) prior to use as a drinking water source.

irrigation and uses at the SBWRP. Advanced treatment processes could include various combinations of methods, including Membrane Bioreactor (MBR), Micro Filtration/Ultrafiltration (MF/UF), Nano Filtration (NF), Reverse Osmosis (RO), and Advanced Oxidation Process (AOP). The treated water could then be delivered to recycled water customers and/or for groundwater recharge. Groundwater recharge is proposed at the existing Recharge Basins, which are owned and operated by the San Bernardino County Flood Control District (SBCFCD).

The Recycled Water Report indicated that previous studies have shown that recycled water distribution throughout the SBMWD's service area is not economically feasible. However, recycled water service could be delivered economically near the SBWRP and along a defined pipeline corridor to nearby potential recycled water customers. The SBMWD had already identified recycled water customers with up to 800 acre-feet per year (0.71 mgd) Average Day Demand (ADD) near the SBWRP and planned to provide recycled water service as part of their Master Plan. The Recycled Water Report identified up to 2.1 mgd (ADD) near the SBWRP and up to 0.7 mgd (ADD) of recycled water demand along a defined pipeline corridor. An additional 1.3 mgd (ADD) of recycled water demand along the defined pipeline corridor was defined as part of this engineering study (total of 2.0 mgd to northern customers).

Advanced treated water could be utilized to deliver water to recycled water customers and/or for groundwater recharge. The Recycled Water Report identified up to 18.2 mgd of advanced water treatment at the SBWRP with 14.2 mgd of product water (considering 92 percent recovery through MF and 85 percent recovery through RO) for groundwater recharge at the existing Recharge Basins. The capacity is limited by production of concentrated brine from the advanced water treatment process (RO or NF) at approximately 15 percent (or 2.5 mgd) which is conveyed by the Inland Empire Brine Line (IEBL) connection at the SBWRP. The SBMWD has a contractual discharge capacity of 2.5 mgd in the IEBL. Improved recovery of product water by different treatment processes could reduce the concentrated brine and/or increase product water available for recharge.

Current California Department of Public Health (CDPH) draft Groundwater Replenishment Reuse regulations (November 21, 2011) allow surface application of advanced treated water for groundwater replenishment without defined dilution. Prior draft regulations required 50 percent advanced treated water to 50 percent dilution water, but operating facilities have increased up to 75 percent advanced treated water or higher. These new regulations allow for the potential ultimate groundwater recharge of 14.2 mgd of advanced treated water at the existing Recharge Basins without dilution.

Current CDPH draft Groundwater Replenishment Reuse regulations (November 21, 2011) also allow surface application of tertiary treated water for groundwater replenishment with substantial dilution (20 percent tertiary to 80 percent dilution water), which increase the potential tertiary water use by up to 5 mgd for recharge at the existing Recharge Basins. A summary of the key parameters is provided in Table 1-1.

July 2012 1-2 Summary Report

**Table 1-1 Key Parameters** 

Facility	Description	Criteria
SBWRP	Existing Rated Capacity	33 mgd
	Current Treatment	Secondary
	Current Operation	22 mgd
IEBL	Existing Contractual Discharge Capacity (SBMWD)	2.5 mgd
RIX	Existing Rated Capacity	40 mgd
	Current Treatment	Tertiary
	Current Operation	36 mgd
Recycled Customers	Northern (ADD)	2.0 mgd
	At SBWRP and Southern (ADD)	2.1 mgd
Advanced Treatment*	Secondary Effluent	18.2 mgd
	Microfiltration (92% recovery)	16.7 mgd
	Reverse Osmosis (85% recovery)	14.2 mgd
	Brine Waste (to IEBL)	2.5 mgd
	Advanced Treated Water	14.2 mgd
Recharge	Recycled Water/Diluent Water	20%/80%
	Advanced Water/Diluent Water	Per CDPH Prior Standard 50%/50% Potential 100%/0%
* Criteria for MF/RO/AOP Advanced Treatment. Other treatment scenarios are being evaluated.		

evaluated.

### **BUNKER HILL GROUNDWATER BASIN**

The Bunker Hill Basin is comprised of the Bunker Hill-A and Bunker Hill-B Management Zones as defined by the Regional Water Quality Control Board (RWQCB). Figure 1-3 shows the location and water quality objectives of the basins in proximity to the CWF Project as developed by the Recycled Water Report. Water quality objectives set by the Santa Ana RWQCB are listed below:

- Bunker Hill-A Management Zone location of recycled water northern customers.
   Basin objectives for total dissolved solids (TDS) = 310 milligrams per liter (mg/L); Nitrate = 2.7 mg/L (basin has no assimilative capacity, existing TDS = 330 mg/L; Nitrate = 4.0 mg/L).
- Bunker Hill-B Management Zone location of recycled water customers near SBWRP. Basin objectives for TDS = 330 mg/L; Nitrate = 7.3 mg/L (basin has assimilative capacity, existing TDS = 280 mg/L; Nitrate = 5.4 mg/L).

The CWF Project proposes tertiary and/or advanced treated water delivery to recycled water customers and groundwater recharge. The water quality objectives of the Bunker Hill-A Management Zone could limit the overall recycled water/advanced treated water use. An evaluation was included in the Recycled Water Report that demonstrated water quality objectives would be met with the flow rates proposed in the Recycled Water Report. The basin objectives were re-evaluated with the proposed flow rates presented in this Summary Report based on the new draft CDPH regulations. The addition of 2 mgd of recycled water for direct use customers and 5 mgd of recycled water for groundwater recharge combined with advanced treated water and State Project Water (SPW) dilution met the water quality objectives (Combined water TDS = 233 mg/L; Nitrate = 2.45). Storm water was not considered for dilution to meet the basin objectives since it is not new water. The dilution water low TDS and nitrate blends with the recycled water with higher TDS and nitrate to meet the basin objectives.

The water quality objectives of the Bunker Hill-B Management Zone using 2.1 mgd (ADD) are expected to be met considering the assimilative capacity of the basin. The assimilative capacity is the ability of the basin to receive groundwater recharge with water constituent (TDS and nitrate) amounts greater than the specified basin objective because the current constituent amounts in the basin are currently below the basin objectives. For the Bunker Hill-B Management Zone, it is expected that with the addition of the 2.1 mgd for direct use customers, the basin objectives will still be met. The Santa Ana River RWQCB may permit groundwater recharge at concentrations higher than the basin objectives if assimilative capacity exists.

# 1.3 ENVIRONMENTAL IMPACT REPORT/ENVIRONMENTAL IMPACT STUDY

RBF Consulting (RBF) is preparing an environmental document for the CWF Project. The document addresses potential environmental impacts represented by the project in accordance with Federal and State law. RBF's approach to the document is to combine the expertise of planning disciplines with engineering review to establish the best viable alternatives and to eliminate elements of the project that are technically infeasible. The approach also uses prior studies and technical reports as much as practicable to present a comprehensive, cost effective analysis.

July 2012 1-4 Summary Report

Because a Federal nexus has been identified, RBF is preparing a combined National Environmental Policy Act (NEPA)/California Environmental Quality Act (CEQA) document for the CWF Project. The combined EIR/EIS will address potential impacts that may result from implementation of the CWF Project. Critical elements include analysis pertaining to redirection of some, or all, of the current discharge to the Santa Ana River, new conveyance and treatment systems, and the effects represented by adding substantial amounts of recycled water and advanced treated water to the upper groundwater basins. All reasonable alternatives to the project will be analyzed pursuant to NEPA requirements.

The environmental document is expected to be completed in the summer of 2013.

To provide sufficient detail on the required conveyance system for the CWF Project EIR/EIS, RBF in association with Black & Veatch is preparing supplemental information on the Conveyance System. This Report identifies conveyance system facility requirements and potential recycled water customers.

#### 1.4 CONVEYANCE SYSTEM TERMINOLOGY

Certain terminology, defined below, is used throughout this Report. These terms were selected to facilitate the presentation of the project description.

<u>Conveyance System</u> – The portion of the CWF Project that includes the facilities required to transport treated water from the SBWRP to the Recharge Basins.

<u>Conveyance Facility</u> – An individual facility, such as a pump station, transmission pipeline or storage reservoir. The Conveyance Facilities, in aggregate, make up the Conveyance System.

<u>Conveyance Facility Corridor</u> – A general term used to describe the study area between the SBWRP and the Recharge Basins in which conveyance facilities will potentially be located.

<u>Conveyance Scenarios</u> – Several configurations (referred to as scenarios) are possible for the Conveyance System. These depend on the use of single or dual transmission pipelines, single-lift or two-lift pumping, or the remote location for the advanced water treatment facilities. Six Conveyance Scenarios are identified and analyzed in this Report.

<u>Alignment Options</u> – Within the Conveyance Facility Corridor, there are numerous potential alignments in which to locate transmission pipelines. Four specific Alignment Options are presented in this Report. Conveyance Scenarios and Alignment Options are independent of each other, i.e., any of the four Alignment Options can be applied to any of the six Conveyance Scenarios.

July 2012 1-5 Summary Report

<u>Site Options</u> – Within the Conveyance Facility Corridor, there are numerous potential locations for siting intermediate pump stations and storage facilities. Similar to Alignment Options, specific Site Options can be applied to different Conveyance Scenarios.

#### 1.5 ABBREVIATIONS AND ACRONYMS

The following abbreviations and acronyms are used in this Report.

AACEI Association for the Advancement of Cost Engineering

International

ABND abandoned

ADD average day demand AFY acre-feet per year

ALT alternative

amsl above mean sea level

AOP advanced oxidation processes

avg average

AW advanced water

AWWA American Water Works Association

BNSF Burlington Northern Santa Fe Railway Company

Caltrans California Department of Transportation

CCI Construction Cost Index

CDPH California Department of Public Health
CEQA California Environmental Quality Act

City of San Bernardino

CL, & centerline

CMU concrete masonry unit

CONC concrete

CWF Clean Water Factory
DW domestic water

dwgdrawingEeastE/Oeast of

EIR Environmental Impact Report
EIS Environmental Impact Statement

ELEC electrical

ENR Engineering News Record

EX existing
FO fiber optic
fps feet per second

G gas

gpm gallons per minute

HDPE high-density polyethylene

HP high pressure HWY highway

IEBL Inland Empire Brine Line

INV invert

IPR indirect potable reuse

L long

LF linear foot/feet

LN lane

max maximum

MBR membrane bioreactor
MDD maximum day demand
MF/UF microfiltration/ultrafiltration

mg/L milligrams per liter mgd million gallons per day

min minimum

MMD maximum month demand

N north N/O north of

NEPA National Environmental Policy Act

NF nanofiltration NPR non-potable reuse

O&M operation and maintenance

PHD peak hour demand

PRV pressure regulating valve psi pounds per square inch

R/R railroad R/W, RW, ROW right-of-way

RCP reinforced concrete pipe

RD road

Recharge Basins Waterman Basins and East Twin Creek Spreading Grounds

RIX Rapid Infiltration and Extraction

RO reverse osmosis RW recycled water

RWQCB Regional Water Quality Control Board

S south S/O south of

SANBAG San Bernardino Association of Governments SBCFCD San Bernardino County Flood Control District

SBMWD City of San Bernardino Municipal Water Department

SBWRP San Bernardino Water Reclamation Plant

SCE Southern California Edison

SD storm drain

SPW State Project Water

SS sanitary sewer

ST street

SWP State Water Project
TDH total dynamic head
TDS Total Dissolved Solids

TELE telephone UV ultraviolet

Valley District San Bernardino Valley Municipal Water District

VFD variable frequency drive

W west W/O west of

July 2012 1-8 Summary Report

Existing Pipeline from SBWRP to RIX San Bernardino County Flood Control District Recharge Facilities Kilometers San Bernardino Municipal Water Department Service Area Proposed Direct Use Pipelines Proposed Recharge Pipelines Streams, Rivers, and Flood Control Channels Water Reclamation Facility Potential Direct Use Sites (


San Bernardino Riverside County County 0 Orange County TA

SOURCE: SBMWD Recycled Water Planning Investigation Report (Wildermuth - November 2010)



Location of Clean Water Factory and Related Facilities





San Bernardino County Flood Control District Recharge Facilities

San Bernardino Basin Area (SBBA) Boundary

San Bernardino Municipal Water Department Service Area

Streams, Rivers, and Flood Control Channels

San Bernardino County Riverside County 9 0 Orange County TA


Miles

SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

San Bernardino Basin Area

BLACK & VEATCH Building a world of difference:





Approximate Location of Groundwater Barrier NO<sub>3</sub>-N Objective (Assimilitive Capacity) (mg/L) - -?- Location Uncertain Bunker Hill-A 310 (-20) TDS Objective (Assimilitive Capacity) 2.7 (-1.3) San Bernardino County Flood Control District Recharge Facilities Kilometers Riverside Management Zone San Bernardino County San Bernardine Water Reclamation Facility Streams, Rivers, and Flood Control Channels Orahge County Location Approximate · · · · Location Concealed County - Location Certain ( Faults

SAN BERNARDINO MUNICIPAL WATER DEPARTMENT





#### 2.0 EXISTING FACILITIES

The primary existing facilities within the area impacted by the proposed CWF Project include the SBWRP, the RIX facility, and the Recharge Basins. The SBMWD does not currently have recycled water infrastructure.

#### 2.1 SAN BERNARDINO WATER RECLAMATION PLANT

The SBWRP is located in the southern part of SBMWD's service area at 399 Chandler Place, San Bernardino, California. The SBWRP currently treats 22 mgd to secondary treatment standards using a treatment train that includes headworks, primary clarifiers, aeration systems with nitrogen removal capabilities, and secondary clarifiers. The secondary treated water is conveyed via a pipeline to the RIX Facility for tertiary treatment and discharge to the Santa Ana River. The SBWRP has a rated capacity of 33 mgd with projected treatment demands of 28 mgd by 2015, 31 mgd by 2020, and up to 35 mgd by 2030. The SBWRP will be expanded or upgraded to meet projected 2030 demands.

#### 2.2 RAPID INJECTION AND EXTRACTION (RIX) FACILITY

The RIX tertiary treatment facility is located approximately four miles southwest of the SBWRP along the Santa River (see Figure 1-1). The SBMWD and City of Colton are members of a Joint Powers Agency that owns and operates the RIX facility. The RIX facility currently treats approximately 5 mgd of secondary-treated effluent from the City of Colton and 22 mgd from the SBWRP to the tertiary level for disposal to the Santa Ana River. Secondary effluent is applied to percolation ponds and a sand filter. Following filtration by the local soils, filtered effluent is extracted and combined with effluent from the sand filter, then disinfected with ultraviolet light and discharged to the Santa Ana River. The RIX tertiary treatment facility is permitted to treat 40 mgd of secondary treated effluent and discharge up to 64 mgd of tertiary treated recycled water. It currently receives approximately 27 mgd of secondary effluent, and currently discharges approximately 36 mgd to the Santa Ana River. The SBMWD has submitted a Petition for Change to the State Water Resources Control Board to reduce the discharge at the RIX facility to 11.9 mgd. As part of the CWF project, secondary effluent from the SBWRP to the RIX facility would be reduced to approximately 4 to 7 mgd. The balance of the secondary effluent from the SBWRP would be treated to a tertiary or advanced level and utilized for recycled water customers or groundwater recharge as part of the CWF project.

#### 2.3 WATERMAN BASINS/EAST TWIN CREEK SPREADING GROUNDS

The Waterman Basins and East Twin Creek Spreading Grounds (collectively known as the Recharge Basins) will be used as the groundwater recharge facilities for the CWF Project. Total recharge that could be used as dilution water as required by CDPH Replenishment Recharge Reuse regulations is estimated at 22,700 acre-feet per year (20.2 mgd) as indicated below. Dilution water is also utilized to meet the Bunker Hill-A Basin water quality objectives.

July 2012 2-1 Summary Report

- Waterman Basins these basins capture storm water runoff and are a current recharge location for the Valley District. Estimated 10-year average storm water runoff is 2,100 acre-feet per year (1.9 mgd). Estimated Valley District recharge with State Project Water (SPW) is 10,700 acre-feet per year (9.5 mgd). The total recharge for the Waterman Basins that could be used as dilution water is 12,800 acre-feet per year (11.4 mgd).
- East Twin Creek Spreading Grounds these spreading grounds capture storm water runoff, and serve as an overflow for the Waterman Basins. The Spreading Grounds do not currently have a turnout for Valley District recharge using State Project Water, but a turnout is planned. Estimated 10-year average storm water runoff is 3,900 acre-feet per year (3.5 mgd). Estimated Valley District recharge with State Project Water is 6,000 acre-feet per year (5.3 mgd). The total recharge for the East Twin Creek Spreading Grounds that could be used as dilution water is 9,900 acre-feet per year (8.8 mgd).

The Recharge Basins are owned and operated by the San Bernardino County Flood Control District. These basins will continue to function as flood control facilities. Recycled water and advanced treated water used for groundwater recharge may be limited prior to and during storm events. Groundwater recharge flows may need to be diverted at the SBWRP to the RIX facility and Santa Ana River during storm events. During large storm events where the flow in the Santa Ana River is greater than a 20 to 1 ratio as compared to the SBWRP discharge rate, the RWQCB allows discharge at the SBWRP of secondary effluent to the Santa Ana River without tertiary and/or advanced treatment.

#### 3.0 PROPOSED FACILITIES

Six Conveyance Scenarios were developed to analyze possible configurations of conveyance facilities for the CWF Project. Configurations included:

- A single pipeline that would deliver advanced treated water to both recycled water customers and the Recharge Basins;
- Dual pipelines with one recycled water pipeline to customers and one advanced water pipeline to the Recharge Basins;
- A single pipeline that would deliver recycled water to both recycled water customers and to an advanced water treatment plant located at the Recharge Basins.

Pump stations and storage tanks were located to optimize system hydraulics and flexibility for delivery of recycled water and advanced treated water flow. Design criteria and sizing of facilities are described in Section 5.

Facilities will be required at the Waterman Basins and East Twin Creek Spreading Grounds to discharge recycled water and advanced treated water for infiltration into the Recharge Basins. Turnouts with isolation valves, meters, and concrete discharge structures would be installed at various locations along the edge of the Spreading Basins. Monitoring wells will also be required at various points within and adjacent to the Recharge Basins to monitor the flow of recycled water and advanced treated water within the groundwater basin.

The six Conveyance Scenarios are described below and evaluated in detail in the following sections of this report.

#### 3.1 CONVEYANCE SCENARIOS

Descriptions of six Conveyance Scenarios are provided below and summarized in Table 3-1. The Conveyance Scenarios are also depicted in Figures 3-1 through 3-6. Facilities have been assigned designation numbers with the first number representing the Conveyance Scenario number and second number representing the facility number (i.e. Storage Tank 1-1 is Conveyance Scenario 1 and Tank 1 within this scenario).

<u>Conveyance Scenario 1</u> – This scenario utilizes a single conveyance system to deliver advanced treated water to both direct use northern customers and the Recharge Basins, and a separate recycled water system to serve direct use customers near the SBWRP. A recycled water storage tank (Storage Tank 1-1) and pump station (Pump Station 1-1) would be located at the SBWRP to serve direct use customers near the SBWRP. An advanced water storage tank (Storage Tank 1-2) and pump station (Pump Station 1-2) would be located at the SBWRP and would convey water in Pipeline 1-1 to both direct use northern customers and the Recharge Basins. An advanced water storage tank (Storage Tank 1-3) at an intermediate location would serve a

July 2012 3-1 Summary Report

portion of direct use northern customers. Brine would be discharged to the IEBL at the SBWRP. Secondary treated effluent would be conveyed through an existing pipeline to the RIX facility.

Conveyance Scenario 2 – This scenario utilizes a single conveyance system with two lifts to deliver advanced treated water to both direct use northern customers and the Recharge Basins, and a separate recycled water system to serve direct use customers near the SBWRP. A recycled water storage tank (Storage Tank 2-1) and pump station (Pump Station 2-1) would be located at the SBWRP to serve direct use customers near the SBWRP. An advanced water storage tank (Storage Tank 2-2) and pump station (Pump Station 2-2) would be located at the SBWRP and would convey water in Pipeline 2-1 to both direct use northern customers and an intermediate storage tank (Storage Tank 2-3). Advanced water would be conveyed in a second lift by an intermediate pump station (Pump Station 2-3) through Pipeline 2-2 to a portion of direct use northern customers and to the Recharge Basins. Brine would be discharge to the IEBL at the SBWRP. Secondary treated effluent would be conveyed through an existing pipeline to the RIX facility.

Conveyance Scenario 3 – This scenario utilizes dual conveyance systems with one recycled water pipeline serving direct use northern customers and one advanced water pipeline to the Recharge Basins, and a separate recycled water system to serve direct use customers near the SBWRP. A recycled water storage tank (Storage Tank 3-1) and pump station (Pump Station 3-1) would be located at the SBWRP to serve direct use customers near the SBWRP and direct use northern customers in Pipeline 3-1. A recycled water storage tank (Storage Tank 3-3) at a northern location would serve direct use northern customers. Recycled water would be conveyed in a second lift by a northern pump station (Pump Station 3-3) through Pipeline 3-2 to the Recharge Basins. An advanced water storage tank (Storage Tank 3-2) and pump station (Pump Station 3-2) would be located at the SBWRP and would convey water in Pipeline 3-3 to the Recharge Basins. Brine would be discharged to the IEBL at the SBWRP. Secondary treated effluent would be conveyed through an existing pipeline to the RIX facility.

Conveyance Scenario 4 – This scenario utilizes dual conveyance systems with one recycled water pipeline serving direct use northern customers and one advanced water pipeline with two lifts to the Recharge Basins, and a separate recycled water system to serve direct use customers near the SBWRP. A recycled water storage tank (Storage Tank 4-1) and pump station (Pump Station 4-1) would be located at the SBWRP to serve direct use customers near the SBWRP and direct use northern customers in Pipeline 4-1. A recycled water storage tank (Storage Tank 4-3) at a northern location would serve direct use northern customers. Recycled water would be conveyed in a second lift by a northern pump station (Pump Station 4-3) through Pipeline 4-2 to the Recharge Basins. An advanced water storage tank (Storage Tank 4-2) and pump station (Pump Station 4-2) would be located at the SBWRP and would convey water in Pipeline 4-3 to an intermediate storage tank (Storage Tank 4-4). Advanced water would be conveyed in a second lift by an intermediate pump station (Pump Station 4-4) through Pipeline 4-4 to the Recharge Basins. Brine would be discharged to the IEBL at the SBWRP. Secondary treated effluent would be conveyed through an existing pipeline to the RIX facility.

July 2012 3-2 Summary Report

Conveyance Scenario 5 – This scenario utilizes a single conveyance system that would deliver recycled water to both direct use northern customers and to an advanced water treatment plant located at the Recharge Basins. A recycled water storage tank (Storage Tank 5-1) and pump station (Pump Station 5-1) would be located at the SBWRP to serve direct use customers near the SBWRP; and direct use northern customers, Recharge Basins, and an advanced treatment plant all through Pipeline 5-1. A recycled water storage tank (Storage Tank 5-2) at an intermediate location would serve a portion of direct use northern customers. A separate pipeline (Pipeline 5-2) would convey brine from an advanced treatment plant at the Recharge Basins to the SBWRP for discharge to the IEBL. Secondary treated effluent would be conveyed through an existing pipeline to the RIX facility.

Conveyance Scenario 6 – This scenario utilizes a single conveyance system with two lifts that would deliver recycled water to both direct use northern customers and to an advanced water treatment plant located at the Recharge Basins. A recycled water storage tank (Storage Tank 6-1) and pump station (Pump Station 6-1) would be located at the SBWRP to serve direct use customers near the SBWRP; and a portion of direct use northern customers through Pipeline 6-1. A recycled water storage tank (Storage Tank 6-2) at an intermediate location would serve a portion of direct use northern customers. Recycled water would be conveyed in a second lift by an intermediate pump station (Pump Station 6-2) through Pipeline 6-2 to a portion of direct use northern customers, Recharge Basins, and an advanced treatment plant. A separate pipeline (Pipeline 6-2) would convey brine from an advanced treatment plant at the Recharge Basins to the SBWRP for discharge to the IEBL. Secondary treated effluent would be conveyed through an existing pipeline to the RIX facility.





Table 3-1 Conveyance Scenarios

Scenario No.	Description	Facilities
1	Single conveyance system to deliver advanced treated water to direct use northern customers and the Recharge Basins. A separate recycled water system to serve direct use customers near SBWRP.	<ul> <li>Recycle water storage tank and pump station at SBWRP</li> <li>Advanced water storage tank and pump station at SBWRP</li> <li>Advanced water storage tank at an intermediate location</li> </ul>
2	Single conveyance system with two lifts to deliver advanced treated water to direct use northern customers and the Recharge Basins. A separate recycled water system to serve direct use customers near the SBWRP.	<ul> <li>Recycle water storage tank and pump station at SBWRP</li> <li>Advanced water storage tank and pump station at SBWRP</li> <li>Advanced water storage tank and pump station at an intermediate location</li> </ul>
3	Dual conveyance systems with one recycled water pipeline serving direct use northern customers and one advanced water pipeline to the Recharge Basins. A separate recycled water system to serve direct use customers near the SBWRP.	<ul> <li>Recycle water storage tank and pump station at SBWRP</li> <li>Recycled water storage tank and pump station at a northern location</li> <li>Advanced water storage tank and pump station at SBWRP</li> </ul>
4	Dual conveyance systems with one recycled water pipeline serving direct use northern customers and one advanced water pipeline with two lifts to the Recharge Basins. A separate recycled water system to serve direct use customers near the SBWRP.	<ul> <li>Recycle water storage tank and pump station at SBWRP</li> <li>Recycled water storage tank and pump station at a northern location</li> <li>Advanced water storage tank and pump station at SBWRP</li> <li>Advanced water storage tank and pump station at an intermediate location</li> </ul>
5	Single conveyance system to deliver recycled water to both direct use northern customers and to an advanced water treatment plant located at the Recharge Basins.	<ul> <li>Recycle water storage tank and pump station at SBWRP</li> <li>Recycled water storage tank at an intermediate location</li> <li>Advanced treatment plant at Recharge Basins</li> <li>Brine pipeline from Recharge Basins to SBWRP</li> </ul>
6	Single conveyance system with two lifts to deliver recycled water to both direct use northern customers and to an advanced water treatment plant located at the Recharge Basins.	<ul> <li>Recycle water storage tank and pump station at SBWRP</li> <li>Recycled water storage tank and pump station at an intermediate location</li> <li>Advanced treatment plant at Recharge Basins</li> <li>Brine pipeline from Recharge Basins to SBWRP</li> </ul>

July 2012 3-4 Summary Report






























































# 4.0 POTENTIAL DIRECT USE CUSTOMERS AND RECYCLED WATER DEMANDS

The CWF Project will reduce SBMWD's per capita water usage in order to comply with SBX-7, although many additional benefits will be realized including, but not limited to, increasing water supply reliability. This will be accomplished in part by converting existing potable water customers, either partially or entirely, to recycled water (direct use). Some typical uses for recycled water include irrigation, cleaning, industrial cooling, industrial processes, fire flow, refilling of lakes, and other various uses. As previously mentioned, the Recycled Water Report indicated that conventional direct recycled water distribution throughout the entire SBMWD service area is not economically feasible; however, there are several specific candidates for recycled water conversion along the recycled water conveyance alignments that may be a viable option for cost-effectively reducing per capita potable water usage. This philosophy was maintained when identifying and evaluating potential direct use customers as part of this analysis as described in the following sections.

#### 4.1 DIRECT USE CUSTOMERS

Identifying potential direct use customers began with examining the areas that were previously identified in the Recycled Water Report. Potential direct use customers in the Recycled Water Report were limited to the San Bernardino Public Golf Course; existing irrigation customers along the East Twin Creek flood control channel, including parks, schools, and golf courses; and on-site use at the SBWRP. A total of 19 irrigation customers were identified, with a total average day demand of approximately 2.8 mgd (2.1 mgd at the SBWRP and to the south and 0.7 mgd to the north). As part of this analysis, these areas were confirmed to be viable candidates for recycled water usage, and remain included in the list of potential direct use customers.

In addition to the previously identified areas, additional potential direct use customers were identified within the area proximate to the proposed conveyance pipeline alignments, generally defined as bound by I-215 Freeway to the west, the I-10 Freeway to the south, Del Rosa Drive to the east, and the Recharge Basins at the north end of the SBMWD service area totaling approximately 1.3 mgd. Presumed large users just outside of this area were also identified; however, these potential customers have been excluded from the demand calculations since their distances from the proposed conveyance pipelines may make these cost-prohibitive options. These large users are as follows:

- Montecito Memorial Park and Mortuary
- Loma Linda University
- Loma Linda Community Park
- Rancon Lake
- San Bernardino International Airport
- San Bernardino Soccer Complex

July 2012 4-1 Summary Report

For potential customer selection, emphasis was placed on those areas presumed to have the highest irrigation demands, which would include golf courses, parks, schools, cemeteries, and nurseries. As of result of further investigation, a total of 60 potential customers were identified corresponding to a total gross area of approximately 961 acres

A comprehensive list of potential direct use customers is provided in Table A-1 in Appendix A. Their areas and proximity to the conveyance pipeline Alignment Options are shown in Figures 4-1 through 4-5. Conveyance pipeline segments and alignments are described further in Section 6.

#### 4.2 RECYCLED WATER CRITERIA AND DEMANDS

In order to evaluate recycled water facility sizing and effectiveness of serving potential direct use customers, estimated water demands were calculated using gross parcel areas and water demand factors. Water demand factors were calculated according to land use category based on historic water demand data for the previously identified areas provided in the Recycled Water Report. A summary of this data is shown in Table 4-1 (see Appendix A for more detailed information). It should be noted that the SBWRP, the San Bernardino Public Golf Course, and irrigated areas along the I-215 Freeway currently receive groundwater from a well located at the SBWRP. There are also groundwater wells located at Wildwood Park and the Arrowhead Country Club. Usage of these groundwater wells may understate the actual amount of recycled water that would ultimately be needed.

Table 4-1
Existing Irrigation Water Demand

	Total	Approx	Calculated
	(AFY)	Gross Area	Demand Factor
Irrigation Customers [1]	[1]	(ac) [1]	(AFY/ac)
San Bernardino Water Reclamation Plant	1998	49 [2]	40.51
San Bernardino Public Golf Course	209.1	93	2.25
CalTrans (I-215)	100.2	15 [2]	6.89
Arrowhead Country Club	247.2	110	2.25
Mill Community Park	25.3	14	1.81
Meadowbrook Recreational Park	25.4	14	1.81
Meadowbrook Park	12.6	7	1.80
Secombe Lake State Recreational Area	56	31	1.81
Perris Hill Park	57.7	32	1.80
Horine Park	10.2	6	1.70
Wildwood Park	43.6	24	1.82
Palm Field	8.9	5	1.78
Community Gardens	27	15	1.80

July 2012 4-2 Summary Report

Table 4-1 (continued)
Existing Irrigation Water Demand

		Total (AFY)	Approx Gross Area	Calculated Demand Factor
Irrigation Customers [1]		[1]	(ac) [1]	(AFY/ac)
Pioneer Memorial Cemetery		36.7	20	1.84
Mountain View Cemetery		104.6	58	1.80
Golden Valley Middle School		16.44	16 [2]	1.02
Parkside Elementary		16.44	5 [2]	3.00
Wilson Elementary		16.44	6 [2]	2.78
Sierra High School		81.23	14 [2]	5.89
	Totals	3093	534	-

<sup>[1]</sup> Source: SBMWD Recycled Water Planning Investigation Report, Appendix B, (Wildermuth, November 2010), except as noted.

The demand factors for similar land use categories were averaged to establish demand factors for golf courses, parks, schools, nurseries, cemeteries, and public use areas (e.g., libraries, governmental buildings, etc.). Where available, demand factors based on historic water use for customers identified in the Recycled Water Report were utilized. For any additional potential customers, the demand factors were increased to form more conservative planning factors to allow for some variability for future demands. These water demand factors are listed in Table 4-2.

Table 4-2
Water Demand Factors

	Avg Demand Factor (Historic)	Planning Demand Factor
Land Use Category	(AFY/ac)	(AFY/ac) [1]
Golf Courses (GC)	2.25	2.5
Parks (PK)	1.79	2.0
Schools (SC)	2.78	4.0
Nursery (N)	1.80	2.0
Cemeteries (C)	1.82	2.0
Public Use (PB) [2]	-	3.0
Caltrans (CT) [3]	-	2.0

<sup>[1]:</sup> Note: Planning factor corresponds to gross area.

<sup>[2]</sup> Gross area based on County of San Bernardino GIS data.

<sup>[2]:</sup> Planning factor for Public Use category is based upon a 75 percent irrigated ratio as compared to Schools.

<sup>[3]:</sup> Planning factor for Caltrans category is based upon the Parks land use category applied to the irrigated portion of Caltrans land use.

Water demand peaking factors were also established to account for the variations in demands that typically occur seasonally, daily, and hourly. Four pertinent demand conditions were considered, including average day demand (ADD), maximum month demand (MMD), maximum day demand (MDD), and peak hour demand (PHD) during a maximum day. Maximum month demand represents the month with the highest amount of water usage, typically occurring in the hottest month of the year during summer. This factor was calculated as 1.3 times the average day demand from the Recycled Water Report. Similarly, maximum day demand represents the single day of the year with the highest amount of water usage. Although the Recycled Water Report concluded that the maximum day factor was equivalent to the maximum month factor of 1.3 times the average day demand based on the premise that irrigation schedules are usually varied on a seasonal basis rather than a daily basis, this factor was increased to a more conservative value of 2.0 to allow for some variation in demand throughout the month. The peak hour demand factor was calculated as 3.0 times the maximum day demand based on an 8-hour irrigation window per 24-hours, since irrigation typically occurs during a limited period during the late night hours and early morning hours. A summary of the water demand peaking factors is provided in Table 4-3.

Table 4-3
Water Demand Peaking Factors

Demand Condition	<b>Peaking Factor</b>
Average Day Demand (ADD)	-
Maximum Month Demand (MMD)	1.3 x ADD
Maximum Day Demand (MDD)	2.0 x ADD
Peak Hour Demand (PHD)	3.0 X MDD

A detailed summary of potential direct use customers, land use categories, gross areas, and estimated demands is provided in Table A-1 in Appendix A. It should be noted that this analysis does not take into consideration potential future changes in land use or future projects that may need or want recycled water service.

For development of pipeline, pump station, and storage tank capacity, the direct use demands were evaluated and are summarized in Table 4-4. Direct use customers were split into two groups: (1) northern users, and (2) users at the SBWRP and southern users. The groups will have separate pipeline, pump station and storage tank facilities for service due to their location.

Table 4-4 Water Demands

Direct Users	Demand Condition	Demand
Northern	Average Day Demand (ADD)	2.0 mgd (2,219 AF/yr)
	Maximum Month Demand (MMD)	2.6 mgd (2,884 AF/yr)
	Maximum Day Demand (MDD)	4.0 mgd (4,437 AF/yr)
	Peak Hour Demand (PHD)	12.0 mgd (13,311 AF/yr)
At SBWRP and Southern	Average Day Demand (ADD)	2.1 mgd (2,307 AF/yr)
	Maximum Month Demand (MMD)	2.7 mgd (2,999 AF/yr)
	Maximum Day Demand (MDD)	4.2 mgd (4,614 AF/yr)
	Peak Hour Demand (PHD)	12.6 mgd (13,842 AF/yr)






1040











# 5.0 PRELIMINARY FACILITY SIZING

Preliminary facility sizing was developed for recycled water and advanced treated water facilities. Primary facilities included transmission pipelines, pump stations, and storage reservoirs. Design criteria were developed for each type of facility and is listed in Table 5-1.

Table 5-1 Design Criteria

Facility	Description	Criteria
Pipelines	Capacity, Transmission	Maximum Day Demand (MDD)  Consider Average Day Demand for Recharge alternating with MDD for Recycled Water
	Capacity, Distribution	Peak Hour Demand for Recycled Water
	Velocity	6 feet per second (fps)
	Roughness	Hazen-Williams C=130 (Pipe Dia. ≥ 14") Hazen-Williams C=120 (Pipe Dia. ≤ 12")
	Pressure, pipe	150 psi (to match valve/pipe classes) 250 psi (to match valve/pipe classes)
	Pressure, pipe class	Minimum Thickness Class 50 for Ductile Iron Pipe
	Pressure, design	Design Pressure = Operating + Surge
	Material, < 48 inch Dia.	Ductile Iron Pipe with cement mortar lining and seal coat per AWWA C-104 Bituminous coating per AWWA C-151
	Alternative Materials, < 48 inch Dia.	Steel Pipe per AWWA C-200 with cement mortar lining and coating. PVC Pipe per AWWA C900/C905 HDPE Pipe per AWWA C906
	Material, ≥ 48 inch Dia.	Steel Pipe per AWWA C-200 with cement mortar lining and coating
	Easements	25-foot minimum width
	Depth of Cover	3 feet in street 3 feet if established grade, Pipe Dia. ≤ 12" 3.5 feet if established grade, Pipe Dia. > 12" 5 feet for open areas (no established grade)

July 2012 5-1 Summary Report

Table 5-1 (continued)
Design Criteria

Facility	Description	Criteria
Pump Stations	Capacity	Maximum Day Demand (MDD). Consider Average Day Demand for Recharge alternating with MDD for Recycled Water. Peak Hour Demand (PHD) for closed loop.
	Number of Pumps	For Capacity + one spare
	Backup Power	Provide access for hookup of portable emergency generator. Quick connection per SBMWD Dwg. W11.9, W11.10, W11.11.
	Operation	Simple operation desired.  Consider Variable Frequency Drives (VFDs) for flexibility/optimization of capital and  O&M costs
	Architecture	Blend in with neighborhood
	Access	Accommodate 30-foot long vehicles
Storage Tanks	Volume	Tank: Maximum Day Demand for Recycled Water Forebay: 20 minutes Average Day Demand for Advanced Water
	Туре	Round, pre-stressed concrete (above ground)
	Alternative Types	Round, steel (above ground) Rectangular, cast-in-place (above or below ground)
	Operation	Allow for shutdowns for inspection every 3 to 5 years
	Access	Accommodate 30-foot long vehicles

Preliminary facility sizing was based on the SBWRP capacity of 33 mgd, advanced water treatment and conveyance sizing, recycled water treatment and conveyance sizing, brine disposal IEBL capacity of 2.5 mgd, and secondary treated flows to the RIX facility.

#### 5.1 ADVANCED TREATED WATER CONVEYANCE FACILITIES OVERVIEW

Advanced treated water conveyance facilities include pipelines, pump stations, and storage tanks to provide advanced treated water to direct use northern customers and/or Recharge Basins. The various advanced water Conveyance Scenarios provide for either a single combined conveyance pipeline that would serve both direct use northern customers and

July 2012 5-2 Summary Report

Recharge Basins, or a dual conveyance pipelines where one pipeline would be dedicated to providing advanced treated water to Recharge Basins and one pipeline would be dedicated to providing conventional recycled water to Recharge Basins and direct use customers for irrigation. In either case, the maximum capacity of the advanced water pipeline would be sized for 14.2 mgd (limited by IEBL capacity for brine disposal from advanced treatment). Pump stations are sized for pumping flow to the Recharge Basins in one lift, or to an intermediate storage tank then to the Recharge Basins in two lifts using a second pump station located near the intermediate storage tank. The maximum pump discharge pressures are approximately 250 psi for the one lift configuration, and 150 psi for the two lift configuration. Storage tanks are sized for direct use Maximum Day Demand (MDD) if recycled water customers are served using advanced treated water. For advanced water to Recharge Basins only conveyance scenario, storage tanks are sized as pump station forebays only. Where disposal of brine is required from an advanced treatment plant located at the Recharge Basins, the brine pipeline would be a gravity pipeline sized for 2.5 mgd.

#### 5.2 RECYCLED WATER CONVEYANCE FACILITIES OVERVIEW

Recycled water conveyance facilities include pipelines, pump stations, and storage tanks to provide recycled water to direct use northern customers and/or Recharge Basins. The various conventional recycled water Conveyance Scenarios provide for either a single recycled water conveyance pipeline that would serve both direct use northern customers and Recharge Basins, or a single recycled water conveyance pipeline that would serve direct use northern customers, Recharge Basins, and an advanced treatment plant located at the Recharge Basins. The maximum capacity of the conventional recycled water pipeline segments are 7.0 mgd for combined direct use northern customers and groundwater recharge (limited by direct use customers and dilution in Recharge Basins); 5.0 mgd for groundwater recharge; and 25.2 mgd for combined to direct use northern customers, groundwater recharge, and advanced treatment. Pump stations are sized for pumping flow to the Recharge Basins in one lift, or to an intermediate storage tank then to the Recharge Basins in two lifts using a second pump station located near the intermediate storage tank. The maximum pump discharge pressures are approximately 250 psi for the one lift configuration, and 150 psi for the two lift configuration. Storage tanks are sized for direct use MDD for the appropriate segment of direct use demand.

#### 5.3 CONVEYANCE SCENARIOS FACILITY SIZING

The following section summarizes the preliminary facility sizing for transmission pipelines, pump stations, and storage reservoirs under each conveyance scenario identified in Section 3 and are shown on Figures 5-1 through 5-6. It should be noted that a range of lengths are shown for each pipeline. This is because the actual length of each pipeline will depend on the final alignment selected for each. The potential alignments for the transmission mains are discussed in detail in Section 6, and summarized on Table A-2 in Appendix A

July 2012 5-3 Summary Report

#### 5.3.1 Conveyance Scenario 1

• Pipeline 1-1: Advanced water pipeline from SBWRP to Recharge Basins with capacity for combined direct reuse northern customers and groundwater recharge.

- Capacity: 14.2 mgd [2.0 mgd (Direct Use, ADD) + 12.2 mgd (Basins)]

- Velocity: 6 fps- Diameter: 30 inch

- Length: 38,460 to 42,900 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 250 psi

• Pump Station 1-1: Recycled water pump station at SBWRP for transmission to direct reuse customers near SBWRP.

- Capacity: 12.6 mgd (8,750 gpm) PHD

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 4,400 gpm each, 250 HP each

• Pump Station 1-2: Advanced water pump station at SBWRP for transmission to combined direct reuse northern customers and groundwater recharge, and an intermediate storage tank (Storage Tank 1-3).

- Capacity: 14.2 mgd (9,860 gpm)

- Pressure: 250 psi

- Pumps: 4 pumps (3 operating + 1 spare), 3,300 gpm each, 600 HP each

• Storage Tank 1-1: Recycled water storage tank at SBWRP with capacity for direct reuse customers near SBWRP.

- Capacity: 4.2 million gallons (MDD)

• Storage Tank 1-2: Advanced water storage tank at SBWRP with capacity for a portion of direct reuse northern customers.

- Capacity: 3.2 million gallons (MDD)

• Storage Tank 1-3: Advanced water storage tank at intermediate location with capacity for a portion of direct reuse northern customers.

- Capacity: 0.8 million gallons (MDD)

## 5.3.2 Conveyance Scenario 2

 Pipeline 2-1: Advanced water pipeline from SBWRP to Storage Tank 2-3 with capacity for direct reuse northern customers and groundwater recharge.

- Capacity: 14.2 mgd [2.0 mgd (Direct Use, ADD) + 12.2 mgd (Basins)]

- Velocity: 6 fps- Diameter: 30 inch

- Length: 24,500 to 28,200 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 30 to 100 psi

• Pipeline 2-2: Advanced water pipeline from Storage Tank 2-3 to Recharge Basins with capacity for a portion of direct reuse northern customers and groundwater recharge.

- Capacity: 14.2 mgd [2.0 mgd (Direct Use, ADD) + 12.2 mgd (Basins)]

- Velocity: 6 fps- Diameter: 30 inch

- Length: 13,900 to 16,600 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 150 psi

• Pump Station 2-1: Recycled water pump station at SBWRP for transmission to direct reuse customers near SBWRP.

- Capacity: 12.6 mgd (8,750 gpm) PHD

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 4,400 gpm each, 250 HP each

• Pump Station 2-2: Advanced water pump station at SBWRP for transmission to combined direct reuse northern customers and groundwater recharge and an intermediate tank (Storage Tank 2-3).

- Capacity: 14.2 mgd (9,860 gpm)

- TDH: 100 psi

- Pumps: 4 pumps (3 operating + 1 spare), 3,300 gpm each, 250 HP each

• Pump Station 2-3: Advanced water pump station at an intermediate location for transmission to a portion of direct reuse northern customers and groundwater recharge.

- Capacity: 14.2 mgd (9,860 gpm)

- Pressure: 150 psi

- Pumps: 4 pumps (3 operating + 1 spare), 3,300 gpm each, 400 HP each

• Storage Tank 2-1: Recycled water storage tank at SBWRP with capacity for direct reuse customers near SBWRP.

- Capacity: 4.2 million gallons (MDD)

• Storage Tank 2-2: Advanced water storage tank at SBWRP with capacity for a portion of direct reuse northern customers.

- Capacity: 1.6 million gallons (MDD)

• Storage Tank 2-3: Advanced water storage tank at an intermediate location with capacity for a portion of direct reuse northern customers.

- Capacity: 2.4 million gallons (MDD)

#### 5.3.3 Conveyance Scenario 3

 Pipeline 3-1: Recycled water pipeline from SBWRP to Storage Tank 3-3 with capacity for direct reuse and groundwater recharge.

- Capacity: 7.0 mgd [2.0 mgd (Direct Use, ADD) + 5.0 mgd (Basins)]

- Velocity: 6 fps- Diameter: 20 inch

- Length: 35,200 to 38,800 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 30 to 250 psi

• Pipeline 3-2: Recycled water pipeline from Storage Tank 3-3 to Recharge Basins with capacity for groundwater recharge.

- Capacity: 5.0 mgd (Basins)

- Velocity: 6 fps- Diameter: 16 inch

- Length: 3,300 to 6,000 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 80 psi

 Pipeline 3-3: Advanced water pipeline from SBWRP to Recharge Basins with capacity for groundwater recharge.

- Capacity: 14.2 mgd (Basins)

- Velocity: 6 fps- Diameter: 30 inch

- Length: 38,460 to 42,900 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 250 psi

 Pump Station 3-1: Recycled water pump station at SBWRP with two sets of pumps – one set for transmission to direct reuse customers near SBWRP, and one set for transmission to combined direct reuse northern customers and groundwater recharge.

- Recycled Water Pumps (to SBWRP Direct Users):

- Capacity: 12.6 mgd (8,750 gpm) PHD

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 4,400 gpm each, 250 HP each

- Recycled Water Pumps (to Northern Direct Users and Storage Tank 3-3):

- Capacity: 7.0 mgd (4,860 gpm)

- Pressure: 250 psi

- Pumps: 3 pumps (2 operating + 1 spare), 2,500 gpm each, 450 HP each

• Pump Station 3-2: Advanced water pump station at SBWRP for transmission to groundwater recharge.

- Capacity: 14.2 mgd (9,860 gpm)

- Pressure: 250 psi

- Pumps: 4 pumps (3 operating + 1 spare), 3,300 gpm each, 600 HP each

 Pump Station 3-3: Recycled water pump station at an intermediate location for transmission to groundwater recharge.

- Capacity: 5.0 mgd (3,475 gpm)

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 1,750 gpm each, 100 HP each

• Storage Tank 3-1: Recycled water storage tank at SBWRP with capacity for direct reuse customers near SBWRP.

- Capacity: 4.3 million gallons [4.2 million gallons (MDD) + 0.1 million gallons (pumping forebay)]

• Storage Tank 3-2: Advanced water storage tank at SBWRP with capacity for use as a pumping forebay.

- Capacity: 0.2 million gallons

• Storage Tank 3-3: Recycled water storage tank at a northern location with capacity for direct reuse northern customers.

- Capacity: 4.0 million gallons (MDD)

#### 5.3.4 Conveyance Scenario 4

• Pipeline 4-1: Recycled water pipeline from SBWRP to Storage Tank 4-3 with capacity for direct reuse and groundwater recharge.

- Capacity: 7.0 mgd [2.0 mgd (Direct Use, ADD) + 5.0 mgd (Basins)]

- Velocity: 6 fps- Diameter: 20 inch

- Length: 35,200 to 38,800 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 30 to 250 psi

 Pipeline 4-2: Recycled water pipeline from Storage Tank 4-3 to Recharge Basins with capacity for groundwater recharge.

- Capacity: 5.0 mgd (Basins)

- Velocity: 6 fps- Diameter: 16 inch

- Length: 3,300 to 6,000 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 80 psi

• Pipeline 4-3: Advanced water pipeline from SBWRP to Storage Tank 4-4 with capacity for groundwater recharge.

- Capacity: 14.2 mgd (Basins)

- Velocity: 6 fps- Diameter: 30 inch

- Length: 24,500 to 28,200 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 30 to 100 psi

• Pipeline 4-4: Advanced water pipeline from Storage Tank 4-4 to Recharge Basins with capacity for groundwater recharge.

- Capacity: 14.2 mgd (Basins)

- Velocity: 6 fps- Diameter: 30 inch

- Length: 13,900 to 16,600 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 150 psi

• Pump Station 4-1: Recycled water pump station at SBWRP with two sets of pumps – one set for transmission to direct reuse customers near SBWRP, and one set for transmission to combined direct reuse northern customers and groundwater recharge.

- Recycled Water Pumps (to SBWRP Direct Users):

- Capacity: 12.6 mgd (8,750 gpm) PHD

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 4,400 gpm each, 250 HP each

- Recycled Water Pumps (to Northern Direct Users and Storage Tank 4-3):

- Capacity: 7.0 mgd (4,860 gpm)

- Pressure: 250 psi

- Pumps: 3 pumps (2 operating + 1 spare), 2,500 gpm each, 450 HP each

• Pump Station 4-2: Advanced water pump station at SBWRP for transmission to groundwater recharge and intermediate tank (Storage Tank 4-4).

- Capacity: 14.2 mgd (9,860 gpm)

- Pressure: 100 psi

- Pumps: 4 pumps (3 operating + 1 spare), 3,300 gpm each, 250 HP each

• Pump Station 4-3: Recycled water pump station at an intermediate location for transmission to groundwater recharge.

- Capacity: 5.0 mgd (3,475 gpm)

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 1,750 gpm each, 100 HP each

• Pump Station 4-4: Advanced water pump station at an intermediate location for transmission to groundwater recharge

- Capacity: 14.2 mgd (9,860 gpm)

- Pressure: 150 psi

- Pumps: 4 pumps (3 operating + 1 spare), 3,300 gpm each, 400 HP each

- Storage Tank 4-1: Recycled water storage tank at SBWRP with capacity for direct reuse customers near SBWRP.
  - Capacity: 4.3 million gallons [4.2 million gallons (MDD) + 0.1 million gallons (pumping forebay)]
- Storage Tank 4-2: Advanced water storage tank at SBWRP with capacity for use as a pumping forebay.
  - Capacity: 0.2 million gallons
- Storage Tank 4-3: Recycled water storage tank at a northern location with capacity for direct reuse northern customers.
  - Capacity: 4.0 million gallons (MDD)
- Storage Tank 4-4: Advanced water storage tank at an intermediate location for use as a pumping forebay and intermediate storage for groundwater recharge.
  - Capacity: 0.2 million gallons

#### 5.3.5 Conveyance Scenario 5

- Pipeline 5-1: Recycled water pipeline from SBWRP to Advanced Treatment at Recharge Basins with capacity for combined direct reuse northern customers and treatment for groundwater recharge.
  - Capacity: 25.2 mgd [2.0 mgd (Direct Use, ADD) + 5.0 mgd (Basins) + 18.2 mgd

(Advanced Treatment Plant)]

- Velocity: 6 fps- Diameter: 36 inch

- Length: 38,460 to 42,900 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 250 psi

- Pipeline 5-2: Brine pipeline from Advanced Treatment at Recharge Basins to SBWRP (IEBL Pipeline) with capacity for waste brine.
  - Capacity: 2.5 mgd (Brine)

- Velocity: 6 fps

- Diameter: 12 inch

- Length: 38,460 to 42,900 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 5 to 15 psi (Gravity line)

- Pump Station 5-1: Recycled water pump station at SBWRP with two sets of pumps one set for transmission to direct reuse customers near SBWRP, and one set for transmission to combined direct reuse northern customers and advanced water treatment at Recharge Basins.
  - Recycled Water Pumps (to SBWRP Direct Users):

- Capacity: 12.6 mgd (8,750 gpm) PHD

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 4,400 gpm each, 250 HP each

- Recycled Water Pumps (to Northern Direct Users, Advanced Treatment at Recharge Basins, and Storage Tank 5-2):

- Capacity: 25.2 mgd (17,500 gpm)

- Pressure: 250 psi

- Pumps: 4 pumps (3 operating + 1 spare), 5,830 gpm each, 1,000 HP each

• Storage Tank 5-1: Recycled water storage tank at SBWRP with capacity for direct reuse customers near SBWRP and a portion of direct reuse northern customers.

- Capacity: 7.4 million gallons [4.2 million gallons (MDD) + 3.2 million gallons (MDD)]

• Storage Tank 5-2: Recycled water storage tank at intermediate location with capacity for a portion of direct reuse northern customers.

- Capacity: 0.8 million gallons (MDD)

## 5.3.6 Conveyance Scenario 6

• Pipeline 6-1: Recycled water pipeline from SBWRP to Storage Tank 6-2 with capacity for combined direct reuse northern customers and treatment for groundwater recharge.

- Capacity: 25.2 mgd [2.0 mgd (Direct Use, ADD) + 5.0 mgd (Basins) + 18.2 mgd

(Advanced Treatment Plant)]

- Velocity: 6 fps- Diameter: 36 inch

- Length: 24,500 to 28,200 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 30 to 100 psi

 Pipeline 6-2: Recycled water pipeline from Storage Tank 6-2 to Advanced Treatment at Recharge Basins with capacity for combined direct reuse northern customers and treatment for groundwater recharge

- Capacity: 25.2 mgd [2.0 mgd (Direct Use, ADD) + 5.0 mgd (Basins) + 18.2 mgd

(Advanced Treatment Plant)]

- Velocity: 6 fps- Diameter: 36 inch

- Length: 13,900 to 16,600 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 15 to 150 psi

• Pipeline 6-3: Brine pipeline from Advanced Treatment at Recharge Basins to SBWRP (IEBL Pipeline) with capacity for waste brine

- Capacity: 2.5 mgd (Brine)

- Velocity: 6 fps- Diameter: 12 inch

- Length: 38,460 to 42,900 feet

- Material: AWWA C104 Ductile Iron Pipe

- Pressure: 5 to 15 psi (Gravity line)

• Pump Station 6-1: Recycled water pump station at SBWRP with two sets of pumps – one set for transmission to direct recycled water reuse customers near SBWRP and one set for transmission to combined direct water reuse northern customers and advanced water treatment at Recharge Basins and intermediate tank (Storage Tank 6-2).

- Recycled Water Pumps (to SBWRP Direct Users):

- Capacity: 12.6 mgd (8,750 gpm) PHD

- Pressure: 80 psi

- Pumps: 3 pumps (2 operating + 1 spare), 4,400 gpm each, 250 HP each

- Recycled Water Pumps (to Northern Direct Users, Advanced Treatment at Recharge Basins, and Storage Tank 6-2):

- Capacity: 25.2 mgd (17,500 gpm)

- Pressure: 100 psi

- Pumps: 4 pumps (3 operating + 1 spare), 5,830 gpm each, 450 HP each


 Pump Station 6-2: Recycled water pump station at an intermediate location for transmission to a portion of direct reuse northern customers and advanced water treatment at Recharge Basins.

- Capacity: 25.2 mgd (17,500 gpm)

- Pressure: 150 psi

- Pumps: 4 pumps (3 operating + 1 spare), 5,830 gpm each, 600 HP each

- Storage Tank 6-1: Recycled water storage tank at SBWRP with capacity for direct reuse customers near SBWRP and a portion of direct reuse northern customers.
  - Capacity: 5.8 million gallons [4.2 million gallons (MDD) + 1.6 million gallons (MDD)]
- Storage Tank 6-2: Recycled water storage tank at an intermediate location with capacity for a portion of direct reuse northern customers.
  - Capacity: 2.4 million gallons (MDD)








SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Conveyance Scenarios Facility Sizing









SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Conveyance Scenarios Facility Sizing



























# 6.0 PRELIMINARY HYDRAULIC ANALYSIS

A preliminary hydraulic analysis was conducted utilizing the preliminary facility sizing criteria described in Section 5 for pipelines, pump stations, and storage tanks for each conveyance scenario. The hydraulic analysis calculations are included in Appendix B. The preliminary hydraulic analysis was conducted for the six Conveyance Scenarios and three Alignment Options. A Hazen-Williams coefficient of C=130 was utilized for pipelines with a diameter greater than 12-inches and a C=120 for pipelines with a diameter of 12-inches or less. The calculated total head loss (friction and minor losses) for delivery from the SBWRP to the spreading basins varied from approximately 90 to 100 feet. Hydraulic profiles for Conveyance Scenarios 1-6 are shown on Figures 6-1 to 6-9.

# 6.1 ADVANCED TREATED WATER CONVEYANCE FACILITIES

Conveyance Scenarios 1 through 4 include advanced treated water facilities. Operations for each conveyance scenario for advanced treated water were considered to develop the hydraulic analysis and are described below.

Conveyance Scenario 1 – Advanced treated water will be produced at the SBWRP with brine concentrate discharged to the IEBL and product water delivered to a finished water storage tank on site (Storage Tank 1-2). The finished water storage tank was sized for distribution of MDD to direct use northern customers. Peak hour direct use demands can be met with the storage volume. Seasonal direct use demands will fluctuate and can be addressed by adjusting flows to Recharge Basins. The pump station (Pump Station 1-2) will be located on site and will use Storage Tank 1-2 as the forebay and will pump to direct use northern customers, Storage Tank 1-3, and to the Recharge Basins. The delivery to multiple locations allows flexibility to serve varying direct use demands and overall annual input to the Recharge Basins. Pressure to Storage Tank 1-3 will be reduced with a pressure regulating valve (PRV). Storage Tank 1-3 will serve a selected group of direct users in an intermediate location along the alignment.

Conveyance Scenario 2 – Advanced treated water will be produced at the SBWRP with brine concentrate discharged to the IEBL and product water delivered to a finished water storage tank on site (Storage Tank 2-2). The finished water storage tank was sized for distribution of MDD to a portion of direct use northern customers. Peak hour direct use demands can be met with the storage volume. The pump station (Pump Station 2-2) will be located on site and will use Storage Tank 2-2 as the forebay and will pump to a portion direct use northern customers and Storage Tank 2-3. Storage Tank 2-3 will be located at an intermediate location along the alignment and will serve a selected group of direct users. Pump Station 2-3 will be located at the same intermediate location and will use Storage Tank 2-3 as a forebay and will pump to a portion of direct use northern customers and to the Recharge Basins. Seasonal direct use demands will fluctuate and can be addressed by adjusting overall flows to the Recharge Basins.

July 2012 6-1 Summary Report

<u>Conveyance Scenario 3</u> – Advanced treated water will be produced at the SBWRP with brine concentrate discharged to the IEBL and product water delivered to a finished water storage tank on site (Storage Tank 3-2). The finished water storage tank was sized as a forebay only for Pump Station 3-2. The pump station (Pump Station 3-2) will be located on site and will use Storage Tank 3-2 as the forebay and will pump to the Recharge Basins.

Conveyance Scenario 4 – Advanced treated water will be produced at the SBWRP with brine concentrate discharged to the IEBL and product water delivered to a finished water storage tank on site (Storage Tank 4-2). The finished water storage tank was sized as a forebay only for Pump Station 4-2. The pump station (Pump Station 4-2) will be located on site and will use Storage Tank 4-2 as the forebay and will pump to Storage Tank 4-4. Storage Tank 4-4 will be located at an intermediate location along the alignment and will allow two head lifts of advanced treated water to reduce pipeline pressures. Pump Station 4-4 will be located at the same intermediate location and will use Storage Tank 4-4 as a forebay and will pump to the Recharge Basins.

#### 6.2 RECYCLED WATER CONVEYANCE FACILITIES

Conveyance Scenarios 1 through 6 include recycled water facilities. Operations for each conveyance scenario were considered for recycled water to develop the hydraulic analysis and are described below.

Conveyance Scenarios 1 and 2 – Recycled water will be produced at the SBWRP with product water delivered to a finished water storage tank on site (Storage Tank 1-1 or 2-1). The finished water storage tank was sized for distribution of MDD to direct use customers near the SBWRP. Peak hour direct use demands can be met with varying pumping rate. Seasonal direct use demands will fluctuate and can be addressed by varying the tertiary water produced at the treatment plant, releasing excess tertiary water to the RIX facility and Santa Ana River, or providing a large seasonal storage tank. The pump station (Pump Station 1-1 or 2-1) will be located on site and will use the finished water storage tank as the forebay and will pump to direct use customers near the SBWRP.

Conveyance Scenario 3 and 4 – Recycled water will be produced at the SBWRP with product water delivered to a finished water storage tank on site (Storage Tank 3-1 or 4-1). The finished water storage tank was sized for distribution of MDD to direct use customers near the SBWRP and as a forebay for pumping to northern direct use customers. Peak hour direct use demands can be met with varying pumping rate. The pump station (Pump Station 3-1 or 4-1) will be located on site and will use the finished water storage tank as the forebay and one set of pumps will pump to direct use customers near the SBWRP, and another set of pumps will pump to direct use northern customers and a northern storage tank (Storage Tank 3-3 or 4-3). Peak hour direct use northern customer demands will be met with Storage Tank 3-3 or 4-3. Storage Tank 3-3 or 4-3 will be located at a northern location along the alignment and will serve direct use northern customers. Pump Station 3-3 or 4-3 will be located at the same northern location and


July 2012 6-2 Summary Report

will use northern storage tank (Storage Tank 3-3 or 4-3) as a forebay and will pump to the Recharge Basins. Seasonal direct use demands will fluctuate and can be addressed by adjusting overall flows to the Recharge Basins.

Conveyance Scenario 5 – Recycled water will be produced at the SBWRP with product water delivered to a finished water storage tank on site (Storage Tank 5-1). The finished water storage tank was sized for distribution of MDD to direct use customers near the SBWRP. Peak hour direct use demands can be met with varying pumping rate. The pump station (Pump Station 5-1) will be located on site and will use the finished water storage tank as the forebay and one set of pumps will pump to direct use customers near the SBWRP, and another set of pumps will pump to direct use northern customers, Storage Tank 5-2, the Recharge Basins, and to advanced treatment at the Recharge Basins. The delivery to multiple locations allows flexibility to serve varying direct use demands and overall annual input to the Recharge Basins. Pressure to Storage Tank 5-2 will be reduced with a pressure regulating valve (PRV). Storage Tank 5-2 will serve a selected group of direct users in an intermediate location along the alignment. Seasonal direct use demands will fluctuate and can be addressed by adjusting overall flows to the Recharge Basins. A pipeline will be required to convey brine from the advanced treatment at the Recharge Basins to the SBWRP and IEBL.

Conveyance Scenario 6 – Recycled water will be produced at the SBWRP with product water delivered to a finished water storage tank on site (Storage Tank 6-1). The finished water storage tank was sized for distribution of MDD to direct use customers near the SBWRP. Peak hour direct use demands can be met with varying pumping rate. The pump station (Pump Station 6-1) will be located on site and will use the finished water storage tank as the forebay and one set of pumps will pump to direct use customers near the SBWRP, and another set of pumps will pump to direct use northern customers and Storage Tank 6-2. Storage Tank 6-2 will serve a selected group of direct users in an intermediate location along the alignment. Pump Station 6-2 will be located at the same intermediate location and will use Storage Tank 6-2 as a forebay and will pump to a portion of direct use northern customers, to the Recharge Basins, and to advanced treatment at the Recharge Basins. Seasonal direct use demands will fluctuate and can be addressed by adjusting overall flows to the Recharge Basins. A pipeline will be required to convey brine from the advanced treatment at the Recharge Basins to the SBWRP and IEBL.






SAN BERNARDINO MUNICIPAL WATER DEPARTMENT Hydraulic Profile Pipeline 1-1: Advanced Treated Water










**Hydraulic Profile** SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Pipelines 2-1 & 2-2: Advanced Treated Water









**Hydraulic Profile** Pipelines 3-1 and 3-2: Recycled Water SAN BERNARDINO MUNICIPAL WATER DEPARTMENT








# **Hydraulic Profile** Pipeline 3-3: Advanced Treated Water








**Hydraulic Profile** Pipelines 4-1 & 4-2: Recycled Water SAN BERNARDINO MUNICIPAL WATER DEPARTMENT








**Hydraulic Profile** Pipelines 4-3 & 4-4: Advanced Treated Water



Building a world of difference:






**Hydraulic Profile** Pipeline 5-1: Recycled Water SAN BERNARDINO MUNICIPAL WATER DEPARTMENT










**Hydraulic Profile** Pipelines 6-1 & 6-2: Řecycled Water SAN BERNARDINO MUNICIPAL WATER DEPARTMENT









Hydraulic Profile Pipeline 5-1 & 6-1: Brine Water SAN BERNARDINO MUNICIPAL WATER DEPARTMENT







# 7.0 FACILITY REQUIREMENTS

As discussed in the preceding sections, there will be pumping facilities located at the SBWRP and, depending on the conveyance scenario that is selected, there may be intermediate pump station and reservoir sites between the SBWRP and the Recharge Basins. To assist the SBMWD in determining the facility space and land acquisition requirements, we have developed typical site layouts for a reservoir site, a pumping station site, and a site which combines both facilities.

#### 7.1 TYPICAL STORAGE RESERVOIR SITE

It is assumed that an individual storage reservoir site would include one circular reservoir constructed of either welded steel or prestressed concrete. In order to determine typical site requirements, we have assumed the following:

- Minimum 25-foot clear drivable access around entire reservoir.
- One side of reservoir to have 45-foot clear space to ensure space for yard piping, valve vaults, electrical equipment and vehicle access.
- Landscaping buffer 10 feet wide on all sides.
- 30-foot-wide driveway access and 20-foot wide gate.
- Fencing on property lines and right-of-way line.

The minimum amount of land required will be dependent on the size of storage reservoir, as shown on Figure 7-1. For example, a 100-foot diameter reservoir will require a parcel with minimum dimensions of 170 feet x 190 feet, or approximately 0.75 acres.

# 7.2 TYPICAL PUMPING STATION SITE

It is assumed that an individual pumping station site would include a simple rectangular building of concrete masonry unit (CMU) block construction. It is anticipated that the building will house pumps and electrical equipment. In order to determine typical site requirements, we have assumed the following:

- Minimum 25-foot clear drivable access around entire building.
- 50-foot clear space from the building on two sides to ensure space for yard piping, valve vaults, flow meter, surge tank, electrical equipment, and space provisions for connecting a portable backup generator.
- Landscaping buffer 10 feet wide on all sides.
- 30-foot-wide driveway access and 20-foot wide gate.
- Fencing on property lines and right-of-way line.

The minimum amount of land required will be dependent on the size of the building, as shown on Figure 7-1. For example, a 20 foot x 40 foot building will require a parcel with minimum dimensions of 115 feet x 135 feet, or approximately 0.36 acres.

#### 7.3 TYPICAL COMBINED STORAGE RESERVOIR/PUMPING STATION SITE

Two optional configurations have been developed for a site that combines a storage reservoir and pump station. It is assumed that the site would accommodate one circular reservoir constructed of either welded steel or prestressed concrete, and one rectangular CMU block pump building. The difference between the options is the orientation of the pump building as shown on Figure 7-2. In order to determine typical site requirements, we have assumed the following:

# Option A

- Minimum 25-foot clear drivable access around entire reservoir and building footprints.
- A minimum of 40 feet clear between the reservoir and pump building.
- A 50-foot clear area immediately in front of the access driveway to ensure space for yard piping, valve vaults, flow meter, surge tank, electrical equipment, and space provisions for connecting a portable backup generator.
- Landscaping buffer 10 feet wide on all sides.
- 30-foot-wide driveway access and 20-foot wide gate.
- Fencing on property lines and right-of-way line.


The minimum amount of land required will be dependent on the sizes of the reservoir and building, as shown on Figure 7-2. For example, a 100 foot diameter reservoir and a 20 foot x 40 foot building will require a parcel with minimum dimensions of 170 feet x 250 feet, or approximately 0.98 acres.


# Option B

- Minimum 25-foot clear drivable access around entire reservoir and building footprints.
- A minimum of 40 feet clear between the reservoir and pump building.
- A 50-foot clear area immediately in front of the access driveway to ensure space for yard piping, valve vaults, flow meter, surge tank, electrical equipment, and space provisions for connecting a portable backup generator.
- Landscaping buffer 10 feet wide on all sides.
- 20-foot-wide driveway access centered between the reservoir and pump building.
- Fencing on property lines and right-of-way line.

The minimum amount of land required will be dependent on the sizes of the reservoir and building, as shown on Figure 7-2. For example, a 100 foot diameter reservoir and a 20 foot  $\times$  40 foot building will require a parcel with minimum dimensions of 170 feet  $\times$  240 feet, or approximately 0.94 acres.







PUMP STATION SITE PLAN NTS






2/8/12 JN 65-100826 MAS


SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Separate Reservoir and Pump Station Sites



RESERVOIR / PUMP STATION SITE PLAN (OPTION A)

NTS



RESERVOIR/ PUMP STATION SITE PLAN (OPTION B)

NTS





SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Combined Reservoir and Pump Station Sites

# 8.0 PIPELINE ALIGNMENT ANALYSIS

# 8.1 OVERVIEW

An alignment analysis was conducted to evaluate potential transmission pipeline alignments between the SBWRP and the Recharge Basins, located approximately seven miles north. As part of this study, a Conveyance Facility Corridor was identified that provides a relatively direct route from the SBWRP to the Recharge Basins. To develop general pipeline alignment options within the Corridor, a total of 27 segments were identified in public streets and along the San Bernardino County Flood Control District right-of-way (shown on Figures 4-1 to 4-5).

The SBMWD then identified four preferred Alignment Options, which were analyzed in further detail and subsequently refined. This analysis included identifying agency and regulatory requirements associated with the transmission pipeline facilities, reviewing existing record information, identifying existing utilities for each alignment, and developing cross-sections to depict critical crossings. The refined Alignment Options are shown on Figures 8-1 and 8-2, and their lengths are summarized on Table A-2 in Appendix A. An evaluation of the preferred Alignment Options, based on the evaluation factors and rating of each alignment, is presented in this Section.

# 8.2 POTENTIAL CORRIDORS/SEGMENTS

There are four preferred alignments for the various transmission pipeline segments. For Conveyance Scenarios with two pipelines (Scenarios 3 through 6), Alignment Options are described below. For Conveyance Scenarios with one combined pipeline (Scenarios 1 and 2), only one pipeline would be constructed in Alignment Option 1, 2, or 3.

- 1. Alignment Option 1 Two pipelines (recycled water and advanced water) in one trench along Twin Creek channel.
- 2. Alignment Option 2 Two pipelines (recycled water and advanced water) along public streets. Streets include Arrowhead Avenue, Sierra Way, Crestview Avenue, and Valencia Avenue.
- 3. Alignment Option 3 Two pipelines (recycled and advanced) along public streets. Streets include Arrowhead Avenue, Sierra Way, and Waterman Avenue.
- 4. Alignment Option 4 Consists of Alignment Option 1 for the advanced pipeline and Alignment Option 2 for recycled pipeline.

July 2012 8-1 Summary Report

Additional distribution pipelines are required to deliver recycled water to direct reuse customers. These distribution pipelines would connect to the transmission pipeline and each direct reuse customer.

Pump station and storage tanks would be located within the Conveyance Facility Corridor near the pipeline alignment. Conveyance Scenarios include pump stations and/or storage tanks at intermediate and/or northern locations. Potential pump station/storage tank sites are discussed in Section 9.

# 8.3 AGENCY REQUIREMENTS

Agency requirements associated with the transmission and distribution pipelines primarily include SBMWD and SBCFCD requirements. Pipeline design criteria for the SBMWD are discussed in Section 5. Where the alignment crosses another agency's facility, such as Caltrans or a railroad, these agencies also have specific requirements for construction of the pipeline.

- SBMWD The criteria for design and location of pipelines are defined in SBMWD's Design Standards. These standards indicate that pipelines should be located no closer than 3 feet horizontally from gas mains, should have a horizontal separation of 10 feet between potable and non-potable water lines, and should have a vertical separation of 12 inches between potable and non-potable water lines. The SBMWD Water and Sewer Separation Standards are shown on SBMWD Drawing Number W6.14, included in Appendix F.
- SBCFCD The SBCFCD only allows installation of other agency pipelines within their right of way or property through a license agreement. The location of pipelines should be as close to property lines and as far away from drainage features or flood control channels as possible. It is advised that pipelines crossing a drainage feature consider sediment transport analysis to determine depth of cover. For pipelines that cross a fixed flood control channel, the pipeline is typically mounted on a bridge, but is required to be above the 100-year flood design flow level of the channel with no obstructions.
- Caltrans Caltrans has very specific requirements for submittal of proposed pipeline crossings of its freeway right of way. Requirements include: (1) the pipeline must cross perpendicular to the freeway right-of-way at no more than 15 degree skew from perpendicular, (2) the pipeline must be within a steel casing pipeline, and (3) the top of the steel casing pipeline must be at least 15 feet below any part of the freeway (freeway road base or bridge abutment). The proposed CWF Project pipeline alignments cross Caltrans Highway 210. Alignment Option 1 would cross Highway 210 near a bridge abutment of the Highway 210 crossing of East Twin Creek Channel and the pipeline would need to meet Caltrans guidelines for separation from bridge abutments. Alignment Option 2 would cross Highway 210 near the Valencia Avenue bridge and further coordination would be required to evaluate whether one or both pipelines could

be installed within spare bridge cells designated for future pipelines. Alignment Option 3 would cross Highway 210 near the Waterman Avenue bridge and further coordination would be required to evaluate whether one or both pipelines could be installed within spare bridge cells designated for future pipelines.

• Railroad – Each pipeline alignment option has one railroad crossing. This railroad is currently owned by the San Bernardino Association of Governments (SANBAG) and operated by Burlington Northern Santa Fe Railway Company (BNSF). It is utilized as a regional rail line for freight delivery (designated as Southern California Regional Rail – A). There are specific requirements for submittal of proposed pipeline crossings of railroads. Design of pipeline crossings of railroads are generally determined by the utility agency with review by the railroad, but typically require bore and jack crossings to minimize service interruption and compliance with standards of practice.

# 8.4 REGULATORY REQUIREMENTS

Regulatory requirements associated with the transmission and distribution pipeline primarily include the CDPH. There are specific requirements for recycled water distribution and use.

• CDPH – The location of the pipeline alignments require specific separation distances between recycled water pipelines and potable water pipelines (Title 22 California Code of Regulations, Water Main Installation, Section 64630 and Water Main Separation, Section 64572). These requirements require that new potable water mains be installed at least 10 feet horizontally and 1 foot vertically above any parallel pipeline conveying recycled water and 4 feet horizontally and 1 foot vertically above any parallel pipeline conveying advanced treated water. At crossings, new potable water mains shall be installed at least one foot above a recycled or advanced treated water pipeline with no joints within 8 feet. These conditions can be applied for separation when installing new recycled or advanced treated water pipelines. Alternative criteria are permitted for special situations that allow installation in closer proximity by utilizing special pipe material, using a continuous sleeve, or requiring no joints within a specified distance. The SBMWD has adopted these separation requirements as shown on SBMWD Drawing Number W6.14 in Appendix F.

# 8.5 ALIGNMENT EVALUATION CRITERIA

Critical evaluation factors relative to the construction and operation of the transmission pipeline alignments were developed to evaluate the advantages and disadvantages of each pipeline alignment option. Each factor was evaluated and rated using an established rating system. Pipeline Alignment Options with advantages were rated higher and those with disadvantages were rated lower. Eleven critical evaluation factors were developed for the Alignment Options: right of way, agency coordination/permitting, community impacts/duration, traffic, utilities,

July 2012 8-3 Summary Report

special crossings, constructability, land development, direct use customers, construction costs, and operations and maintenance (O&M) costs.

# 8.5.1 Right of Way

This criterion was used to evaluate the available right of way width for construction and maintenance of the various pipeline options. For dual pipelines in the same trench or two separate pipe trenches, an estimated 25 feet right of way width would allow for shored construction with space for equipment adjacent to the trench (an additional 10 feet would allow for passing equipment). Right of way width for short segments of pipeline could utilize a minimum right of way width of 20 feet. In roadways, sufficient width is typically available with consideration of overall roadway width and potential lane closures. Within the East Twin Creek Flood Control Channel, sufficient width was evaluated within the existing right of way. Alignment Options with wider available right of way width were rated higher than those with restricted right of way width.

# 8.5.2 Agency Coordination/Permitting

The location of pipeline alignment may require coordination with other agencies for right of way acquisition (i.e. a license agreement with the SBCFCD). The location of the pipeline may require other special permitting such as crossing a highway or railroad. Alignment Options without significant agency coordination and permitting requirement were rated higher than those with significant requirements.

#### 8.5.3 Direct Use Customers

This criterion was used to evaluate the proximity for the Alignment Options to potential direct use customers. Alignment Options located closer to direct use customers were rated higher than Alignment Options that would require additional distribution piping to direct use customers.

# 8.5.4 Community Impacts/Duration

This criterion was used to evaluate potential impacts to the community considering residential, commercial, parks, golf course, schools, churches, and other land uses in relation to the pipeline construction and maintenance. The estimated duration of construction was considered for the impacts to community uses such as streets, parks, and businesses. Alignment Options with fewer community impacts and shorter construction duration were rated higher than those with more community impacts or longer duration.

July 2012 8-4 Summary Report

#### 8.5.5 Traffic

The potential impacts to traffic were evaluated considering average daily traffic counts for each street along a pipeline segment. The traffic impacts at intersections were also considered for pipeline alignments. Alignment Options with fewer traffic impacts were rated higher than those with more traffic impacts.

#### 8.5.6 Utilities

A number of utilities were identified to exist in the Conveyance Facility Corridor including overhead utilities (power, phone, and cable), storm drains, water lines, sewer lines, underground electrical lines, petroleum fuel lines, high pressure gas lines, and buried communication lines. The utility information was obtained through utility research and investigation by contacting multiple agencies and visual observance. The number, location, size, and type of crossing or parallel utility impact the construction and maintenance of the proposed pipeline. Most of the utility crossings were considered to be minor and not expected to result in difficult construction or relocation of the proposed pipeline alignment or utility. However, if significant or multiple parallel utilities would require a relocation of a utility or proposed pipeline alignment, the segment was assigned a lower rating.

# 8.5.7 Special Crossings

Special crossing were defined as pipeline crossings of major drainage facilities, storm water channels, wetlands, high pressure gas pipelines, petroleum pipelines, freeways, and railroads. These special crossings were identified for each pipeline segment and were evaluated for level of impact. Tunneling or trenchless technology would be required for any major highway crossing, major storm drain crossing, or railroad crossing and in areas requiring deep excavations. Alignment Options with fewer special crossings were rated higher than those with a greater number of special crossings.

# 8.5.8 Constructability

The overall constructability of the pipeline segment was evaluated considering access for equipment, staging areas, material storage, slope of construction, cross slopes, and work hour restrictions (i.e. schools, traffic, etc.). Areas with limited space for construction access, equipment, and material storage would result in a more difficult working environment and could require specialty construction equipment and/or additional time to construct. Such areas were rated less favorably.

# 8.5.9 Land Condition

This factor represents the type of use of land and developments on the land in the location of the pipeline segment. Land conditions include open grade (dirt or grass surface), vegetated, sensitive habitat, asphalt paved road, concrete road, and buildings/structures. Each Alignment Option was evaluated based on the land condition with a higher rating for Alignment Options with open country and lower rating for impacts to roadways, buildings/structures, and sensitive habitat.

#### 8.5.10 Construction Costs

The estimated construction cost of pipeline segments was evaluated. Alignment Options were rated based on their relative estimated construction costs.

# 8.5.11 Operation and Maintenance Costs

The estimated O&M cost of pipeline segments was evaluated. Alignment Options were rated based on their relative estimated construction costs.

#### 8.6 ALIGNMENT SEGMENT SCREENING

A total of 27 pipeline segments were initially identified as possible alignment routes from the SBWRP to the Recharge Basins. Some pipeline segments were determined to have distinct disadvantages when compared to similar pipeline segments in the same vicinity. Based on input from SBMWD and various stakeholders, four preferred Pipeline Alignment Options were identified for further consideration in the Report.

# 8.7 ALIGNMENT DESCRIPTIONS

## 8.7.1 Pipeline Alignment Option 1

Pipeline Alignment Option 1 would consist of two pipelines (recycled water and advanced water) in one trench along Twin Creek channel (for Conveyance Scenarios 3 or 4). For Conveyance Scenarios 5 or 6, the two pipelines would be a recycled water pipeline and a brine pipeline in one trench along Twin Creek channel. For Conveyance Scenarios 1 or 2, this option would consist of one pipeline along Twin Creek channel (advanced water). A brief summary of the estimated length and description by segment for Pipeline Alignment Option 1 is shown in Table 8-1.

July 2012 8-6 Summary Report

Table 8-1
Pipeline Alignment Option 1

Segment No.	Length (ft)	Description	
1	1,400	Twin Creek Channel	
5	6,410	Twin Creek Channel, Twin Creek Channel Crossings, Street Crossings, Railroad Crossing	
10	11,320	Twin Creek Channel, Street Crossings	
18	5,600	Twin Creek Channel, Street Crossings, Perris Hill Park	
24	11,290	Twin Creek Channel, Street Crossings, Highway 210 Crossing, East Twin Creek Spreading Grounds	
27	3,260	Waterman Basins	
TOTAL	39,280		

# 8.7.2 Pipeline Alignment Option 2

Pipeline Alignment Option 2 would consist of two pipelines (recycled water and advanced water) along public streets including Arrowhead Avenue, Sierra Way, Crestview Avenue, and Valencia Avenue (for Conveyance Scenarios 3 or 4). For Conveyance Scenarios 5 or 6, the two pipelines would be a recycled water pipeline and a brine pipeline. For Conveyance Scenarios 1 or 2, this option would consist of one pipeline (advanced water) along the same public streets. A brief summary of the estimated length and description by segment for Pipeline Alignment Option 2 is shown in Table 8-2.

Table 8-2
Pipeline Alignment Option 2

Segment No.	Length (ft)	Description	
1	1,400	Twin Creek Channel	
2	950	West Orange Show Road	
4	7,710	Arrowhead Avenue, Railway Crossing	
8	1,370	West Rialto Avenue	
11	7,460	Sierra Way	
13	1,930	East Baseline Street	
14	1,590	East Baseline Street	

# Table 8-2 (continued) Pipeline Alignment Option 2

Segment No.	Length (ft)	Description	
17	4,660	Crestview Avenue	
20	1,100	East 21st Street and Valencia Avenue	
23	10,580	Valencia Avenue, Bridge over Highway 210	
26	890	East 40th Street	
27	3,260	Waterman Basins	
TOTAL	42,900		

# 8.7.3 Pipeline Alignment Option 3

Pipeline Alignment Option 3 would consist of two pipelines (recycled water and advanced water) along public streets including Arrowhead Avenue, Sierra Way, and Waterman Avenue (for Conveyance Scenarios 3 or 4). For Conveyance Scenarios 5 or 6, the two pipelines would be a recycled water pipeline and a brine pipeline. For Conveyance Scenarios 1 or 2, this option would consist of one pipeline (advanced water) along the same public streets. A brief summary of the estimated length and description by segment for Pipeline Alignment Option 3 is shown in Table 8-3.

Table 8-3
Pipeline Alignment Option 3

Segment No.	Length (ft)	Description	
1	1,400	Twin Creek Channel	
2	950	West Orange Show Road	
4	7,710	Arrowhead Avenue, Railway Crossing	
8	1,370	West Rialto Avenue	
11	7,460	Sierra Way	
13	1,930	East Baseline Street	
16	5,310	Waterman Avenue	
22	10,570	Waterman Avenue, Bridge over Highway 210	
25	1,890	East 40th Street	
26	890	East 40th Street	

# Table 8-3 (continued) Pipeline Alignment Option 3

Segment No.	Length (ft)	Description
27	3,260	Waterman Basins
TOTAL	42,740	

# 8.7.4 Pipeline Alignment Option 4

Pipeline Alignment Option 4 would consist of two pipelines using the alignment from Pipeline Alignment Option 1 for the advanced water pipeline and the alignment from Pipeline Alignment Option 2 for the recycled water pipeline (for Conveyance Scenarios 3 or 4). Pipeline Alignment Option 4 does not apply for Conveyance Scenarios 1, 2, 5, or 6.

# 8.7.5 Distribution Pipeline System

The proposed distribution pipeline systems that would be required to serve the potential direct use customers from the main transmission pipelines were developed for each Alignment Option. The distribution pipeline systems were optimized to minimize the distribution pipeline lengths and diameters, as well as to limit the number of special crossings required. Distribution pipeline diameters were sized based on a maximum allowable velocity of 6 feet per second under peak hour demands. An absolute minimum diameter criterion of 8-inches was utilized per SBMWD requirements. It should be noted that since Alignment Options 2 and 4 share the same recycled water Alignment Option, they also share the same distribution pipeline system. A summary of the distribution pipeline diameters and lengths required for each Alignment Option is presented in Table 8-4. The distribution pipeline systems are shown on Figures 8-3 through 8-8.

Table 8-4
Distribution Pipeline Summary

Alignment		Alignment		Alignment	
Option 1		Options 2 & 4		Option 3	
Diameter	Length	Diameter Length		Diameter	Length
(in)	(ft)	(in) (ft)		(in)	(ft)
8	93,400	8	80,400	8	74,000
10	14,300	10	9,500	10	11,100
Total	107,700	Total	89,900	Total	85,100

#### 8.8 ALIGNMENT CROSS-SECTIONS

Detailed cross-sections were prepared for the anticipated most-critical areas along each pipeline alignment option to identify existing utilities and verify that adequate space would be available for construction of one or two proposed pipelines within the alignment corridor. Cross-section cuts are shown on Figures 8-1 and 8-2 and are labeled with the pipeline alignment option number and section cut letter (i.e. Section 2E is a section E of Pipeline Alignment Option 2). Cross-sections are shown on Figures 8-9 to 8-35.

Based on the evaluation of the alignment cross-sections, the following findings were made:

- Alignment Option 1 has adequate space for construction of two pipelines in a common trench for the length of the alignment. Due to an existing 78-inch storm drain along the north/west side of the Twin Creek Channel near Mill Street, the proposed alignment crosses to the east/south of the channel just south of Central Avenue, and then crosses back over just east of Waterman Avenue. Also, one area near E. Highland Avenue shown on Figure 8-15 (Section 1G) has a narrow width with an existing power pole that would likely require relocation.
- Alignment Option 2 has adequate space for construction of two pipelines in a common trench for the length of the alignment.
- Alignment Option 3 has limited space in at least one section of the pipeline alignment that would require the relocation of a 12-inch waterline in Waterman Avenue between Gilbert Street and Wabash Street as shown on Figure 8-31 (Section 3G) in order to construct two pipelines in a common trench for the length of the alignment. Insufficient separation is available to construct the pipelines in separate trenches.
- Alignment Option 4 has adequate space for construction of the advanced water pipeline along the alignment for Alignment Option 1 and adequate space for construction of the recycled water pipeline along the alignment for Alignment Option 2.

### 8.9 SPECIAL CROSSINGS

Several special crossings were identified that may require special construction methods or have strict agency construction restrictions. Special crossings include major drainage facilities, storm drain channels, high pressure gas pipelines, freeways, and railroads, as described below.

 Major Drainage Facilities – In areas where the pipeline crosses an open drainage channel, design should consider sediment transport analysis to determine depth of cover over the pipeline.

July 2012 8-10 Summary Report

- Storm Drain Channels In areas where the pipeline crosses a storm drain channel, the
  pipeline will likely be deep and have limited access. In these areas, it is recommended
  that the pipeline be placed in a casing to protect the pipe and allow easier access for
  maintenance.
- High Pressure Gas Pipelines These crossings are a safety concern and require identification and protection during construction. Mark-out and support of high pressure gas pipelines are crucial during construction of the new crossing pipeline.
- Freeway all of the Alignment Options cross Highway 210. Plan view exhibits were developed to indicate a preliminary crossing methodology using an 84-inch steel casing pipe with both the advanced water and recycled water pipelines within the steel casing (See Caltrans Crossing 1I, 2I, and 3H on Figures 8-17, 8-29, and 8-32). Alternatively, one or both of the proposed pipelines may be able to be constructed within the existing bridge cells at the Valencia Ave. and Waterman Ave bridge crossings of Highway 210. Caltrans agency requirements are described in Section 8.3.
- Railroad All of the Alignment Options cross the railroad, which is owned by the SANBAG and operated by BNSF. Cross-sections were developed to indicate a preliminary crossing methodology using a steel casing pipe with the advanced water and recycled water pipeline within the steel casing (See Cross-Sections 1B, 2D, and 3D on Figures 8-10, and 8-24). Railroad agency requirements are described in Section 8.3.

#### 8.10 ALIGNMENT EVALUATION RATING

Criterium Decision Plus, a Windows based software program, was used to assist in the evaluation process. Decision Plus is a decision management tool that helps organize, complete, and communicate complex decision-making tasks. Criterium Decision Plus was used to list the decision criteria developed with input from the SBMWD. The decision criteria were then applied to the Alignment Options. Evaluation factors and their weighting factors were determined in a workshop format with the SBMWD, and scores for the various options were identified. Evaluation criteria are presented in Section 8.5. This section presents the rating system used in the evaluation of the different criteria for Alignment Options.

Each pipeline alignment option was rated based upon its ability to satisfy the project objectives. The options were rated using a scale of 1 to 5 as shown in Table 8-5 with a higher rating indicating a more favorable scenario or option.

July 2012 8-11 Summary Report

Table 8-5
Definition of Rating System

Definition	Rating
Satisfies project objectives with significant noted advantages	5
Satisfies project objectives with noted advantages	4
Satisfies project objectives	3
Satisfies project objectives with noted disadvantages	2
Satisfies project objectives with significant noted disadvantages	1

Each evaluation criteria was then assigned a weight representing the importance of the criterion on a scale of 1 to 5. A higher weight represents more important criteria as shown in Table 8-6.

Table 8-6
Definition of Weighting System

Definition	Rating
Critical Importance	5
Significant Importance	4
Important	3
Low Importance	2
Least Importance	1

Evaluation criteria weightings for Pipeline Alignment Options are shown in Table 8-7.

Table 8-7
Pipeline Alignment Options Criteria Weighting

Evaluation Criteria	Weight
Right of Way	3
Agency Coordination/Permitting	3
Community Impacts/Duration	4
Traffic	3
Utilities	2
Special Crossings	2
Constructability	4
Land Development	2
Direct Use Customers	3
Construction Costs	5
O&M Costs	5

A score for each evaluation criterion was calculated by multiplying the rating and the weight. A higher score indicated a more favorable option. The overall scores were compared for each option. The overall score is a good indication as to which options are the best match for meeting the project objectives.

Since the overall score may not add up to 100, a weighted score was calculated for each option. The overall scores were converted to percentages; therefore the ideal score would have value of 100 percent. The higher the weighted score of the option, the closer that option would come to meeting all the project objectives considering the criteria impacting the decision.

Utilizing *Criterium Decision Plus*, a decision score was calculated with an ideal score of 1.00. The higher the decision score of the option, the closer that option would come to meeting all the project objectives considering the criteria impacting the decision. Weighted scores and decision scores were similar, but since *Criterium Decision Plus* utilizes a more complex integrated rating and ranking system, the decision score was considered in evaluating the rank.

The highest decision score is considered the highest ranked or preferred option. Ranks were then assigned to the remaining options in the order of highest score to lowest score.

Each of the four potential Pipeline Alignment Options was evaluated, rated, and ranked. Ranking results are listed in Table 8-8 and depicted graphically in Figure 8-36, and discussed briefly below.

July 2012 8-13 Summary Report

Table 8-8
Pipeline Alignment Options Evaluation and Ranking


Evaluation Factor	Pipeline Alignment 1	Pipeline Alignment 2	Pipeline Alignment 3	Pipeline Alignment 4
Right of Way Weight = 3	East Twin Creek Flood Control Channel; Some limited width Rating = 3	Mostly wider streets; Some lane closure restrictions Rating = 4	Mostly wider streets; Some lane closure restrictions Rating = 4	Combined Channel and streets Rating = 2
	Score = 9	Score = 12	Score = 12	Score = 6
Agency Coordination/ Permitting Weight = 3	Requires License Agreement with SBCFCD Rating = 3	Within City streets Rating = 4	Within City streets Rating = 4	Combined License Agreement and City streets Rating = 2
	Score = 9	Score = 12	Score = 12	Score = 6
Direct Use Customers Weight = 3	Located at east edge of Corridor; longer distribution piping Rating = 2 Score = 6	Located in middle of Corridor; shorter distribution piping Rating = 4 Score = 12	Located at west edge of Corridor; shortest distribution piping Rating = 5 Score = 15	Located in middle of Corridor; shorter distribution piping Rating = 4 Score = 12
Community Impacts/ Duration Weight = 4	Minimal impacts; within Flood Channel Rating = 5	Impacts to community; adjacent to roads Rating = 3	Impacts to community; adjacent to roads Rating = 3	Impacts to both Flood Channel and community near roads Rating = 2
	Score = 20	Score = 12	Score = 12	Score = 8
Traffic Weight = 3	Minimal impacts; within Flood Channel Rating = 5	Impacts along multiple streets with medium traffic Rating = 3	Impact along multiple streets with high traffic Rating = 1	Impacts at Flood Channel crossing and along streets with medium traffic Rating = 3
	Score = 15	Score = 9	Score = 3	Score = 9
Utilities Weight = 2	Some crossings and parallel utilities Rating = 4	Multiple crossing and parallel utilities Rating = 3	Multiple crossing and parallel utilities; utility relocations Rating = 1	Crossing at Flood Channel and multiple crossing and parallel utilities in roads Rating = 2
	Score = 8	Score = 6	Score = 2	Score = 4
Special Crossings Weight = 2	Railroad, Highway 210 Rating = 4	Railroad, Highway 210 Rating = 3	Railroad, Highway 210 Rating = 3	Two Railroad and Two Highway 210 Rating = 3
Constructability	Score = 8	Score = 6	Score = 6	Score = 6
Weight = 4	Limited space; standard work hours Rating = 4	Limited space; limited work hours Rating = 3	Limited space, limited work hours Rating = 3	Limited space; limited work hours Rating = 3
T 16 100	Score = 16	Score = 12	Score =12	Score =12
Land Condition Weight = 2	Open land Rating = 5	Paved Rating = 3	Paved Rating = 3	Open land and paved Rating = 3

Table 8-8 (continued)
Pipeline Alignment Options Evaluation and Ranking

Evaluation Factor	Pipeline Alignment 1	Pipeline Alignment 2	Pipeline Alignment 3	Pipeline Alignment 4
	Score = 10	Score = 6	Score = 6	Score = 6
Construction	\$ 93.1 M	\$ 118.0 M	\$ 116.5 M	\$ 101.4 M
Costs*	Rating = 5	Rating = 2	Rating = 2	Rating = 4
Weight = 5			_	
	Score = 25	Score = 10	Score = 10	Score = 20
O &M Costs*	\$ 0.9 M/yr	\$ 1.1 M/yr	\$ 1.2 M/yr	\$ 1.0 M/yr
Weight = 5	Rating = 5	Rating = 3	Rating = 2	Rating = 4
	Score = 25	Score = 15	Score = 10	Score = 20
TOTAL	Overall Score	Overall Score	Overall Score	Overall Score
(Weight = 36)	151	112	100	109
Weighted SCORE	84%	62%	56%	61%
DECISION SCORE	0.840	0.620	0.539	0.597
RANK	<b>1</b> st	<b>2</b> <sup>nd</sup>	<b>4</b> <sup>th</sup>	3rd

<sup>\*</sup>Construction and O&M costs are based on Pipeline Alignments for either Conveyance Scenario 3 or 4.

Figure 8-36
Pipeline Alignment Options Evaluation



# 8.10.1 Alignment Option 1

This alignment had the highest score and ranked first. Primary factors for the evaluation and ranking of Alignment Option 1 were the minimal community impacts, traffic impacts, and conflicting utilities and land condition. This alignment also had the lowest capital and O&M costs.

## 8.10.2 Alignment Option 2

This alignment had the second highest score and ranked second. Primary factors for the evaluation and ranking of Alignment Option 2 were an overall average satisfactory ability to meet project objectives with some noted advantages in reduced agency coordination and central location for connecting distribution pipelines to direct use customers. However, this alignment had high overall construction and O&M costs.

#### 8.10.3 Alignment Option 3

This alignment had the lowest score and ranked forth. Primary factors for the evaluation and ranking of Alignment Option 3 were an overall average satisfactory ability to meet project objectives with some noted disadvantages in increased traffic impacts and utility conflicts. This alignment also had high overall construction and O&M costs.

#### 8.10.4 Alignment Option 4

This alignment had the third highest score and ranked third. Primary factors for the evaluation and ranking of Alignment Option 4 were the combined advantages of using Alignment Option 1 for the advanced pipeline (reduced community impacts, traffic impacts, conflicting utilizes and land condition) and benefit of the central location for connecting distribution pipelines to direct use customers for Alignment Option 2 for the recycled pipeline. This alignment also had the second lowest capital costs.

## 8.11 SUMMARY

Based on the evaluation, all of the four Pipeline Alignment Options would be feasible for the CWF Project. There are noted advantages for Alignment Option 1, which ranked the highest in the evaluation. Concurrence with the SBCFCD and compliance with their requirements will be imperative in further development and selection of Alignment Option 1 as the preferred alignment. Preliminary meetings with SBCFCD have indicated that pipeline(s) aligned within the SBCFCD Twin Creek Flood Channel would be compatible under a license agreement.

July 2012 8-16 Summary Report

#### 8.12 COST ESTIMATES


Feasibility-level cost estimates were prepared for the four preferred Pipeline Alignment Options based on feasibility-level planning data collected and developed as part of this analysis. Due to the preliminary status of the project, the current unpredictable bidding climate, and estimated project schedule, opinions of probable costs should be updated regularly as the project is better defined. A contingency of 30 percent was applied to the estimated construction costs to account for the preliminary nature of the project. An additional allocation of 30 percent was made for administrative, legal, design, and construction management costs in order to define overall project costs. Utilizing a Class 4 Estimate for feasibility-level estimates as defined by the Association for the Advancement of Cost Engineering International (AACEI), an estimated range of -15 percent to +30 percent can be expected and an additional contingency of 15 percent was applied to the overall project costs. Finally, with the estimated mid-point of construction in three years (March 2015), an escalation cost due to projected inflation at an annual rate of 4 percent was applied (total inflation for three years equal to 12.5 percent).

Based on the current understanding of the project's criteria and general assumptions made regarding facility locations and configurations, this opinion is intended to provide a feasibility-level overall cost. Unit pipeline costs were based on historical cost data compiled from multiple similar pipeline projects and the experience of RBF and Black & Veatch. This estimate was compiled in March 2012 with an Engineering News Record (ENR) – Construction Cost Index (CCI) (Los Angeles) of 10,283.55. Therefore, the costs can be updated once the schedule has been further defined. Table 8-9 summarizes the feasibility-level costs for each preferred pipeline option. More detailed cost information for each preferred pipeline option is included in Appendix D-1.

Table 8-9
Pipeline Alignment Options Feasibility-Level Cost Estimates

Conveyance Scenario	Pipeline Alignment 1	Pipeline Alignment 2	Pipeline Alignment	Pipeline Alignment 4
Conveyance	\$68.1 million	\$79.7 million	\$78.6 million	N/A
Scenario 1 or 2				
Conveyance	\$94.3 million	\$117.0 million	\$115.9 million	\$100.5 million
Scenario 3 or 4				
Conveyance	\$91.2 million	\$112.9 million	\$111.1 million	N/A
Scenario 5 or 6				










SAN BERNARDINO MUNICIPAL WATER DEPARTMENT










SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

Alignment Options










SAN BERNARDINO MUNICIPAL WATER DEPARTMENT











SAN BERNARDINO MUNICIPAL WATER DEPARTMENT








ce: County of San Bernardino, Eagle Aerial - 2011, Esri Online































FIGURE 8-11 **MUNICIPAL WATER DEPARTMENT** SECTION 1C - TWIN CREEK CHANNEL 200±' SOUTH OF MILL ST. SAN BERNARDINO -30" Ø ADVANCED TREATED WATER PIPELINE -EX FENCE E R∕w BLACK & VEATCH Building a world of difference. 12"-24" 3,-6" MIN. VARIES 8' TO 11' PIPE TRENCH 29' VARIES 12"-24" 11.5 -EX TWIN CREEK CHANNEL FLOOR 20" Ø RECYCLED WATER PIPELINE EX TWIN CREEK CHANNEL EX FENCE DAILINGNOO



SAN BERNARDINO

DAILINGNOO



H:\PDATA\65100826\CADD\WATER\EXHIBITS\X~SECTIONS\0826-SECIE-CHANNEL.DWG DANNYM 7/18/12 2:15 pm

# **SECTION 1E - TWIN CREEK CHANNEL**

**SECTION 1G - TWIN CREEK CHANNEL** 

TWIN CREEK CHANNEL

-EX UTILITY POLE (TO BE RELOCATED)

WEST R/W-

EX FENCE .

±11,

±3,

±20°

- EX CHANNEL CONCRETE WALL

NIM

-EX FENCE

-30"ø ADVANCED TREATED WATER PIPELINE

Z

VARIES 8' TO 11' PIPE TRENCH - 12" MIN-

12" MIN-

20"ø RECYCLED WATER PIPELINE

H:\PDATA\65100826\CADD\WATER\EXHIBITS\X—SECTIONS\0826—SEC1H—CHANNEL.DWG DANNYM 7/18/12 2:26 pm

FIGURE 8-17

CALTRANS CROSSING 11

SAN BERNARDINO MUNICIPAL WATER DEPARTMENT


BLACK & VEATCH Building a world of difference:







NOTECTION OF NOTECTION

H:\PDATA\65100826\CADD\WATER\EXHBITS\X-SECTIONS\0826-SEC1K-CHANNEL.DWG\_DANNYM\_7/18/12\_2:18\_pm












FIGURE 8-25 **MUNICIPAL WATER DEPARTMENT** SECTION 2E & 3E - RIALTO AVE BETWEEN ARROWHEAD AVENUE AND SIERRA WAY SAN BERNARDINO 3.75' S R/W 5.5, 17.0, 20.0, Building a World of difference. **BLACK & VEATCH** 15.0, 16" G (HP) SECTION 2E & 3E - RIALTO AVE 41.25' 9 "9 32.0, ELEC VAULT HORZ SCALE: 1" = 15' VERT SCALE: NONE 8, 28 6.5 82,5 11.0, H:\PDATA\65100826\CADD\WATER\EXHIBITS\X—SECTIONS\0826—SEC2E—3E—RIALTOAVE.DWG DANNYM 7/18/12 11:26 am ,5 LO (4) 32.0, 20. I <u>"</u>⊅/!-! 41.25' TRENCH .05 90A9 11, RMWA PR0P 20" CONSULTING J-¢" EFEC 5.5 N R/W 3.75'





# **SECTION 2H - CRESTVIEW AVE**

HORZ SCALE: 1" = 15' VERT SCALE: NONE





**BLACK & VEATCH** Building a **World** of difference.

MUNICIPAL WATER DEPARTMENT SAN BERNARDINO

SECTION 2H - CRESTVIEW AVE BETWEEN 21ST ST AND 19TH ST

8-28

FIGURE

2 CALTRANS CROSSING


SAN BERNARDINO MUNICIPAL WATER DEPARTMENT


BLACK & VEATCH Building a world of difference:






DESIGN B CONSTRUCTION





















FIGURE

8-34

SECTION 31 - WATERMAN AVE BETWEEN 30TH ST AND MARSHALL BLVD

**MUNICIPAL WATER DEPARTMENT** SAN BERNARDINO



LOCATION IS APPROXIMATE RECORD DRAWING NOT AVAILABLE.

SS έω

**UTILITY NOTES** 

COMMENT

. 9

# **SECTION 3I - WATERMAN AVE**


HORZ SCALE: 1" = 15' VERT SCALE: NONE







CONSULTING





# 9.0 PUMP STATION/STORAGE RESERVOIR ANALYSIS

An analysis was conducted to evaluate potential Pump Station/Storage Reservoir Sites within the Conveyance Facility Corridor. Seven preferred Pump Station/Storage Reservoir Sites were identified for the various Conveyance Scenarios. Typical site requirements were identified and layouts were developed for each potential site. Facility power requirements were determined and connections to existing power lines were identified. An evaluation of the preferred Pump Station/Storage Reservoir Sites was conducted considering evaluation factors and rating each site.

### 9.1 TYPICAL SITE REQUIREMENTS

Typical facility site requirements were identified in Section 7 for a typical storage reservoir site, pumping station site, and combined storage reservoir/pumping station site. These facility requirements were utilized to develop specific site layouts for each of the seven preferred Pump Station/Storage Reservoir Sites (see Figures 9-1 to 9-7).

### 9.2 ALTERNATIVE SITES

There are two potential areas for Pump Station/Storage Reservoir Sites – at an intermediate location or at a northern location depending on the conveyance scenario selected. Different site options were identified for each location. Three intermediate locations (Sites A, B, and C) were identified at a point approximately half way from the SBWRP to the Recharge Basins with an elevation approximately half way between the SBWRP elevation (Elevation 1,000 feet, amsl) and the Recharge Basins elevation (Elevation 1,470 feet, amsl). Four northern locations were identified near the Recharge Basins (Sites D, E, F, and G). The potential sites were also located on open private property or within a City park to minimize impacts to existing structures, homes, and commercial businesses. Storage reservoirs could be above-grade, welded steel; or above-grade, partially buried, or buried prestressed concrete. Specific site options are described below:

### **Intermediate Location**

- 1. Pump Station/Storage Reservoir Site Option A This site is located at a vacant lot at the corner of East 23<sup>rd</sup> Street and Leroy Street. It is anticipated that the tank would be above-grade welded steel or prestressed concrete.
- 2. Pump Station/Storage Reservoir Site Option B This site is located in Perris Hill Park on the northwest corner of the park at the corner of East Highland Avenue and Valencia Avenue. It is anticipated that the tank would be partially buried or buried prestressed concrete due to its location within Perris Hill Park at the entrance to the park.

July 2012 9-1 Summary Report

3. Pump Station/Storage Reservoir Site Option C - This site is located in Perris Hill Park at the corner where East Highland Avenue and East Twin Creek Channel meet and west of East Twin Creek Channel. It is anticipated that the tank would be above-grade welded steel or prestressed concrete since it is located at the edge of the park near East Twin Creek Channel.

### Northern Location

- 1. Pump Station/Storage Reservoir Site Option D This site is located in Wildwood Park along the west of the park where it borders Waterman Avenue. It is anticipated that the tank would be partially buried or buried prestressed concrete due to its location within Wildwood Park.
- 2. Pump Station/Storage Reservoir Site Option E This site is located in Wildwood Park at the southeast corner where it borders East 40<sup>th</sup> Street. It is anticipated that the tank would be partially buried or buried prestressed concrete due to its location within Wildwood Park.
- 3. Pump Station/Storage Reservoir Site Option F This site is located adjacent to East Twin Creek Spreading Grounds at the corner where East 40<sup>th</sup> Street and East Twin Creek Channel intersect and west of the East Twin Creek Spreading Basins within SBCFCD property. It is anticipated that the tank would be above-grade welded steel or prestressed concrete.
- 4. Pump Station/Storage Reservoir Site Option G This site is located north of the Waterman Basins at the terminus of the pipeline alignments. It is anticipated that the tank would be above-grade welded steel or prestressed concrete.

### 9.3 PUMP STATION/STORAGE RESERVOIR EVALUATION CRITERIA

Critical evaluation factors relative to the construction and operation of the Pump Station/Storage Reservoir Sites were developed to evaluate the advantages and disadvantages of each site option. Each factor was evaluated and rated using an established rating system. Pump Station/Storage Reservoir Site Options with advantages were rated higher and those with disadvantages were rated lower. Eleven critical evaluation factors were developed for the Pump Station/Storage Reservoir Site Options: property, agency coordination/permitting, flexibility for future expansion, community/visual impacts, access, utilities, power supply, constructability, land development, construction costs, and O&M costs.

July 2012 9-2 Summary Report

# 9.3.1 Property

The available property is important for construction and maintenance of the Pump Station/Storage Reservoir Sites. For combined pump station/storage reservoir locations, estimated required property dimensions were determined as follows:

- Intermediate Pump Station/Storage Reservoir Site: 190 feet by 265 feet
- Northern Pump Station/Storage Reservoir Site: 220 feet by 290 feet

For some of the selected sites, the property is slightly smaller than these dimensions, the property is shaped differently, or existing facilities on-site would need to be relocated. All of these factors were included in the evaluation of this criterion.

## 9.3.2 Agency Coordination/Permitting

The location of the Pump Station/Storage Reservoir Site may require coordination with other agencies for property acquisition (i.e. purchase of a privately owned lot or a license agreement with the SBCFCD). The location of the Pump Station/Storage Reservoir Site may require other special coordination such as locations within existing parks. Pump Station/Storage Reservoir Site Options without significant agency coordination and permitting requirement were rated higher than those with significant requirements.

# 9.3.3 Flexibility for Future Expansion

This criterion was used to evaluate the ability for future expansion with space available for construction of future facilities within or adjacent to the Pump Station/Storage Reservoir Site. Pump Station/Storage Reservoir Sites with space for future expansion were rated higher than those sites without additional space.

### 9.3.4 Community/Visual Impacts

This criterion was used to evaluate potential impacts to the community considering residential, commercial, parks, schools, churches, and other land uses in relation to the location of the Pump Station/Storage Reservoir Site. The estimated duration of construction was considered for the impacts to community uses such as parks and businesses. Pump Station/Storage Reservoir Site Options with fewer community impacts and visual impacts were rated higher than those with more community impacts and visual impacts.

### 9.3.5 Access

The ability to access the Pump Station/Storage Reservoir Site was evaluated. Potential impacts to traffic were considered for access to the Pump Station/Storage Reservoir Site.

### 9.3.6 Utilities

Existing utilities were identified to exist in the Pump Station/Storage Reservoir Sites including overhead utilities (power, phone, and cable), storm drains, water lines, sewer lines, underground electrical lines, high pressure gas lines, and buried communication lines. The utility information was obtained through utility research and investigation by contacting multiple agencies and visual observance. The number, location, size, and type of crossing or parallel utility impacts the construction and maintenance of the proposed Pump Station/Storage Reservoir Site. Most of the utility on sites were considered to be minor and not expected to result in difficult construction or relocation of the utility. If utilities would require relocation, the site was assigned a lower rating.

### 9.3.7 Power Supply

The availability of power was evaluated for each Pump Station/Storage Reservoir Site. Sites could be supplied with power from existing overhead or underground power. If no adjacent power service is available, an extension of the power service would be required to the Pump Station/Storage Reservoir Site.

# 9.3.8 Constructability

The overall constructability of the Pump Station/Storage Reservoir Site was evaluated considering access for equipment, staging areas, material storage, slope of construction, and cross slopes. The type of construction was also evaluated (i.e. circular versus rectangular and above ground versus buried).

### 9.3.9 Land Condition

This factor represents the type of use of land and developments on the land in the location of the Pump Station/Storage Reservoir Site. Land condition include open grade (dirt or grass surface) or vegetated, and may include asphalt paved roads or parking lots, recreational facilities (park, baseball field, etc.), and buildings/structures. Each Pump Station/Storage Reservoir Site Option was evaluated based on the land condition with a higher rating for sites with open country and lower rating for impacts to existing facilities.

# 9.3.10 Construction Costs

The estimated construction cost of Pump Station/Storage Reservoir was evaluated. Pump Station/Storage Reservoir Sites were rated based on their relative estimated construction costs.

July 2012 9-4 Summary Report

### 9.3.11 Operation and Maintenance Costs

The estimated O&M cost of Pump Station/Storage Reservoirs was evaluated. Pump Station/Storage Reservoir Sites were rated based on their relative estimated construction costs.

### 9.4 PUMP STATION/STORAGE RESERVOIR SITE RANKING

Similar to the pipeline alignment evaluation and ranking, *Criterium Decision Plus*, was utilized for Pump Station/Storage Reservoir Site ranking (see Section 8.10). The same rating and weighting definitions were used. Each site option are rated based upon its ability to satisfy the project objectives. The alternatives were rated using a scale of 1 to 5 as shown in Table 9-1 with a higher rating indicating a more favorable scenario or option.

Table 9-1
Definition of Rating System

Definition	Rating
Satisfies project objectives with significant noted advantages	5
Satisfies project objectives with noted advantages	4
Satisfies project objectives	3
Satisfies project objectives with noted disadvantages	2
Satisfies project objectives with significant noted disadvantages	1

Each evaluation criteria was then assigned a weight representing the importance of the criteria on a scale of 1 to 5. A higher weight represents more important criteria as shown in Table 9-2.

Table 9-2
Definition of Weighting System

Definition	Rating
Critical Importance	5
Significant Importance	4
Important	3
Low Importance	2
Least Importance	1

Evaluation criteria weightings for Pump Station/Storage Reservoir Site Options are shown in Table 9-3.

Table 9-3
Pump Station/Storage Reservoir Site Options Criteria Weighting

Evaluation Criteria				
Property	4			
Agency Coordination/Permitting	3			
Flexibility for Future Expansion	2			
Community/Visual Impacts	4			
Access	1			
Utilities	1			
Power Supply	3			
Constructability	4			
Land Condition	3			
Construction Costs	5			
O&M Costs	5			

A score for each evaluation criteria was calculated by multiplying the rating and the weight. A higher score indicated a more favorable site option. The overall scores were compared for each site option. The overall score is a good indication as to which site options are the best match for meeting the project objectives.

Since the overall score may not add up to 100, a weighted score was calculated for each site option. The overall scores were converted to percentages; therefore the ideal score would have value of 100 percent. The higher the weighted score of the option, the closer that option would come to meeting all the project objectives considering the criteria impacting the decision.

Utilizing *Criterium Decision Plus*, a decision score was calculated with an ideal score of 1.00. The higher the decision score of the option, the closer that option would come to meeting all the project objectives considering the criteria impacting the decision. Weighted scores and decision scores were similar, but since *Criterium Decision Plus* utilizes a more complex integrated rating and ranking system, the decision score was considered in evaluating the rank.

The highest decision score is considered the highest ranked or preferred site option. Ranks were then assigned to the remaining site options in the order of highest score to lowest score.

The ranking of Pump Station/Storage Reservoir Site Options is shown in Table 9-4 and depicted graphically on Figure 9-8.

6-7

Table 9-4
Pump Station/Storage Reservoir Site Options Evaluation and Ranking

Evaluation Factor	Site A	Site B	Site C	Site D	Site E	Site F	Site G
Property Weight = 4	Private Property Rating = 1	Perris Hill Park, entrance Rating = 4	Perris Hill Park, edge Rating = 5	Wildwood Park, edge Rating = 4	Wildwood Park, edge Rating = 4	East Twin Creek, SBCFCD owned Rating = 2	Waterman Basin, SBCFCD owned Rating = 2
	Score = 4	Score = 16	Score = 20	Score = 16	Score = 16	Score = 8	Score = 8
Agency Coordination/	Commercial Business Zone	Coordinate with Park	Coordinate with Park (above-ground)	Coordinate with Park	Coordinate with Park	Coordinate with	Coordinate with
Weight = 3	Rating = 4	(2013) Rating = 3	(2255 9.527.5) Rating = 3	Rating = 3	Rating = 3	Rating = 2	Rating = 1
	Score = 12	Score = 9	Score = 9	Score = 9	Score = 9	Score = 6	Score = 3
Flexibility for Future Expansion	Site fills lot Rating = 1	Expansion within Park Rating = 4	Expansion within Park Rating = 4	Expansion within Park Rating = 4	Expansion within Park, within corner	Limited by Slope/SBCFCD	Limited by Slope/SBCFCD
Weight = 2	Score = 2	S: 0200	Score = 8	Score = 8	Score = 6	Score = 6	Score = 6
Community/Visual Impacts Weight = 4	Above-ground within Commercial Zone Rating = 3	Buried within Park Rating = 4	Above-ground within Park Rating = 2	Buried within Park Rating = 3	Buried within Park; Impacts Ball Field Rating = 2	Above-ground near Residential Rating = 3	Above-ground near Waterman Basin Rating = 4
	Score = 12	Score = 16	Score = 8	Score = 12	Score = 8	Score = 12	Score = 16
Access Weight = 1	Access from E. 23 <sup>rd</sup> Street Rating = 5	Access from E. Highland Ave.	Access from E. Highland Ave.	Access from N. Waterman Ave. (busy)	Access from E. 40 <sup>th</sup> Str. Rating = 5	Access from E. 40 <sup>th</sup> Str. Rating = 5	Access through SBCFCD Property
	Score - 5	Score = 4	Score = 4		Score - 5	S each	Score = 2
Utilities Weight = 1	No Utilities on Site Rating = 5	Irrigation Utilities on Site Rating = 4	Irrigation Utilities on Site Rating = 4	Irrigation Utilities on Site Rating = 4	Irrigation/Ball Field Utilities On Site Rating = 3	No Utilities on Site Rating = 5	No Utilities on Site Rating = 5
	Score = 5	Score = 4	Score = 4	Score = 4	Score = 3	Score = 5	Score = 5
Power Supply Weight = 3	Power Available, overhead on E. 23 <sup>rd</sup> Str.	Power Available, overhead on E. Highland	Power Available, overhead on E. Highland	Power Available, overhead on N. Waterman	Power Available, overhead on E. 40 <sup>th</sup> Str.	Power Available, overhead on E. 40 <sup>th</sup> Str.	Power facilities needed to site (3,300 feet)
	Rating = 5	Rating = 5	Rating = 5	Rating = 5	Rating = 5	Rating = 5	Rating = 1
	Score = 15	Score = 15	Score = 15	Score = 15	Score = 15	Score = 15	Score = $5$
Constructability Weight = 4	Limited Space; above-ground; flat Rating = 4	Space available; Buried; flat Rating = 3	Space available; above-ground; flat Rating = 5	Space available; Buried; flat Rating = 3	Space available; buried; flat Rating = 3	Limited Space; above-ground; sloped Rating = 3	Limited Space; above-ground; sloped Rating = 2
	Score = 16	Score = 12	Score =20	Score = 12	Score = 12	Score = 12	Score = 8
Land Condition Weight = 3	Open Land, dirt Rating = 5	Park, grass Rating = 4	Park, grass Ratina = 4	Park, grass Rating = 4	Park, ball field Rating = 3	Edge of Channel; dirt Rating = 4	Vegetation Rating = 2
	Score = 15	Score = 12	Score = 12	Score = 12	Score = 9	Score = 12	Score = 6
Construction Costs* Weight = 5	\$ 26.6 M Rating = 3	\$ 29.5 M Rating = 2	\$ 26.0 M Rating = 4	\$ 23.8 M Rating = 2	\$ 24.2 M Rating = 2	\$19.1 M Rating = 5	\$20.8 M Rating = 2
	Score = 15	Score = 10	Score = 20	Score = 10	Score = 10	Score = 25	Score = 10
Operation & Maintenance	\$ 0.83 M/yr Rating – 3	\$ 0.86 M/yr Rating = 3	\$ 0.82 M/yr Rating – 3	\$ 0.34 M/yr Rating – 4	\$ 0.35 M/yr Rating – 4	\$ 0.29 M/yr Rating – 4	\$ 0.32 M/yr Rating = 4
Weight = 5	Score = 15	Score = 15	Score = 15	Score = 20	Score = 20	Score = 20	Score = 20
TOTĂL	Overall Score	Overall Score	Overall Score	Overall Score	Overall Score	Overall Score	Overall Score
(Weight = 35)	116	121	135	122	113	126	87
Weighted SCORE	%99	%69	77%	%02	%59	72%	20%
DECISION SCORE	0.713	0.734	0.773	0.722	0.662	0.742	0.500
RANK	3 <sup>rd</sup>	2 <sup>nd</sup>	1 st	2 <sup>nd</sup>	3 <sup>rd</sup>	ν	<b>4</b> <sup>th</sup>
* Construction and O&M cost	s are based on Conveyance S	Scenario 2 for Sites A/B/C and	* Construction and O&M costs are based on Conveyance Scenario 2 for Sites A/B/C and based on Conveyance Scenario 3 or 4 for Sites D/E/F/G	io 3 or 4 for Sites D/E/F/G			



Value Alternatives Decision Scores Pump Station/Tank Site A 0.713 0.734 Pump Station/Tank Site B Pump Station/Tank Site C Pump Station/Tank Site D 0.722 Northern Location Sites Pump Station/Tank Site E 0.662 0.742 Pump Station/Tank Site F Pump Station/Tank Site G 0.500

Figure 9-8
Pump Station/Storage Reservoir Site Options Evaluation

# 9.4.1 Pump Station/Storage Reservoir Site A

This site had the lowest ranking of the three intermediate location sites. Primary factors for the evaluation and ranking of Site A were the private ownership of the lot in a commercial area with limited space for future expansion.

### 9.4.2 Pump Station/Storage Reservoir Site B

This site ranked second of the three intermediate location sites. Primary factors for the evaluation and ranking of Site B were the location within Perris Hill Park near the entrance to the park would likely require the storage reservoir to be buried, with increased costs and difficulty of construction.

### 9.4.3 Pump Station/Storage Reservoir Site C

This site ranked first of the three intermediate location sites. Primary factors for the evaluation and ranking of Site C were the location within Perris Hill Park near East Twin Creek Channel, which would likely allow the storage reservoir to be constructed above-grade, reducing costs and decreasing difficulty of construction. The location of Site C was considered the most compatible location within Perris Hill Park since it is adjacent to an existing structure (the YMCA building), and is at an edge of the park near East Twin Creek Channel.

July 2012 9-8 Summary Report

### 9.4.4 Pump Station/Storage Reservoir Site D

This site ranked second of the four northern location sites. Primary factors for the evaluation and ranking of Site C were the location within Perris Hill Park in an area without existing facilities and reduced visual impact with the storage reservoir likely buried. This option did have higher costs and difficulty of construction.

### 9.4.5 Pump Station/Storage Reservoir Site E

This site ranked third of the four northern location sites. Primary factors for the evaluation and ranking of Site E were the location within Perris Hill Park in an area with existing ball park facilities and reduced visual impact with the storage reservoir likely buried. This option did have higher costs and difficulty of construction.

### 9.4.6 Pump Station/Storage Reservoir Site F

This site ranked first of the four northern location sites. Primary factors for the evaluation and ranking of Site F were the location near the edge of East Twin Creek Channel with the storage reservoir above-grade, which reduced costs and decreased difficulty of construction. This option would require more grading and coordination with the SBCFCD including property acquisition or a license agreement.

# 9.4.7 Pump Station/Storage Reservoir Site G

This site had the lowest ranking of the four northern location sites. Primary factors for the evaluation and ranking of Site G were the location within SBCFCD property within a vegetated area that required extension of power facilities. This option has several disadvantages, but was considered as an option that would allow the storage reservoir to be terminal storage without a separate pump station for flow to the Recharge Basins.

### 9.5 SUMMARY

Based on the evaluation, any of the seven sites are feasible for the CWF Project. There are noted advantages for Pump Station/Storage Reservoir Site Option C for the intermediate location and Site Option F for the northern site location, which both ranked the highest in the evaluation. Coordination with the City's Parks and Recreation Department will be imperative in further development and selection of Site Option C as the preferred intermediate site. Coordination with the SBCFCD is recommended in further development and selection of Site Option F as the preferred northern site.

# 9.6 FACILITY POWER REQUIREMENTS

A preliminary investigation was conducted to identify power requirements for the preferred Pump Station/Storage Reservoir Sites. First, power requirements were developed for each Pump Station/Storage Reservoir Site configuration for each conveyance scenario. Then each site was evaluated to determine the power available at or near each site. Pump Station/Storage Reservoir Sites A, B, C, D, E, and F all have existing available power from Southern California Edison (SCE)'s exiting overhead power grid. A service connection, transformer, and meter would be required to bring 480 volt/3 phase power to the site. Pump Station/Storage Reservoir Site G is located north of Waterman Basin and does not have existing available power on site. However, an approximate 3,300 foot long extension of SCE's overhead power grid from E. 40<sup>th</sup> Street to the site could provide power to the site.

Estimated energy use for various Pump Station/Storage Reservoir Site configurations for each conveyance alternative were developed and are included in the cost data in Appendix D-4.

### 9.7 COST ESTIMATES


Feasibility-level cost estimates were prepared for the seven preferred Pump Station/Storage Reservoir Site Options based on feasibility-level planning data collected and developed as part of this analysis. Due to the preliminary status of the project, the current unpredictable bidding climate, and estimated project schedule, opinions of probable costs should be updated regularly as the project is better defined. A contingency of 30 percent was applied to the estimated construction costs to account for the preliminary nature of the project. An additional allocation of 30 percent was made for administrative, legal, design, and construction management costs in order to define overall project costs. Utilizing a Class 4 Estimate for feasibility-level estimates as defined by the AACEI, an estimated range of -15 percent to +30 percent can be expected and an additional contingency of 15 percent was applied to the overall project costs. Finally, with the estimated mid-point of construction in three years (March 2015), an escalation cost due to projected inflation at an annual rate of 4 percent was applied (total inflation for three years equal to 12.5 percent).

Based on the current understanding of the project's criteria and general assumptions made regarding facility locations and configurations, this opinion is intended to provide a feasibility-level overall cost. Unit costs for pump stations and storage reservoirs were based on historical cost data compiled from multiple similar projects and the experience of RBF and Black & Veatch. This estimate was compiled in March 2012 with an ENR – CCI (Los Angeles) of 10,283.55. Therefore, the costs can be updated once the schedule has been further defined. Table 9-5 summarizes the feasibility-level costs for each preferred Pump Station/Storage Reservoir Site Option. More detailed cost information for each preferred Pump Station/Storage Reservoir Site is included in Appendix D-2.

July 2012 9-10 Summary Report

Table 9-5
Pump Station/Storage Reservoir Site Feasibility-Level Cost Estimate

Conveyance Scenario	Site A	Site B	Site C	Site D	Site E	Site F	Site G
1	\$3.2 M	\$3.7 M	\$2.5 M	N/A	N/A	N/A	N/A
2	\$26.6 M	\$29.5 M	\$26.0 M	N/A	N/A	N/A	N/A
3	N/A	N/A	N/A	\$23.8 M	\$24.2 M	\$19.1 M	\$20.8 M
4	\$19.6 M	\$19.3 M	\$19.0 M	\$23.8 M	\$24.2 M	\$19.1 M	\$20.8 M
5	\$3.2 M	\$3.7 M	\$2.5 M	N/A	N/A	N/A	N/A
6	\$30.6 M	\$33.6 M	\$30.0 M	N/A	N/A	N/A	N/A





SAN BERNARDINO MUNICIPAL WATER DEPARTMENT


INTERMEDIATE PUMP STATION AND RESERVOIR SITE - OPTION D


FIGURE

- PDATA/65100826/CADD/WATER/EXHIBITS/FACILITYLAYOUTS/0826-0PTIOND.DWC JABDI 4/2/12 8:57 om

BLACK & VEATCH Building a world of difference: 14725 ALTON PARKWAY IRVINE, CALIFORNIA 92818-2027 949.472.3505 = FAX 949.472.8373 = www.RBF.com CONSULTING

PLANNING B DESIGN B CONSTRUCTION









# 10.0 CONVEYANCE SYSTEM SCENARIOS

An analysis was conducted to evaluate potential Conveyance Scenarios with various configurations of pipelines and Pump Station/Storage Reservoir Sites within a Conveyance Facility Corridor between the SBWRP and the Recharge Basins. Six potential Conveyance Scenarios were identified. An evaluation of the Conveyance Scenarios was conducted considering evaluation factors and rating each scenario.

### 10.1 OVERVIEW

The six Conveyance Scenarios represent possible overall configuration of the conveyance system to deliver recycled water to direct use customers and to the Recharge Basins and deliver advanced water to the Recharge Basins. Each conveyance scenario could utilize different Pipeline Alignment Options and Pump Station/Storage Reservoir Site Options. In fact, there are 100 possible combinations of Conveyance Scenarios with various Pipeline Alignment Options and Pump Station/Storage Reservoir Site configurations. In order to conduct a comparative analysis of the Conveyance Scenarios, the highest ranked preferred pipeline alignment option was selected (Pipeline Alignment Option 1) and used to compare the various Conveyance Scenarios. Likewise, the highest ranked preferred Pump Station/Storage Reservoir Site Option was selected (Site Option C for the intermediate location, or Site Option F for the northern location). The ranking for Pipeline Alignment Options was presented in Section 8 and for Pump Station/Storage Reservoir Site Options in Section 9.

### 10.2 SCENARIOS

There are six potential Conveyance Scenarios. Each of the Conveyance Scenarios was evaluated, rated, and ranked. The ranking of Conveyance Scenarios is shown on Table 10-1

### 10.2.1 Conveyance Scenario 1

Conveyance Scenario 1 would consist of a single conveyance system with one lift to deliver advanced treated water to direct use northern customers and the Recharge Basins. A separate recycled water system would serve direct use customers near SBWRP. For comparison purposes, this scenario utilized Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C.

### 10.2.2 Conveyance Scenario 2

Conveyance Scenario 2 would consist of a single conveyance system with two lifts to deliver advanced treated water to direct use northern customers and the Recharge Basins. A separate recycled water system would serve direct use customers near SBWRP. For comparison purposes, this scenario utilized Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C.

July 2012 10-1 Summary Report

### 10.2.3 Conveyance Scenario 3

Conveyance Scenarios 3 would consist of dual conveyance systems with one recycled water pipeline serving direct use northern customers and one advanced water pipeline with one lift to the Recharge Basins. A separate recycled water system would serve direct use customers near SBWRP. For comparison purposes, this scenario utilized Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option F (for the recycled water pipeline).

### 10.2.4 Conveyance Scenario 4

Conveyance Scenario 4 would consist of dual conveyance systems with one recycled water pipeline serving direct use northern customers and one advanced water pipeline with two lifts to the Recharge Basins. A separate recycled water system would serve direct use customers near SBWRP. For comparison purposes, this scenario utilized Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C (for the recycled water pipeline) and Pump Station/Storage Reservoir Site Option F (for the advanced water pipeline).

### 10.2.5 Conveyance Scenario 5

Conveyance Scenario 5 would consist of a single conveyance system with one lift to deliver recycled water to both direct use northern customers and to an advanced water treatment plant located at the Recharge Basins. For comparison purposes, this scenario utilized Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C.

### 10.2.6 Conveyance Scenario 6

Conveyance Scenario 6 would consist of a single conveyance system with two lifts to deliver recycled water to both direct use northern customers and to an advanced water treatment plant located at the Recharge Basins. For comparison purposes, this scenario utilized Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C.

### 10.3 EVALUATION CRITERIA

Critical evaluation factors relative to the construction and operation of the Conveyance Scenarios were developed to evaluate the advantages and disadvantages of each conveyance scenario. Each factor was evaluated and rated using an established rating system. Conveyance Scenarios with advantages were rated higher and those with disadvantages were rated lower. Six critical evaluation factors were developed for the Conveyance Scenarios: water supply, operation, treatment facilities location, flexibility for future expansion, construction costs, and O&M costs.

### 10.3.1. Water Supply

The ability to supply recycled water and advanced treated water to direct use customers and for groundwater recharge was evaluated. Delivery of advanced treated water to direct use customers is a disadvantage because the water is treated to level higher than necessary. Scenarios that utilize recycled water for direct use customers were rated higher than those that use advanced treated water for direct use customers. Use of the IEBL at the SBWRP for disposal of brine was rated higher than scenarios that would require a new brine pipeline.

### 10.3.2. Operation

The ease of operation of conveyance alternatives was evaluated. System operation was considered for direct use customers with operation of pump station and tank system to provide service and handle seasonal and diurnal demands including peak month, peak day, and peak hour demands. System operation was considered for advanced treated water recharge of groundwater considering pump station and tank system operation. Use of storage tanks to supply direct use customers were rated higher than those with a closed loop system or direct supply by pumping. System pressures were also evaluated with lower pressure systems rated higher than systems with higher pressures.

### 10.3.3. Treatment Facilities Location

The location of treatment facilities was evaluated whether at the SBWRP or at the Recharge Basins. A new treatment plant at the Recharge Basins has several disadvantages including: operation remote from the existing SBWRP, additional staffing, new property requirements, no method of diverting flow if there are treatment issues, and permitting a new plant. Scenarios that have treatment facilities at the SBWRP were rated higher than those that have the treatment plant at the Recharge Basins.

### 10.3.4. Flexibility for Future Expansion

This criterion is used to evaluate the ability for future expansion of conveyance facilities to connect to potential future direct use customers. Conveyance Scenarios with advanced treated water delivery to recycled customers were rated lower than those that provide recycled water to direct use customers due to advanced treatment limitations (maximum 14.2 mgd limited by IEBL contractual capacity of 2.5 mgd). Expansion flexibility of treatment facilities was also evaluated with treatment facilities at the SBWRP ranking higher than treatment facilities at the Recharge Basins due to land availability.

### 10.3.5. Construction Costs

The estimated construction cost of conveyance alternatives was evaluated. Conveyance Scenarios were rated based on their relative estimated construction costs.

### 10.3.6. Operation and Maintenance Costs

The estimated O&M cost of conveyance alternatives were evaluated. Conveyance Scenarios were rated based on their relative estimated construction costs.

### 10.4 CONVEYANCE SCENARIO RANKINGS

Similar to the pipeline alignment and Pump Station/Storage Reservoir Site evaluation and ranking, *Criterium Decision Plus*, was utilized for conveyance scenarios (see Section 8.10). The same rating and weighting definitions were used. Each scenario was rated based upon its ability to satisfy the project objectives. The alternatives were rated using a scale of 1 to 5 as shown in Table 10-1 with a higher rating indicating a more favorable scenario or option.

Table 10-1
Definition of Rating System

Definition	Rating
Satisfies project objectives with significant noted advantages	5
Satisfies project objectives with noted advantages	4
Satisfies project objectives	3
Satisfies project objectives with noted disadvantages	2
Satisfies project objectives with significant noted disadvantages	1

Each evaluation criterion was then assigned a weight representing the importance of the criteria on a scale of 1 to 5. A higher weight represents a more important criteria as shown in Table 10-2.

Table 10-2
Definition of Weighting System

Definition	Rating
Critical Importance	5
Significant Importance	4
Important	3
Low Importance	2
Least Importance	1

Evaluation criteria weightings for Conveyance Scenarios are shown in Table 10-3.

Table 10-3 Conveyance Scenario Criteria Weighting

Evaluation Criteria	Weight
Water Supply	3
Operation	4
Treatment Facilities Location	2
Flexibility for Future Expansion	2
Construction Costs	5
Operations and Maintenance Costs	5

A score for each evaluation criterion was calculated by multiplying the rating and the weight. A higher score indicated a more favorable conveyance scenario.

The overall scores were compared for each scenario. The overall score is a good indication as to which Conveyance Scenarios are the best match for meeting the project objectives.

Since the overall score may not add up to 100, a decision score was calculated for each scenario. The overall scores were converted to percentages; therefore the ideal score would have value of 100 percent. The higher the decision score of the alternative, the closer that alternative would come to meeting all the project objectives considering the criteria impacting the decision.

Utilizing *Criterium Decision Plus*, a decision score was calculated with an ideal score of 1.00. The higher the decision score of the option, the closer that option would come to meeting all the project objectives considering the criteria impacting the decision. Weighted scores and decision scores were similar, but since *Criterium Decision Plus* utilizes a more complex integrated rating and ranking system, the decision score was considered in evaluating the rank.

The highest score is considered the highest ranked or preferred scenario. Ranks were then assigned to the remaining scenarios in the order of highest score to lowest score.


The ranking of Conveyance Scenarios is shown in Table 10-4 and depicted graphically on Figure 10-1.

Table 10-4 Conveyance Scenarios Evaluation and Ranking

Evaluation Factor	Conveyance Scenario 1	Conveyance Scenario 2	Conveyance Scenario 3	Conveyance Scenario 4	Conveyance Scenario 5	Conveyance Scenario 6
Water	Advanced	Advanced	Recycled	Recycled	Recycled	Recycled
Supply	Water to	Water to Direct				
Weight = 3	Direct Use	Use				
Ü	Customers;	Customers;	Customers;	Customers;	Customers;	Customers;
	Brine at	Brine at	Brine at	Brine at	Needs Brine	Needs Brine
	SBWRP	SBWRP	SBWRP	SBWRP	Pipeline	Pipeline
	Rating = 2	Rating = 2	Rating = 5	Rating = 5	Rating = 2	Rating = 2
	Score = 6	Score = 6	Score = 15	Score = 15	Score = 6	Score = 6
Operation	Difficult	Difficult	Flexible	Flexible	Flexible	Flexible
Weight = 4	Seasonal	Seasonal	Seasonal	Seasonal	Seasonal	Seasonal
	Operation;	Operation;	Operation;	Operation;	Operation;	Operation;
	Partial System	Partial System	System Floats	System Floats	Partial System	Partial System
	Float on Tank;	Float on Tank;	on Tank;	on Tank;	Float on Tank;	Float on Tank;
	250 psi	150 psi	250 psi	150 psi	250 psi	150 psi
	Pressure	Pressure	Pressure	Pressure	Pressure	Pressure
	Rating = 1	Rating = 2	Rating = 4	Rating = 5	Rating = 3	Rating = 4
	Score = 4	Score = 8	Score = 16	Score =20	Score = 12	Score = 16
Treatment	Treatment at					
Plant	SBWRP	SBWRP	SBWRP	SBWRP	Rechg. Basins	Rechg. Basins
Location	Rating = 5	Rating = 5	Rating = 5	Rating = 5	Rating = 1	Rating = 1
Weight = 3	Score = 15	Score = 15	Score =15	Score = 15	Score = 3	Score = 3
Flexibility for	Advanced	Advanced	Recycled	Recycled	Recycled	Recycled
Future	Water to	Water to Direct				
Expansion	Direct Use	Use				
Weight = 2	Customers;	Customers;	Customers;	Customers;	Customers;	Customers;
	Treatment at					
	SBWRP	SBWRP	SBWRP	SBWRP	Rechg. Basins	Rechg. Basins
	Rating = 2	Rating = 2	Rating = 5	Rating = 5	Rating = 2	Rating = 2
	Score = 4	Score = 4	Score =10	Score =10	Score = 4	Score =4
Construction	\$ 132 M	\$ 139 M	\$ 177 M	\$ 185 M	\$ 155 M	\$ 167 M
Costs	Rating = 5	Rating = 5	Rating = 2	Rating = 1	Rating = 4	Rating = 3
Weight = 5	Score = 25	Score = 25	Score = 10	Score = 5	Score = 20	Score = 15
O&M Costs	\$ 2.5 M/yr	\$ 2.6 M/yr	\$ 3.1 M/yr	\$ 3.6 M/yr	\$ 3.5 M/yr	\$ 3.6 M/yr.
Weight = 5	Rating = 5	Rating = 5	Rating = 4	Rating = 3	Rating = 3	Rating =3
	Score = 25	Score = 25	Score = 20	Score = 15	Score = 15	Score = 15
TOTAL	Overall Score					
(Weight = 22)	79	83	86	80	60	59
Weighted SCORE	72%	76%	78%	73%	55%	54%
DECISION SCORE	0.682	0.720	0.829	0.800	0.498	0.503
RANK	4 <sup>th</sup>	3rd	1 <sup>st</sup>	2 <sup>nd</sup>	6 <sup>th</sup>	5th

<sup>\*</sup> Construction and O&M costs are based on Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C and/or F

Figure 10-1 Conveyance Scenarios Evaluation



The cost of each scenario in Table 10-4 considers the construction and O&M costs independent of the amount of water produced. A parallel evaluation was developed for each conveyance scenario to analyze the cost per acre foot of water produced, and the results are shown in Table 10-5. A combined weight of 10 was assigned for the combined cost per acre-foot. Capital and O&M costs for treatment and the recharge basins were developed from data in the Recycled Water Report. The cost per acre-foot does not include IEBL charges.

The per acre-foot costs include consideration of reduced costs from reduced secondary treated effluent flows to the RIX facility and subsequent reduced tertiary treatment costs at the RIX facility. Estimated costs were developed in coordination with SBMWD for reduced treatment at the RIX Facility considering reduced use of sand filters and continued use of percolation/extraction treatment. The unit cost of treatment at the RIX facility drops to approximately \$43,000 per mgd if RIX is operating at or below 22 mgd as originally designed with percolation and extraction only. Current and reduced flows to the RIX facility and corresponding reduced per acre-foot costs are shown in Table 10-6. These reduced per acre-foot cost have already been incorporated in to the per-acre foot costs in Table 10-5.

Table 10-5 Conveyance Scenarios Evaluation and Ranking (per Acre-Foot)

Scenario 1   Scenario 2   Scenario 3   Scenario 4   Scenario 5	
Supply   Water to   Direct Use   Direct Us	Conveyance Scenario 6
Supply   Water to   Direct Use   Direct Us	Recycled
Direct Use   Customers;   Direct Use   Customers;   Cus	Water to Direct
Customers;   Brine at   Brine at   SBWRP   SECORE = 6   Score = 6   Score = 15   Score = 15   Score = 6   Score = 6   Score = 15   Score = 15   Score = 6   Score = 15   Score = 6   Seasonal   Seasonal   Seasonal   Seasonal   Operation; Ope	Use
SBWRP	Customers;
Rating = 2   Score = 6   Score = 15   Score = 15   Score = 6	Needs Brine
Rating = 2   Score = 6   Score = 15   Score = 15   Score = 6	Pipeline
Score = 6	Rating = 2
Operation Weight = 4Difficult Seasonal Operation; Partial System 	Score = 6
Weight = 4Seasonal Operation; Partial System Float on Tank; 150 psi Pressure Rating = 1Seasonal Operation; Partial System Float on Tank; 150 psi Pressure Rating = 1Seasonal Operation; System Floats On Tank; 150 psi Pressure Pressure Rating = 2Seasonal Operation; System Floats On Tank; Pressure Pressure Pressure Rating = 3Seasonal Operation; System Floats On Tank; Pressure Pressure Pressure Rating = 5System Floats On Tank; Pressure Pressure Rating = 5Pressure Rating = 5Pressure Rating = 3Treatment Plant Location Weight = 3Treatment at Score = 15Treatment at Score = 15Treatment at Score = 15Treatment at Score = 15Treatment at Rating = 5Treatment at Rating = 5Treatment at Rating = 1Flexibility for Future Weight = 2Advanced Water to Direct Use Direct Use Direct UseRecycled Water to Direct Use Direct Use <td>Flexible</td>	Flexible
Operation; Partial System Floats on Tank; Partial System Float on Tank; Pressure Rating = 1 Rating = 2 Rating = 4 Rating = 5 Rating = 3  Treatment Plant Sybrem Rating = 5 Rating = 5 Rating = 5 Rating = 1  Cocation Rating = 5 Rating = 5 Rating = 1  Score = 15 Score = 15 Score = 15 Score = 15  Flexibility for Future Water to Expansion Direct Use Direct Use Weight = 2  Cost per Sure Rating = 2 Rating = 5 Rating = 2  Score = 4 Score = 4 Score = 5 Rating = 5 Rating = 5 Rating = 5 Rating = 1  Score = 4 Score = 15 Score = 15 Score = 15 Score = 15  Score = 15 Score = 15 Score = 15 Score = 15 Score = 3  Flexibility for Future Rating = 5 Rating = 1 Ra	Seasonal
Partial System Float on Tank; Float on Tank; Pressure Rating = 1 Score = 4 Float on Tank at Plant Float on Tank; Float on Tank	Operation;
Float on Tank;   Float on Tank;   250 psi   150 psi   250 psi   150 psi   250 psi   150 psi   250 psi   Pressure   Pressure   Rating = 1   Rating = 2   Rating = 4   Rating = 5   Rating = 3   Rating = 5   Rating = 3   Rating = 5   Rating = 3   Rating = 5   Rating = 1   Rating = 1   Rating = 5   Rating	Partial System
250 psi	Float on Tank;
Pressure	150 psi
Score = 4 Score = 8 Score = 16 Score = 20 Score = 12  Treatment Plant Plant Location Weight = 3  Flexibility for Future Expansion Weight = 2  Customers; Treatment at SBWRP SBWRP Score = 15 Score = 3 Flexibility for Future Expansion Direct Use Direct Use Direct Use Direct Use Direct Use Customers; Customers; Customers; Customers; Treatment at SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP Rating = 2 Score = 4 Score = 4 Score = 10 Score = 10 Score = 10 Score = 10 Score = 12  Treatment at Treatment at Treatment at Treatment at Treatment at Treatment at SCORE = 10 Score = 10 Score = 10 Score = 4 Score = 10	Pressure
Score = 4 Score = 8 Score = 16 Score = 20 Score = 12  Treatment Plant Plant Location Weight = 3  Flexibility for Future Expansion Weight = 2  Customers; Treatment at SBWRP SBWRP Score = 15 Score = 3 Flexibility for Future Expansion Direct Use Direct Use Direct Use Direct Use Direct Use Customers; Customers; Customers; Customers; Treatment at SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP SBWRP Rating = 2 Score = 4 Score = 4 Score = 10 Score = 10 Score = 10 Score = 10 Score = 12  Treatment at Treatment at Treatment at Treatment at Treatment at Treatment at SCORE = 10 Score = 10 Score = 10 Score = 4 Score = 10	Rating = 4
Plant LocationSBWRP Rating = 5SBWRP Rating = 5SBWRP Rating = 5SBWRP 	Score = 16
Plant Location Weight = 3SBWRP Rating = 5SBWRP Rating = 5SBWRP Rating = 5SBWRP Rating = 5Recharge Rating = 5Flexibility for FutureAdvanced Water to ExpansionAdvanced Water to Direct UseRecycled Water to Direct UseRecycled Water to Direct UseRecycled Water to Direct UseWeight = 2Customers; Treatment at SBWRP Rating = 2Customers; Rating = 2Customers; Rating = 5Customers; Rating = 5Customers; Rating = 5Treatment at Rating = 5Treatment at Rating = 5Treatment at Rating = 5Cost per\$ 1,414/AF\$ 1,435/AF\$ 1,173/AF\$ 1,213/AF\$ 1,318/AF	Treatment at
Location Weight = 3Rating = 5Rating = 5Rating = 5Rating = 5Basins Rating = 1Flexibility for FutureAdvanced Water toAdvanced Water toRecycled Water toRecycled Water toRecycled Water toExpansion Weight = 2Direct Use Customers; Treatment at SBWRP Rating = 2Direct Use Customers; Rating = 2Direct Use Customers; Rating = 5Direct Use Customers; Treatment at SBWRP Rating = 5Customers; SBWRP Rating = 5Customers; Treatment at Rating = 5Treatment at Recharge Rating = 5Score = 4Score = 4Score = 10Score = 10Score = 4Cost per\$ 1,414/AF\$ 1,435/AF\$ 1,173/AF\$ 1,213/AF\$ 1,318/AF	Recharge
Weight = 3         Score = 15         Score = 15         Score = 15         Score = 15         Score = 3           Flexibility for Future Future Future Future Future Future Expansion Weight = 2         Water to Wate	Basins
Score = 15	Rating = 1
Future Expansion Direct Use Direct Use Direct Use Customers; Treatment at SBWRP Rating = 2 Rating = 2 Score = 4 Score = 4 Score = 10 Score = 10 Score = 10 Score = 4 Score = 4 Score = 10 Score = 10 Score = 10 Score = 10 Score = 4 Score = 10 Score = 4 Score = 10 Score = 4 Score = 10 Score = 10 Score = 4 Score = 10 Score	Score = 3
Future Expansion Direct Use Direct Use Direct Use Customers; Treatment at SBWRP Rating = 2 Rating = 2 Score = 4 Score = 4 Score = 10 Score = 10 Score = 10 Score = 4 Score = 4 Score = 10 Score = 10 Score = 10 Score = 10 Score = 4 Score = 10 Score = 4 Score = 10 Score = 4 Score = 10 Score = 10 Score = 4 Score = 10 Score	Recycled
Weight = 2         Customers; Treatment at SBWRP         Customers; Treatment at SBWRP         Customers; Treatment at SBWRP         Customers; Treatment at SBWRP         Customers; Treatment at SBWRP         Customers; Treatment at SBWRP         Recharge Rating = 5         Basins Rating = 2           Score = 4         Score = 4         Score = 10         Score = 10         Score = 4           Cost per         \$ 1,414/AF         \$ 1,435/AF         \$ 1,173/AF         \$ 1,213/AF         \$ 1,318/AF	Water to Direct
Treatment at   SBWRP   SBWRP   SBWRP   SBWRP   Rating = 2   Rating = 5   Rating = 5   Rating = 5   Rating = 2   Score = 4   Score = 10   Score = 10   Score = 4   Score = 4   Standard	Use
Treatment at   SBWRP   SBWRP   SBWRP   SBWRP   Rating = 2   Rating = 5   Rating = 5   Rating = 5   Rating = 2   Score = 4   Score = 10   Score = 10   Score = 4   Score = 4   Standard	Customers;
	Treatment at
	Recharge
Score = 4         Score = 4         Score = 10         Score = 10         Score = 4           Cost per         \$ 1,414/AF         \$ 1,435/AF         \$ 1,173/AF         \$ 1,213/AF         \$ 1,318/AF	Basins
Cost per \$ 1,414/AF \$ 1,435/AF \$ 1,173/AF \$ 1,213/AF \$ 1,318/AF	Rating = 2
	Score =4
	\$ 1,351/AF
	Rating $= 3$
Weight = 10	Score = 30
TOTAL Overall Score Overall Score Overall Score Overall Score Overall Score Overall Score	Overall Score
(Weight = 22) 49 53 106 110 55	59
Weighted         45%         48%         96%         100%         50%           SCORE         30%         3	54%
DECISION         0.482         0.520         0.962         1.000         0.465           SCORE	0.503
RANK 5th 3rd 2nd 1st 6th	4 <sup>th</sup>

<sup>\*</sup> Cost per Acre-Foot are based on Pipeline Alignment Option 1 and Pump Station/Storage Reservoir Site Option C and/or F

Table 10-6
Reduced RIX Facility Treatment Costs

Canania	Flow to RIX	Reduced flow	Reduced Cost	Reduced Cost per
Scenario	from SBWRP	to RIX	per Year	Acre-Foot
Current Condition	22 mgd	0 mgd	\$0	\$0
Scenario 1 or 2	14.2 mgd	7.8 mgd	\$842,000	\$46
Scenario 3 or 4	7.2 mgd	14.8 mgd	\$1,278,000	\$49
Scenario 5 or 6	5.7 mgd	16.8 mgd	\$1,344,000	\$52

### 10.4.1 Conveyance Scenario 1

This scenario ranked fourth in the original analysis and ranked fifth in the cost per acre-foot analysis. Primary factors for the evaluation and ranking of Conveyance Scenario 1 were the delivery of advanced treated water to direct use customers (excess treatment), difficulty of operation during seasonal fluctuations and only part of the system operates by floating off an intermediate storage reservoir, higher pipeline pressure (250 psi), and limited flexibility for expansion for additional direct use customers in the future (advanced treated water is limited to 14.2 mgd by SBMWD's contractual discharge capacity in the IEBL). This scenario does have lower construction and O&M costs, but considering the capacity of this scenario, it had a high overall cost per acre foot of water.

### 10.4.2 Conveyance Scenario 2

This scenario ranked third in the original analysis and ranked third in the cost per acre-foot analysis. Primary factors for the evaluation and ranking of Conveyance Scenario 1 were the delivery of advanced treated water to direct use customers (excess treatment), difficulty of operation during seasonal fluctuations and only part of the system operates by floating off an intermediate storage reservoir, lower pipeline pressure (150 psi), and limited flexibility for expansion for additional direct use customers in the future (advanced treated water is limited to 14.2 mgd by SBMWD's contractual discharge capacity in the IEBL). This scenario does have lower construction and O&M costs, but considering the capacity of this scenario, it had a high overall cost per acre foot of water.

### 10.4.3 Conveyance Scenario 3

This scenario ranked first in the original analysis and ranked second in the cost per acre-foot analysis. Primary factors for the evaluation and ranking of Conveyance Scenario 3 were use of separate pipelines to deliver the type of water needed (recycled or advanced treated water), flexible seasonal operation and ease of operating the recycled water system by floating off a northern storage reservoir, and the ability to expand the recycled water system in the future. This scenario does operate on a higher pipeline pressure (250 psi), but this is addressed with use

July 2012 10-10 Summary Report

of ductile iron pipe. This scenario does have higher construction and O&M costs, but considering the additional capacity of this scenario, it had a low overall cost per acre foot of water.

### 10.4.4 Conveyance Scenario 4

This scenario ranked second in the original analysis and ranked first in the cost per acre-foot analysis. Primary factors for the evaluation and ranking of Conveyance Scenario 4 were use of separate pipelines to deliver the type of water needed (recycled or advanced treated water), flexible seasonal operation and ease of operating the recycled water system by floating off a northern storage reservoir, lower pipeline pressure (150 psi), and the ability to expand the recycled water system in the future. This scenario does have higher construction and O&M costs, but considering the additional capacity and this scenario, it had a low overall cost per acre foot of water.

### 10.4.5 Conveyance Scenario 5

This scenario ranked last in the original analysis and ranked last in the cost per acre-foot analysis. Primary factors for the evaluation and ranking of Conveyance Scenario 5 were the need for a separate brine line from the Recharge Basins to the SBWRP, flexible seasonal operation but only part of the system operates by floating off an intermediate storage reservoir, higher pipeline pressure (250 psi), location of the treatment plant at the Recharge Basins, and limited ability for expansion of treatment facilities at the Recharge Basins. This scenario had higher construction and O&M costs, and even considering the additional capacity and this scenario, it had a high overall cost per acre foot of water.

### 10.4.6 Conveyance Scenario 6

This scenario ranked fifth in the original analysis and ranked fourth in the cost per acre-foot analysis. Primary factors for the evaluation and ranking of Conveyance Scenario 6 were the need for a separate brine line from the Recharge Basins to the SBWRP, flexible seasonal operation but only part of the system operates by floating off an intermediate storage reservoir, lower pipeline pressure (150 psi), location of the treatment plant at the Recharge Basins, and limited ability for expansion of treatment facilities at the Recharge Basins. This scenario had higher construction and O&M costs, and even considering the additional capacity and this scenario, it had a high overall cost per acre foot of water.

### 10.5 SUMMARY

Based on the evaluation, any of the six Conveyance Scenarios would be feasible for the CWF Project. There are noted advantages for Conveyance Scenarios 3 and 4, which ranked the highest in the evaluation. Consideration of overall project objectives and cost per acre foot of water make Conveyance Scenarios 3 and 4 attractive even though initial construction costs are

July 2012 10-11 Summary Report

higher than Conveyance Scenarios 1 and 2. There are significant disadvantages for Conveyance Scenarios 5 and 6, and eliminating these scenarios should be considered by SBMWD particularly in the ongoing environmental documentation process.

### 10.6 COST ESTIMATES

Feasibility-level cost estimates were prepared for the six Conveyance Scenarios based on feasibility-level planning data collected and developed as part of this analysis. Due to the preliminary status of the project, the current unpredictable bidding climate, and estimated project schedule, opinions of probable costs should be updated regularly as the project is better defined. A contingency of 30 percent was applied to the estimated construction costs to account for the preliminary nature of the project. An additional allocation of 30 percent was made for administrative, legal, design, and construction management costs in order to define overall project costs. Utilizing a Class 4 Estimate for feasibility-level estimates as defined by the Association for the AACEI, a estimated range of -15 percent to +30 percent can be expected and an additional contingency of 15 percent was applied to the overall project costs. Finally, with the estimated mid-point of construction in three years (March 2015), an escalation cost due to projected inflation at an annual rate of 4 percent was applied (total inflation for three years equal to 12.5 percent).

Based on the current understanding of the project's criteria and general assumptions made regarding facility locations and configurations, this opinion is intended to provide a feasibility-level overall cost. Costs for Conveyance Scenarios were developed using the sum of costs determined for the highest ranked pipeline alignment option (Pipeline Alignment Option 1), cost determined for the highest ranked pump station/storage reservoir site option (Pump Station/Storage Reservoir Site Option C for the intermediate location and/or Site Option F for the northern location), and cost determined for pump station and storage tank facilities at the SBWRP. Unit costs for pump stations and storage reservoirs were based on historical cost data compiled from multiple similar projects and the experience of RBF and Black & Veatch. This estimate was compiled in March 2012 with an ENR – CCI (Los Angeles) of 10,283.55. Therefore, the costs can be updated once the schedule has been further defined. Table 10-7 summarizes the feasibility-level costs for each conveyance scenario. More detailed cost information for each conveyance scenario is included in Appendix D-3.

July 2012 10-12 Summary Report

Table 10-7 Conveyance Scenario Site Feasibility-Level Cost Estimate

Facility	Scenario 1	Scenario 2	Scenario 3	Scenario 4	Scenario 5	Scenario 6
Pipeline(s)	\$68.1 M	\$68.1 M	\$94.3 M	\$94.3 M	\$91.2 M	\$91.2 M
(Option 1)						
Pump Station/	\$2.5 M	\$26.0 M	\$19.1 M	\$38.1 M	\$2.5 M	\$30.0 M
Storage						
Reservoir						
(Site Option C/F)						
Pump Station/	\$61.2 M	\$44.5 M	\$64.1 M	\$53.0 M	\$61.5 M	\$45.4 M
Storage						
Reservoir						
(at SBWRP)						
TOTAL	\$131.8 M	\$138.6 M	\$177.5 M	\$185.4 M	\$155.2 M	\$166.6 M

### 11.0 CONCLUSION

A comprehensive feasibility-level analysis of conveyance facilities associated with the CWF Project was conducted and is presented in this document. The data herein will be used in the development of the CWF Project EIR/EIS. Multiple conveyance facility options were evaluated including four Pipeline Alignment Options, seven Pump Station/Storage Reservoir Site Options, and six Conveyance Scenarios. Evaluation criteria were developed and scenarios and options were evaluated, weighted, rated, and ranked. The following conclusions were developed:

- Based on the evaluation, any of the four Pipeline Alignment Options would be feasible
  for the CWF Project. There are noted advantages for Alignment Option 1, which ranked
  the highest in the evaluation. Concurrence with the SBCFCD and compliance with their
  requirements will be imperative in further development and selection of Alignment
  Option 1 as the preferred alignment. Preliminary meetings with SBCFCD have
  indicated that pipeline(s) aligned within the SBCFCD Twin Creek Flood Channel would
  be compatible under a license agreement.
- Based on the evaluation, any of the three intermediate sites and any of the four northern sites would be feasible for the CWF Project. There are noted advantages for Pump Station/Storage Reservoir Site Option C for the intermediate location and Site Option F for the northern site location, which both ranked the highest in the evaluation. Coordination with the City's Parks and Recreation Department will be imperative in further development and selection of Site Option C as the preferred intermediate site. Coordination with the SBCFCD is recommended in further development and selection of Site Option F as the preferred northern site.
- Based on the evaluation, any of the six Conveyance Scenarios would be feasible for the CWF Project. There are noted advantages for Conveyance Scenarios 3 and 4, which ranked the highest in the evaluation. Consideration of overall project objectives and cost per acre foot of water make Conveyance Scenarios 3 and 4 attractive even though initial construction costs would be higher than Conveyance Scenarios 1 and 2. There are significant disadvantages for Conveyance Scenarios 5 and 6, and eliminating these scenarios should be considered by SBMWD particularly in the ongoing environmental documentation process.

July 2012 11-1 Summary Report

### **APPENDIX A**



TABLE A-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

SUMMARY OF POTENTIAL DIRECT USE AREAS

Part						Gross	ADD Water								
Configuration   Configuratio					Groundwater Well	Area	<b>Demand Factor</b>	Est. ADD	Est. ADD	Est. MMD	Est. MMD	Est. MDD	Est. MDD	Est. PHD	Est. PHD
Public No	Item No.	ID No.	Area Name	Land Use Type	Present (Yes/No)	(ac)	(AFY/ac)	(AFY)	(mdg)	(AFY)	(mdg)	(AFY)	(mdg)	(AFY)	(mdg)
Public															
Anny Configuration Plank         Public         No.         49         407         139         1399	Areas Prev	viously idei	ntified in the Wildermuth Keport												
Annich Debt Confronte         No         13         2.5         10.01         13         27.13         189         244.3           Ach and confronte         Colf Fourse         No         15         2.5         2.0         13.2         13.9         21.0         2.5         44.0         13         13         21.0         2.5         13.2         13.3         21.0         2.0         45.0         44.0         13         21.0         22.2         13.2         13.2         13.0         23.0         20.0 <td>Н</td> <td>PB-1</td> <td>San Bernardino Water Reclamation Plant</td> <td>Public</td> <td>No</td> <td>49</td> <td>40.51</td> <td>1,998.0</td> <td>1,239</td> <td>2,597.4</td> <td>1,610</td> <td>3,996.0</td> <td>2,477</td> <td>11,988.0</td> <td>7,432</td>	Н	PB-1	San Bernardino Water Reclamation Plant	Public	No	49	40.51	1,998.0	1,239	2,597.4	1,610	3,996.0	2,477	11,988.0	7,432
ansi (-2.219)  Ansaid A	7	GC-1	San Bernardino Public Golf Course	<b>Golf Course</b>	No	93	2.25	209.1	130	271.8	169	418.2	259	1,254.6	778
Mayor Country Cutb         Golf Course         Vis.         110         2.53         153         32.14         139         9444           Abhadred Country Cutb         Park         No         14         183         25.3         155         32.9         20         50           Abhadreot Recreation Park         Park         No         14         181         25.4         15         32.9         20         50         50           Abhadreot Recreation Park         Park         No         31         183         25.4         15         36         37         15         50 </td <td>ĸ</td> <td>CT-1</td> <td>CalTrans (I-215)</td> <td>Cal-Trans</td> <td>No</td> <td>15</td> <td>6.89</td> <td>100.2</td> <td>62</td> <td>130.3</td> <td>81</td> <td>200.4</td> <td>124</td> <td>601.2</td> <td>373</td>	ĸ	CT-1	CalTrans (I-215)	Cal-Trans	No	15	6.89	100.2	62	130.3	81	200.4	124	601.2	373
Open State Matter (1981)         Park (1982)         No.         14         181         25.3         16         32.9         20         50.6         50.6         30.0         30.0         50.0         50.0         50.0         50.0         50.0         50.0         30.0         50.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         50.0         30.0         50.0         30.0         50.0         30.0         50.0         30.0         30.0         50.0         30	4	GC-2	Arrowhead Country Club	Golf Course	Yes	110	2.25	247.2	153	321.4	199	494.4	306	1,483.2	919
Park         No         14         181         254         16         33.0         20         35.0           Jookhooke Recreation Park         Park         No         31         181         256         15         154         10         25         118           Jookhooke Recreation Acea*         Park         No         31         181         56.0         35         126         45         112           Pill Rack         Park         No         6         170         30         35         72         47         115           Pill Rack         Park         No         6         170         30         35         72         47         115         115         35 <t< td=""><td>2</td><td>PK-1</td><td>Mill Community Park</td><td>Park</td><td>No</td><td>14</td><td>1.81</td><td>25.3</td><td>16</td><td>32.9</td><td>20</td><td>50.6</td><td>31</td><td>151.8</td><td>94</td></t<>	2	PK-1	Mill Community Park	Park	No	14	1.81	25.3	16	32.9	20	50.6	31	151.8	94
Ober Design         Park         No         7         180         126         8         164         10         222           Obside Lock Park         No         37         180         516         36         726         46         10         32         1184         56         36         72         36         72         36         1184         46         1184         46         1184         46         1184         46         1184         46         1184         46         1184         36         37         36         1184         36         37         36         1184         36         37         38         37         38         37         38         37         38         37         38         37         38         37         38         38         37         38         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         37         38         38	9	PK-3	Meadowbrook Recreation Park	Park	No	14	1.81	25.4	16	33.0	20	50.8	31	152.4	94
Object         No         31         181         550         35         75         45         113           Object less State Recreation Areas*         Park         No         31         180         550         35         75         47         1118           A HI Park         No         6         170         182         456         57         35         55         35         35         35         31           Avood Park         Park         No         5         170         182         456         175         47         113         35         <	7	PK-4	Meadowbrook Park	Park	No	7	1.80	12.6	8	16.4	10	25.2	16	75.6	47
thill perk         Park         No         32         180         557         36         750         47         1155           tool park         Park         No         32         180         570         6         132         5         115         47         115         80         20           tool park         Park         Yes         24         182         436         27         55         36         27         35         175         35         175         37 </td <td>∞</td> <td>PK-5</td> <td>Secombe Lake State Recreation Area<sup>4</sup></td> <td>Park</td> <td>No</td> <td>31</td> <td>1.81</td> <td>56.0</td> <td>35</td> <td>72.8</td> <td>45</td> <td>112.0</td> <td>69</td> <td>336.0</td> <td>208</td>	∞	PK-5	Secombe Lake State Recreation Area <sup>4</sup>	Park	No	31	1.81	56.0	35	72.8	45	112.0	69	336.0	208
Perk the	6	PK-9	Perris Hill Park	Park	No	32	1.80	57.7	36	75.0	47	115.4	72	346.2	215
Activation         Park New Avenue Median (North of Falt)         Yes         24         182         436         27         567         35         35         178         882         480         27         435         35	10	PK-17	Horine Park	Park	No	9	1.70	10.2	9	13.3	8	20.4	13	61.2	38
variety States         Park No.         No.         5         1.78         8.9         6         11.6         7         17.8         17.8         17.9	11	PK-15	Wildwood Park	Park	Yes	24	1.82	43.6	27	56.7	35	87.2	54	261.6	162
with Sardens         with Gardens         No         15         180         27.0         17         35.1         20         20           with Medical Cornetary         Cemetary         No         26         184         36.7         23         477         30         734           with Medical Cornetary         Cemetary         No         58         180         164         50         214         13         229         239           with Vallew Cornetary         Cemetary         No         5         3.00         164         50         214         13         229           disc Elementary School         School         No         5         2.78         164         10         214         13         229           with School         School         No         14         5.89         81.2         50         10.4         13         22.9           with School         School         No         14         5.89         81.2         5.0         10.4         13         22.9           street         School         No         1         2.38         1.97         4.021         2.4         1.0         2.1         2.4         2.2           stree	12	PK-6	Palm Field Park	Park	No	2	1.78	8.9	9	11.6	7	17.8	11	53.4	33
rendemorial Cernetary         Cemetary         No         20         1.84         36.7         23         47.7         30         734           Tutin Vealer         Cemetary         No         58         1.80         1046         65         136.0         84         2093           Tutin Vealer windle School         School         No         5         3.00         164         10         21.4         13         3.29           die Elementary School         School         No         6         2.78         164         10         21.4         13         3.29           Aublic         School         No         1         5.89         81.2         50         10.5         1.62         3.29           Aublic         School         No         2         2.89         1.91         4.02         2.24         1.62         3.29         1.83         3.29         1.83         3.29	13	N-2	Community Gardens	Nursery	No	15	1.80	27.0	17	35.1	22	54.0	33	162.0	100
train View Cemetery         Crimetery         Connectery         No         58         180         1046         66         136         136         136         104         65         136         136         114         139         2209           Invaled School         School         No         5         3.00         16.4         10         21.4         13         32.9           In Elementary School         School         No         6         2.78         16.4         10         21.4         13         32.9           In Elementary School         School         No         6         2.78         16.4         10         21.4         13         32.9           In Elementary School         School         No         6         2.78         16.4         10         21.4         13         32.9           At Bill School         School         No         22         2         43.2         27         40.3         4.18         4.18           At School         No No         5         2         2         4         4.2         2.2         3         4.6         2.2         3         4.18         4.18         4.18         4.18         4.11         4.1	14	C-1	Pioneer Memorial Cemetery	Cemetary	No	20	1.84	36.7	23	47.7	30	73.4	46	220.2	137
any fulley Middle School School No 16 1.02 16.4 10 21.4 13 32.9 and delegated School School No 6 5.278 16.4 10 21.4 13 32.9 and delegated yellow of 5 3.00 15.4 10 105.6 15.8 12.9 and delegated yellow of 5 3.00 15.4 10 105.6 15.8 12.1 13 32.9 and delegated yellow of 5 3.00 15.4 13 13 32.9 and delegated yellow of 5 3.00 15.4 13 13 32.9 and delegated yellow of 5 2.78 11.9 7 15.5 10 105.6 11.9 7 15.5 10 105.8 and delegated business of the analysis of the analysi	15	C-2	Mountain View Cemetery	Cemetery	No	28	1.80	104.6	9	136.0	84	209.2	130	627.6	389
dide Elementary School         School         No         5         3.00         16.4         10         21.4         13         32.9           nn Elementary School         School         No         6         2.78         16.4         10         21.4         13         3.29           nn Elementary School         School         No         14         5.89         81.2         5.01         10.14         13         3.22           nuck         100         22         2         4.32         2.71         4.021         2.433         6.186           and funcery R Patio Supply         Nursery         No         2         2         4.32         2.7         56.2         35         5.23         6.186           and funcery R Patio Supply         Nursery         No         6         2         11.9         7         1.55         1.0         2.243         6.186           devardine Scapul devaluations         Nursery         No         6         2         11.9         7         1.83         8.23         1.83         8.23         1.13         4.021         2.243         6.186         1.23         1.243         6.186         1.186         1.243         6.186         1.186         <	16	SC-22	Golden Valley Middle School	School	No	16	1.02	16.4	10	21.4	13	32.9	20	98.6	61
n Elementary School         School         No         6         278         164         10         214         13         329           s High School         School         No         6         278         164         10         214         13         329           steptof         School         No         14         5.89         3.993         1,917         4,021         2,493         6,168           steptof         Relation         Culture         No         2         2         43,2         27         56,2         35         183         32,9           d busics         No         5         2         9,1         6         11,9         7         155,2         10         13,3         36,3	17	SC-21	Parkside Elementary School	School	No	2	3.00	16.4	10	21.4	13	32.9	20	98.6	61
stylest School         School         School         14         5.89         81.2         50.93         1,917         4,021         2,493         6.186           ans (1-210)         ans (	18	SC-20	Wilson Elementary School	School	No	9	2.78	16.4	10	21.4	13	32.9	20	98.6	61
stots         534         5,943         1,917         4,021         2,493         1,918         6,188           ans (1-210)         ans (1-210)         Cal-Trans         No         22         2         43.2         27         56.2         35         88.4           and Nursery         Nursery         No         5         2         11.9         7         15.5         10         23.8           and Freels Squeezed Julices         Nursery         No         5         2         9.1         6         11.9         7         18.3         88.4           and Freels Squeezed Julices         Nursery         No         5         2         9.1         6         11.9         7         18.3         88.4         44.1         18.8         19.7         18.3         88.4         44.1         18.3         18.4         44.1         18.3         18.4         44.1         18.3         18.4         44.1         18.3         18.4         44.1         18.3         18.4         44.1         18.3         18.4         44.1         18.3         18.4         44.1         18.3         18.4         18.3         18.4         18.3         18.4         18.4         18.4         18.4	19	SC-9	Sierra High School	School	N <sub>O</sub>	14	5.89	81.2	50	105.6	65	162.5	101	487.4	302
ans (1-210)  Cal-Trans  No 22 2 43.2 27 56.2 35 86.4  In Nursery  No 6 2 11.9 7 15.5 10 23.8  Nursery  No 6 2 11.9 7 15.5 10 23.8  Nursery  No 6 2 11.9 7 15.5 10 23.8  Nursery  No 6 2 2 11.9 7 15.5 10 23.8  Nursery  No 7 3 22.1 14 28.7 18 36.6  Juliary for San Bernardino  Public  No 7 3 22.1 14 28.7 18 44.1  No 12 3 36.0 22 46.8  Public  No 7 3 3 22.1 14 28.7 18 44.1  No 12 3 36.0 22 46.8  Nursery  No 12 3 36.0 22 46.8  Nursery  No 12 3 36.0 22 46.8  Nursery  No 10 2 2 3.1 14 28.7 18 44.1  No 10 2 3 36.0 22 46.8  Nursery  No 10 2 2 11.9 7 18.3  Nursery  No 10 2 2 21.1 14 28.7 18 44.1  No 10 2 2 36.0 22 46.8  No 11 3 36.0 12.3  Nursery  No 11 0 2 2.1 1.9 7 18.3  Nursery  No 11 0 2 2.1 1.9 7 18.3  Nursery  No 11 0 2 2.1 1.9 7 18.3  Nursery  No 11 0 2 2.1 1.9 7 18.3  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 46.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 42.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 42.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 42.1  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 6.2 2.3  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 6.2 2.3  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 6.2 2.3  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 6.2 2.3  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 6.2 2.3  Nursery  Nursery  No 11 0 2 2.3 1.1 14 30.0 19 6.2 2.3  Nursery			Subtotals			534		3,093	1,917	4,021	2,493	6,186	3,835	18,558	11,505
Nursery   Nurs															
CT-2         Caltrans (1-210)         Cal-Trans         No         22         2         43.2         27         56.2         35         86.4           N-1         Leland Nursery & Patio Supply         Nursery         No         6         2         11.9         7         15.5         10         23.8           N-3         Leland Nursery & Patio Supply         Nursery         No         5         2         9.1         6         11.9         7         18.3         23.8           PB-3         Land Mursery & Patio Supply         Public         No         7         3         28.2         17         18.3         35.5         3         35.2         3         28.7         18.3         35.5         3         35.2         3         4.1         4.1         44.1         <	Additional	l Areas Ide	ntified												
N-1         Leland Nursery & Patrio Supply         Nursery         No         6         2         11.9         7         15.5         10         23.8           N-3         Leland Nursery & Patrio Supply         Nursery         No         5         2         9.1         6         11.9         7         18.3           N-3         Lorton's Fresh Squeezed Juices         No         7         3         22.1         14         26.1         3         56.2         2         19.1         7         18.3         35.3         36.2         17.0         18.3         44.1         18.3         44.1         44.1         3         55.2         17.0         18.3         44.1	20	CT-2	Caltrans (I-210)	Cal-Trans	o Z	22	2	43.2	27	56.2	35	86.4	54	259.3	161
N-3         Lortor's Fresh Squeezed Julices         Nursery         No         5         2         9.1         6         11.9         7         18.3           PB-2         San Benardino County Gov Center         Public         No         7         3         28.2         17         36.6         23         56.3           PB-3         Law Library for San Benardino County Gov Center         Public         No         7         3         12.1         14         28.7         18         44.1           PB-3         Law Library for San Benardino County Medical Center Heliport         Public         No         12         3         14.5         9         18.8         17.0         26.1         19         7         26.1         27.1         27.1         46.8         27.1         27.1         46.8         27.1         27.1         46.8         27.1         27.1         46.8         27.1         27.1         46.8         27.2         46.8         27.2         46.8         27.2         46.8         47.1         46.1         47.1         46.1         47.2         47.2         47.2         47.2         47.2         47.2         47.2         47.2         47.2         47.2         47.2         47.2         47.2	21	N-1	Leland Nursery & Patio Supply	Nurserv	0 Z	9	2	11.9	7	15.5	10	23.8	15	71.4	44
PB-2         San Benardino County Gov Center         Public         No         7         3         28.2         17         36.6         28.3         44.1           PB-3         Law Library for San Bernardino         Public         No         7         3         22.1         14         28.7         18         44.1           PB-3         Law Library for San Bernardino         Public         No         7         3         13.0         8         17.0         11         26.1         26.1         12.0         12.0         26.1         12.0         26.1         26.1         26.2         12.0         26.1         26.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2         27.2 <td< td=""><td>22</td><td>N-3</td><td>Lorton's Fresh Squeezed Juices</td><td>Nursery</td><td>No</td><td>Ŋ</td><td>7</td><td>9.1</td><td>9</td><td>11.9</td><td>7</td><td>18.3</td><td>11</td><td>54.9</td><td>34</td></td<>	22	N-3	Lorton's Fresh Squeezed Juices	Nursery	No	Ŋ	7	9.1	9	11.9	7	18.3	11	54.9	34
PB-3         Law Library for San Bernardino         Public         No         4         3         22.1         14         28.7         18         44.1           PB-4         California Theater         Public         No         4         3         13.0         8         17.0         11         26.1           PB-5         Norman Feldhewm Public Library         Public         No         12         3         14.5         9         18.8         12         26.1           PB-6         San Bernardino County Medical Center Heliport         Public         No         1         2         36.0         22         46.8         29         71.9         7         20.0         12         36.0         12         36.0         14.3         46.3	23	PB-2	San Benardino County Gov Center	Public	No	6	3	28.2	17	36.6	23	56.3	35	168.9	105
PB-4         California Theater         Public         No         4         3         13.0         8         17.0         11         26.1           PB-5         Norman F editheym Public Library         Public         No         1         3         14.5         9         18.8         12         29.0           PB-5         San Bernardino County Medical Center Heliport         Public         No         1         2         4         9         46.8         29         71.9           PB-7         Mountain View Avenue Median (South of I-210)         Park         No         6         2         11.9         7         4         9         3.9         14.3         14.0         14.3         14.3         14.3         14.3         14.3         14.3         14.3         14.5         14.3         14.5<	24	PB-3	Law Library for San Bernardino	Public	No	7	3	22.1	14	28.7	18	44.1	27	132.3	82
PB-5         Norman F Feldheym Public Library         Public         No         5         3         14.5         9         18.8         12         29.0           PB-6         San Bernardino County Medical Center Heliport         Public         No         4         2         7.2         4         9.3         6         7.1.9           PB-7         Mountain View Avenue Medical County Medical County Medical County Medical County Medical (Suth of I-210)         Park         No         6         2         11.9         7         4.5         9.3         6         14.3           PB-8         Mountain View Avenue Median (North of I-210)         Park         No         6         2         11.9         7         15.5         10         23.8           PR-8         Mountain View Avenue Median (North of I-210)         Park         No         1         2         2         14.5         10         23.8           PR-8         Municipal Baseball Park         Park         No         1         2         2         14.5         30.0         19         46.0         40.9           PR-10         Community Park         Park         No         1         2         2.3         1         4.5         4.5         4.5         4.5	25	PB-4	California Theater	Public	No	4	3	13.0	∞	17.0	11	26.1	16	78.3	49
PB-6         San Bernardino County Medical Center Heliport         Public         No         12         3         36.0         22         46.8         29         71.3           PB-7         Mountain View Avenue Median (South of I-210)         Park         No         4         2         7.2         4         9.3         6         14.3           PB-7         Mountain View Avenue Median (North of I-210)         Park         No         10         2         11.9         7         15.5         10         23.8           PR-2         Municipal Baseball Park         No         10         2         20.4         13         26.6         16         40.9           PK-2         Municipal Baseball Park         No         1         2         20.4         13         26.6         16         40.9           PK-7         Residential Community Park         Park         No         1         2         2.6         45         46.1	56	PB-5	Norman F Feldheym Public Library	Public	No	2	3	14.5	6	18.8	12	29.0	18	86.9	54
PB-7         Mountain View Avenue Median (South of I-210)         Park         No         4         2         7.2         4         9.3         6         14.3           PB-8         Mountain View Avenue Median (North of I-210)         Park         No         6         2         11.9         7         15.5         10         23.8           PK-2         Municipal Baseball Park         No         10         2         20.4         13         26.6         16         40.9           PK-2         Municipal Baseball Park         No         12         2         72.6         45         94.3         58         145.1           PK-3         Residential Community         Park         No         1         2         2.6         45         94.3         58         145.1           PK-4         Residential Community Park         Park         No         1         2         2.6         45         94.3         58         145.1           PK-1         Skierra Park         No         1         2         2.3         1         4.5         14.7         9         15.0         9         15.0           PK-1         Harrison Canyon Park         Park         No         1         2 </td <td>27</td> <td>PB-6</td> <td>San Bernardino County Medical Center Heliport</td> <td>Public</td> <td>No</td> <td>12</td> <td>c</td> <td>36.0</td> <td>22</td> <td>46.8</td> <td>29</td> <td>71.9</td> <td>45</td> <td>215.8</td> <td>134</td>	27	PB-6	San Bernardino County Medical Center Heliport	Public	No	12	c	36.0	22	46.8	29	71.9	45	215.8	134
PB-8 Mountain View Avenue Median (North of I-210)         Park No         No         6         2         11.9         7         15.5         10         23.8           PK-2 Municipal Baseball Park Pk-2 Municipal Baseball Park No IV-2 Municipal Baseball Park Pk-1         No         10         2         20.4         13         26.6         16         40.9           PK-7 Residential Community Park Pk-10 Community Park Pk-11 St Sierra Park Pk-11 St Sierra Park No IV-12 Pk-12 St Sierra Park No IV-13 Pk-14 Pk-15 Park No IV-14 Pk-15 Pk-15 Pk-15 Pk-15 Pk-15 Pk-16 Park No IV-14 Pk-15 Pk-16 Park No IV-15 Pk-16 Pk-17 Pk-17 Pk-17 Pk-17 Pk-17 Pk-17 Pk-18 Park No IV-14 Pk-18 Park No IV-15 Pk-18 Park No IV-15 Pk-18 Park No IV-16 Pk-18 Pk-19 Pk-	28	PB-7	Mountain View Avenue Median (South of I-210)	Park	No	4	2	7.2	4	9.3	9	14.3	6	42.9	27
PK-2         Municipal Baseball Park         No         10         2         20.4         13         26.6         16         40.9           PK-7         Residential Community         Park         No         12         2         72.6         45         94.3         58         145.1           PK-8         Fiscalini Field         Park         No         1         2         2.6         2         3.4         2         5.2           PK-10         Community Park         No         1         2         2.6         2         3.4         2         5.2           PK-11         St Sierra Park         No         1         2         2.3         1         2.9         2         4.5           PK-12         Harrison Canyon Park         No         6         2         11.3         7         14.7         9         22.5           PK-13         Harrison Canyon Park         No         6         2         11.5         7         15.0         9         23.0           PK-14         Hampshire Floodway Park         No         1         2         8.3         5         10.8         7         16.6           PK-16         Community Park         No </td <td>29</td> <td>PB-8</td> <td>Mountain View Avenue Median (North of I-210)</td> <td>Park</td> <td>No</td> <td>9</td> <td>2</td> <td>11.9</td> <td>7</td> <td>15.5</td> <td>10</td> <td>23.8</td> <td>15</td> <td>71.5</td> <td>44</td>	29	PB-8	Mountain View Avenue Median (North of I-210)	Park	No	9	2	11.9	7	15.5	10	23.8	15	71.5	44
PK-7         Residential Community         Park         No         12         2         72.6         45         94.3         58         145.1           PK-8         Fiscalini Field         Park         No         1         2         2.6         2         3.4         2         5.2           PK-10         Community Park         No         1         2         2.6         2         3.4         2         5.2           PK-11         St Sierra Park         No         6         2         1.3         7         14.7         9         22.5           PK-12         Harrison Canyon Park         No         6         2         11.5         7         15.0         9         23.0           PK-13         Harrison Canyon Park         No         4         2         8.3         5         10.8         7         16.6           PK-14         Hampshire Floodway Park         No         1         2         2.6         2         10.8         7         16.6           PK-14         Hampshire Floodway Park         No         1         2         2         3.3         2         3.3         2         3.3         3         3         3         3	30	PK-2	Municipal Baseball Park	Park	N <sub>O</sub>	10	2	20.4	13	26.6	16	40.9	25	122.6	92
PK-8         Fiscalini Field         Park         No         12         2         23.1         14         30.0         19         46.1           PK-10         Community Park         No         1         2         2.6         2         3.4         2         5.2           PK-11         St Sierra Park         No         6         2         11.3         7         14.7         9         22.5           PK-12         Harper Field         Park         No         6         2         11.3         7         14.7         9         23.0           PK-13         Harrison Canyon Park         No         6         2         11.5         7         15.0         9         23.0           PK-14         Hampshire Floodway Park         No         4         2         8.3         5         10.8         7         16.6           PK-16         Community Park         No         1         2         2.6         2         3.3         2         5.1	31	PK-7	Residential Community	Park	No	36	2	72.6	45	94.3	58	145.1	06	435.4	270
PK-10 Community Park         No         1         2         2.6         2         3.4         2         5.2           PK-11 St Sierra Park         No         1         2         2.3         1         2.9         2         4.5           PK-12 Harper Field         Park         No         6         2         11.3         7         15.0         9         23.0           PK-13 Harrison Canyon Park         Park         No         4         2         8.3         5         10.8         7         16.6           PK-14 Hampshire Floodway Park         Park         No         1         2         8.3         5         10.8         7         16.6           PK-16 Community Park         No         1         2         2.6         2         3.3         2         5.1	32	PK-8	Fiscalini Field	Park	No	12	2	23.1	14	30.0	19	46.1	29	138.4	98
PK-11       St Sierra Park       No       1       2       3       1       2.9       2       4.5         PK-12       Harper Field       No       6       2       11.3       7       14.7       9       22.5         PK-13       Harrison Canyon Park       No       6       2       11.5       7       15.0       9       23.0         PK-14       Hampshire Floodway Park       No       4       2       8.3       5       10.8       7       16.6         PK-16       Community Park       No       1       2       3.3       2       5.1	33	PK-10	Community Park	Park	No	1	2	2.6	2	3.4	2	5.2	3	15.6	10
PK-12 Harper Field       Park       No       6       2       11.3       7       14.7       9       22.5         PK-13 Harrison Canyon Park       No       6       2       11.5       7       15.0       9       23.0         PK-14 Hampshire Floodway Park       Park       No       4       2       8.3       5       10.8       7       16.6         PK-16 Community Park       Park       No       1       2       3.3       2       5.1	34	PK-11	St Sierra Park	Park	No	1	2	2.3	1	2.9	2	4.5	3	13.5	8
PK-13 Harrison Canyon Park       No       6       2       11.5       7       15.0       9       23.0         PK-14 Hampshire Floodway Park       No       4       2       8.3       5       10.8       7       16.6         PK-16 Community Park       No       1       2       2       3.3       2       5.1	35	PK-12	Harper Field	Park	No	9	2	11.3	7	14.7	6	22.5	14	9.79	42
PK-14 Hampshire Floodway Park No 4 2 8.3 5 10.8 7 16.6 PK-16 Community Park No 1 2 2.6 2 3.3 2 5.1	36	PK-13	Harrison Canyon Park	Park	No	9	2	11.5	7	15.0	6	23.0	14	69.1	43
PK-16 Community Park No 1 2.6 2 3.3 2 5.1	37	PK-14	Hampshire Floodway Park	Park	No	4	2	8.3	Ŋ	10.8	7	16.6	10	49.8	31
	38	PK-16	Community Park	Park	No	1	2	2.6	2	3.3	2	5.1	3	15.4	10

TABLE A-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

SUMMARY OF POTENTIAL DIRECT USE AREAS

					Gross	ADD Water								
Item No.	ID No.	Area Name Lar	Land Use Type	Groundwater Well Present (Yes/No)	Area (ac)	Demand Factor (AFY/ac)	Est. ADD (AFY)	Est. ADD (gpm)	Est. MMD (AFY)	Est. MMD (gpm)	Est. MDD (AFY)	Est. MDD (gpm)	Est. PHD (AFY)	Est. PHD (gpm)
Additional Areas Identified	l Areas Ide	entified												
39	SC-1	Norton Space Academy	School	ON N	4	4	15.8	10	20.6	13	31.7	20	95.0	59
40	SC-2	Burbank Elementary	School	No	8	4	31.1	19	40.4	25	62.1	39	186.4	116
41	SC-3	Residential	School	No	33	4	11.3	7	14.6	6	22.5	14	9.79	42
42	SC-4	Conrand MS and Harding School	School	No	4	4	16.3	10	21.2	13	32.7	20	0.86	61
43	SC-5	Juanita Blakely Jones Elementary	School	No	18	4	73.3	45	95.3	59	146.6	91	439.8	273
44	9- <b>3</b> S	Anderson Elementary	School	No	4	4	17.9	11	23.2	14	35.8	22	107.3	99
45	SC-7	Center for Individual Development	School	No	7	4	26.6	17	34.6	21	53.3	33	159.9	66
46	SC-8	Monterey Elementary	School	No	9	4	25.4	16	33.0	20	50.7	31	152.2	94
47	SC-10	E Neal Roberts Elementary	School	No	9	4	25.4	16	33.0	20	50.8	31	152.4	94
48	SC-11	School	School	No	17	4	9.89	43	89.2	55	137.2	85	411.7	255
46	SC-12	Curtis Middle School	School	No	27	4	108.6	29	141.2	88	217.3	135	651.8	404
20	SC-13	Bradley Elementary	School	No	10	4	39.5	24	51.3	32	79.0	49	237.0	147
51	SC-14	Lincoln School	School	No	6	4	35.6	22	46.3	29	71.2	44	213.7	132
52	SC-15	Riley School	School	No	<b>∞</b>	4	32.7	20	42.5	26	65.4	41	196.3	122
23	SC-16	Pacific High School	School	No	49	4	197.8	123	257.1	159	395.6	245	1,186.7	736
54	SC-17	San Bernardino High School	School	No	36	4	144.8	06	188.2	117	289.6	180	868.7	539
22	SC-18	Arrowview Middle School	School	No	18	4	71.2	44	92.6	57	142.4	88	427.2	265
26	SC-19	School	School	No	7	4	28.5	18	37.0	23	56.9	35	170.8	106
22	SC-23	Arrowhead Elementary	School	No	2	4	19.6	12	25.4	16	39.1	24	117.4	73
28	SC-24	Hillside Elementary	School	No	∞	4	33.5	21	43.6	27	67.0	42	201.0	125
29	SC-25	Our Lady of the Assumption Catholic School	School	No	2	4	20.9	13	27.2	17	41.9	26	125.7	78
09	SC-26	North Park Elementary	School	No	6	4	36.7	23	47.7	30	73.5	46	220.4	137
		Subtotals			427		1,433	888	1,863	1,155	2,866	1,776	8,597	5,329
		Grand Totals			961		4,526	2,806	5,884	3,647	9,052	5,611	27,155	16,834

<sup>1:</sup> Max Month Demand = Average Day Demand x 1.3

<sup>2:</sup> Max Day Demand = Average Day Demand x 2.0 3: Peak Hour Demand = Max Day Demand x 3.0 (8-hour Irrigation Period) 4: May not include lake make-up water.

H:\pdata\65100826\Reports\Conveyance Calcs\Prelim-Alt\_2012-07-12.xlsx

# Table A-2 City of San Bernardino MWD Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analsyis

### Conveyance Scenario Pipeline Length Summary

					Alignmer	Alignment Option	
Conveyance	Pipeline						
Scenario	Segment	Description	Туре	1	2	3	4
1	Pipeline 1-1	SBWRP to Recharge Basins	Advanced	39,280	42,900	42,740	82,180
2	Pipeline 2-1	SBWRP to Intermediate Tank/Pump Station	Advanced	24,700	28,200	26,100	52,900
	Pipeline 2-2	Intermediate Tank/Pump Station to Recharge Basins	Advanced	14,600	14,700	16,600	29,300
				39,300	42,900	42,700	82,200
3	Pipeline 3-1	SBWRP to Intermediate Tank/Pump Station	Recycled	36,000	38,800	36,700	38,800
	Pipeline 3-2	Intermediate Tank/Pump Station to Recharge Basins	Recycled	3,300	4,200	000'9	4,200
	Pipeline 3-3	SBWRP to Recharge Basins	Advanced	39,280	42,900	42,740	39,280
				78,580	006'58	85,440	82,280
4	Pipeline 4-1	SBWRP to Intermediate Tank/Pump Station	Recycled	36,000	38,800	36,700	38,800
	Pipeline 4-2	Intermediate Tank/Pump Station to Recharge Basins	Recycled	3,300	4,200	000'9	4,200
	Pipeline 4-3	SBWRP to Intermediate Tank/Pump Station	Advanced	24,700	28,200	26,100	24,700
	Pipeline 4-4	Intermediate Tank/Pump Station to Recharge Basins	Advanced	14,600	14,700	16,600	14,600
				78,600	006′58	85,400	82,300
5	Pipeline 5-1	SBWRP to Recharge Basins	Recycled	39,280	42,900	42,740	N/A
	Pipeline 5-2	Recharge Basins to SBWRP	Brine	39,280	42,900	42,740	N/A
				78,560	008'58	85,480	N/A
9	Pipeline 6-1	SBWRP to Intermediate Tank/Pump Station	Recycled	24,700	28,200	26,100	N/A
	Pipeline 6-2	Intermediate Tank/Pump Station to Recharge Basins	Recycled	14,600	14,700	16,600	N/A
	Pipeline 6-3	Recharge Basins to SBWRP	Brine	39,280	42,900	42,740	N/A
				78,580	85,800	85,440	



### **APPENDIX B**



### City of San Bernardino MWD Recycled Water Conveyance System Alternatives Engineering Study Preliminary Hydraulic Analysis

Hazen-Williams

Coefficient, C 130

### ADVANCED WATER

Alternative	Α	lternative	1	Al	ternative	2	Al	ternative	3	Al	ternative	4
Alignment	1	2	3	1	2	3	1	2	3	1	2	3
Flow, Q (mgd)	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2
Pipe Diameter, D (in)	30	30	30	30	30	30	30	30	30	30	30	30
Pipe Length, L (ft)												
Segment 1	39,280	42,900	42,740	24,730	28,170	26,130	38,500	42,900	42,740	24,730	28,170	26,130
Segment 2	0	0	0	14,550	14,730	16,610	0	0	0	14,550	14,730	16,610
Velocity, V (fps)	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
Area, A (sf)	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91	4.91
Wetted Perimeter, (ft)	7.85	7.85	7.85	7.85	7.85	7.85	7.85	7.85	7.85	7.85	7.85	7.85
Hydraulic Radius, (ft)	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63
Friction Headloss (ft)												
Segment 1 (ft)	79.92	87.29	86.96	50.32	57.32	53.17	78.34	87.29	86.96	50.32	57.32	53.17
Segment 2 (ft)	0.00	0.00	0.00	29.61	29.97	33.80	0.00	0.00	0.00	29.61	29.97	33.80
Minor Headloss (ft)												
Segment 1 (ft)	10.00	10.00	10.00	6.00	6.00	6.00	10.00	10.00	10.00	6.00	6.00	6.00
Segment 2 (ft)	0.00	0.00	0.00	4.00	4.00	4.00	0.00	0.00	0.00	4.00	4.00	4.00
Total Headloss (ft)	89.92	97.29	96.96	89.92	97.29	96.96	88.34	97.29	96.96	89.92	97.29	96.96
SBWRF Elev (ft)	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000
Intermediate PS/Tank Elev (ft)				1165	1165	1165				1165	1165	1165
Recharge Basin Elev (ft)	1470	1470	1470	1470	1470	1470	1470	1470	1470	1470	1470	1470
Max. HGL												
Segment 1 (ft)	559.92	567.29	566.96	221.32	228.32	224.17	558.34	567.29	566.96	221.32	228.32	224.17
Segment 1 (psi)	242.39	245.58	245.44	95.81	98.84	97.04	241.70	245.58	245.44	95.81	98.84	97.04
Segment 2 (ft)				338.61	338.97	342.80				338.61	338.97	342.80
Segment 2 (psi)				146.58	146.74	148.40				146.58	146.74	148.40

### City of San Bernardino MWD Recycled Water Conveyance System Alternatives Engineering Study Preliminary Hydraulic Analysis

Hazen-Williams

Coefficient, C 130

### RECYCLED WATER

Alternative	٨١	ternative	3	ΛΙ	ternative	. 4	ΛΙ	ternative	. 5	٨١	ternative	6
Alignment	1	2	3	1	2	3	1	2	3	1	2	3
Flow, Q (mgd)	1		3	1		J	1		J	1		3
Segment 1	7.0	7.0	7.0	7.0	7.0	7.0	25.2	25.2	25.2	25.2	25.2	25.2
Segment 2	5.0	5.0	5.0	5.0	5.0	5.0	23.2	25.2	25.2	25.2	25.2	25.2
Pipe Diameter, D (in)	3.0	3.0	5.0	3.0	5.0	5.0				23.2	23.2	23.2
Segment 1	20	20	20	20	20	20	36	36	36	36	36	36
Segment 2	16	16	16	16	16	16	30	30	30	36	36	36
Pipe Length, L (ft)	10	10	10	10	10	10				30	30	30
Segment 1	36,020	38,750	36,700	36,020	38,750	36,700	39,280	42,900	42,740	24,730	28,170	26,130
Segment 2	3,260	4,150	6,040	3,260	4,150	6,040	0	0	0	14,550	14,730	
Velocity, V (fps)	3,200	1,130	0,010	3,200	1,130	0,010		- O	- O	11,550	11,730	10,010
Segment 1	5.0	5.0	5.0	5.0	5.0	5.0	5.5	5.5	5.5	5.5	5.5	5.5
Segment 2	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5
Area, A (sf)	0.0			0.0								
Segment 1	2.18	2.18	2.18	2.18	2.18	2.18	7.07	7.07	7.07	7.07	7.07	7.07
Segment 2	1.40	1.40	1.40	1.40	1.40	1.40				7.07	7.07	7.07
Wetted Perimeter, (ft)												
Segment 1	5.24	5.24	5.24	5.24	5.24	5.24	9.42	9.42	9.42	9.42	9.42	9.42
Segment 2	4.19	4.19	4.19	4.19	4.19	4.19				9.42	9.42	9.42
Hydraulic Radius, (ft)												
Segment 1	0.42	0.42	0.42	0.42	0.42	0.42	0.75	0.75	0.75	0.75	0.75	0.75
Segment 2	0.33	0.33	0.33	0.33	0.33	0.33				0.75	0.75	0.75
Friction Headloss (ft)												
Segment 1	142.66	153.48	145.36	142.66	153.48	145.36	95.04	103.80	103.42	59.84	68.16	63.23
Segment 2	20.54	26.15	38.06	20.54	26.15	38.06				35.21	35.64	40.19
Minor Headloss (ft)												
Segment 1	9.00	9.00	9.00	9.00	9.00	9.00	10.00	10.00	10.00	6.00	6.00	6.00
Segment 2	1.00	1.00	1.00	1.00	1.00	1.00	0.00	0.00	0.00	4.00	4.00	4.00
Total Headloss (ft)	173.20	189.62	193.41	173.20	189.62	193.41	105.04	113.80	113.42	105.04	113.80	113.42
SBWRF Elev (ft)	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000
Intermediate PS/Tank Elev (ft)	1350	1350	1350	1350	1350	1350		-		1165	1165	1165
Recharge Basin Elev (ft)	1470	1470	1470	1470	1470	1470	1470	1470	1470	1470	1470	1470
Max. HGL												
Segment 1 (ft)	501.66	512.48	504.36	501.66	512.48	504.36	575.04	583.80	583.42	230.84	239.16	234.23
Segment 1 (psi)	217.17	221.85	218.34	217.17	221.85	218.34	248.94	252.73	252.56	99.93	103.53	101.40
Segment 2 (ft)	141.54	147.15	159.06	141.54	147.15	159.06				344.21	344.64	349.19
Segment 2 (psi)	61.27	63.70	68.86	61.27	63.70	68.86				149.01	149.20	151.16

### City of San Bernardino MWD Recycled Water Conveyance System Alternatives Engineering Study Preliminary Hydraulic Analysis

Hazen-Williams

Coefficient, C 130

### BRINE

DRINE						
Alternative	Al	lternative	5	Al	ternative	6
Alignment	1	2	3	1	2	3
Flow, Q (mgd)	2.5	2.5	2.5	2.5	2.5	2.5
Pipe Diameter, D (in)	12	12	12	12	12	12
Pipe Length, L (ft)						
Segment 1	39,280	42,900	42,740	39,280	42,900	42,740
Segment 2	0	0	0	0	0	0
Velocity, V (fps)	4.9	4.9	4.9	4.9	4.9	4.9
Area, A (sf)	0.79	0.79	0.79	0.79	0.79	0.79
Wetted Perimeter, (ft)	3.14	3.14	3.14	3.14	3.14	3.14
Hydraulic Radius, (ft)	0.25	0.25	0.25	0.25	0.25	0.25
Friction Headloss (ft)						
Segment 1 (ft)	278.68	304.36	303.23	278.68	304.36	303.23
Segment 2 (ft)	0.00	0.00	0.00	0.00	0.00	0.00
Minor Headloss (ft)						
Segment 1 (ft)	10.00	10.00	10.00	10.00	10.00	10.00
Segment 2 (ft)	0.00	0.00	0.00	0.00	0.00	0.00
Total Headloss (ft)	288.68	314.36	313.23	288.68	314.36	313.23
SBWRF Elev (ft)	1000	1000	1000	1000	1000	1000
Intermediate PS/Tank Elev (ft)						
Recharge Basin Elev (ft)	1470	1470	1470	1470	1470	1470
Max. HGL (Gravity Line)						
Segment 1 (ft) (Available)	181.32	155.64	156.77	181.32	155.64	156.77
Segment 1 (psi) (Available)	78.49	67.38	67.87	78.49	67.38	67.87
Segment 2 (ft)						_
Segment 2 (psi)				•		



### **APPENDIX C**



Table C-1
City of San Bernardino MWD
Clean Water Factory Project
Recycled/Advanced Water Conveyance System Engineering Study

# SUMMARY OF RESERVOIR SITE LAND ACQUISITION REQUIRMENTS

							Minimu	Minimum Reservoir (only)	(only)
	Reservoir			Res	Reservoir Site Criteria	eria	Sit	Site Dimensions	S
				Volume	Height [1]	Diameter, D	06 + Q	D + 70	
Item	No.	Operation	Location	(MG)	(ft)	(ft)	(ft)	(ft)	(Ac)
1	1-1	Recycled - Dist./Forebay	SBWRP	4.2	30	155	245	225	1.3
2	1-2	Advanced - Forebay	SBWRP	3.2	30	135	225	202	1.1
33	1-3	Advanced - Distribution	Intermediate Site	0.8	20	83	173	153	9.0
4	2-1	Recycled - Dist./Forebay	SBWRP	4.2	30	155	245	225	1.3
2	2-2	Advanced - Forebay	SBWRP	1.6	20	117	207	187	6.0
9	2-3	Advanced - Dist./Forebay	Intermediate Site	2.4	30	117	207	187	6.0
7	3-1	Recycled - Dist./Forebay	SBWRP	4.3	30	157	247	227	1.3
<b>∞</b>	3-2	Advanced - Forebay	SBWRP	0.2	10	59	149	129	0.4
6	3-3	Recycled - Dist./Forebay	Northern Site	4.0	30	151	241	221	1.2
10	4-1	Recycled - Dist./Forebay	SBWRP	4.3	30	157	247	227	1.3
11	4-2	Advanced - Forebay	SBWRP	0.2	10	59	149	129	0.4
12	4-3	Recycled - Dist./Forebay	Northern Site	4.0	30	151	241	221	1.2
13	4-4	Advanced - Forebay	Intermediate Site	0.2	10	59	149	129	0.4
14	5-1	Recycled - Dist./Forebay	SBWRP	7.4	40	178	268	248	1.5
15	2-5	Recycled - Distribution	Intermediate Site	0.8	20	83	173	153	9.0
16	6-1	Recycled - Dist./Forebay	SBWRP	5.8	40	158	248	228	1.3
17	6-2	Recycled - Dist./Forebay	Intermediate Site	2.4	30	117	207	187	0.9

= Intermediate/Northern Sites

Table C-2 City of San Bernardino MWD Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Study

## SUMMARY OF PUMP STATION SITE LAND ACQUISITION REQUIRMENTS

Pu	Pump Station	Q			Samn	Pump Station Site Criteria	teria		Minimum	Minimum Pump Station (only) Site Dimensions	on (only)
					Pumps				L + 95	W + 95	
Item	No.	Operation	Location	Number	Size (gpm)	Size (HP)	Length (ft) [1]	Width (ft) [1]	<b>E</b>	<b>£</b>	(Ac)
1	1-1	Recycled - Distribution	SBWRP	3	4,400	250	55	20	150	115	0.4
2	1-2	Advanced - Transmission	SBWRP	4	3,300	009	95	28	190	123	0.5
3	2-1	Recycled - Distribution	SBWRP	3	4,400	250	55	20	150	115	0.4
4	2-2	Advanced - Transmission	SBWRP	4	3,300	250	65	20	160	115	0.4
2	2-3	Advanced - Transmission	Intermediate Site	4	3,300	400	80	24	175	119	0.5
9	3-1	Recycled - Dist./Trans.	SBWRP	3+3*	4,400 + 2,500	250 + 450	89	44	163	139	0.5
7	3-2	Advanced - Transmission	SBWRP	4	3,300	009	95	28	190	123	0.5
∞	3-3	Recycled - Dist./Trans.	Northern Site	က	1,750	100	42	16	137	111	0.3
6	4-1	Recycled - Dist./Forebay	SBWRP	3+3*	4,400 + 2,500	250 + 450	89	44	163	139	0.5
10	4-2	Advanced - Transmission	SBWRP	4	3,300	250	65	20	160	115	0.4
11	4-3	Recycled - Dist./Trans.	Northern Site	က	1,750	100	42	16	137	111	0.3
12	4-4	Advanced - Transmission	Intermediate Site	4	3,300	400	80	24	175	119	0.5
13	5-1	Recycled - Dist./Trans.	SBWRP	3+4*	4,400 + 5,830	250 + 1000	95	48	190	143	9.0
14	6-1	Recycled - Dist./Trans.	SBWRP	3 + 4 *	4,400 + 5,830	250 + 450	80	44	175	139	9.0
15	6-2	Recycled - Dist./Trans.	Intermediate Site	4	5,830	009	95	28	190	123	0.5

	Equip Space	and number pumps Spacing Size Add to Length	Small Pump Station (ft) = $8$ 0 to 100 HP 10	Medium Pump Station (ft) = 10 150 to 250 HP 15	Large Pump Station (ft) = 12 300 to 550 HP 20	Very Large Pump Station (ft) = 14 600 to 1000 HP 25
= Intermediate/Northern Sites		[1] Length and width determined by size and number pumps	S	Med		Very L

<sup>\*</sup>For combined pumps, use larger size and total number of pumps for length sizing criteria and add width.

City of San Bernardino MWD Table C-3

Recycled/Advanced Water Conveyance System Engineering Study Clean Water Factory Project

# SUMMARY OF COMBINED PUMP STATION + RESERVOIR SITE LAND ACQUISITION REQUIRMENTS

			Note							For W, use PS L +95			For W, use PS L +95		For W, use PS L +95			
		Multiple	Combined	No	No	No	No	No	No	No								
d Site	ons		(Ac)	1.5	1.3	1.5	1.1	1.1	1.7	0.7	1.5	1.7	0.7	1.5	0.7	2.0	1.7	1.1
Minimum Combined Site	(Alt. B) Dimensions	Dia +70	W (ft)	225	205	225	187	187	227	154	221	227	154	221	154	248	228	187
Mini	(A	Dia+W+120	r (#)	295	283	295	257	261	321	207	287	321	199	287	203	346	322	265
ned Site	sions		(Ac)	1.7	1.6	1.7	1.3	1.3	1.7	0.8	1.5	1.7	0.7	1.5	0.7	2.2	1.8	1.4
Minimum Combined Site	(Alt. A) Dimensions	) Dia + 70	W (ft)	225	205	225	187	187	227	129	221	227	129	221	129	248	228	187
Mir	)	Dia+L+110	z] L (ft)	320	340	320	292	307	335	264	303	335	234	303	249	383	348	322
			Width (ft) [2]	20	28	20	20	24	44	28	16	44	20	16	24	48	44	28
	eria		Length (ft) [2]	22	95	55	65	80	89	95	42	89	65	42	80	95	80	95
	<b>Pump Station Site Criteria</b>		Size (HP)	250	009	250	250	400	250 + 450	009	100	250 + 450	250	100	400	250 + 1000	250 + 450	600
	Pump St	Pumps	Size (gpm)	4,400	3,300	4,400	3,300	3,300	4,400 + 2,500	3,300	1,750	4,400 + 2,500	3,300	1,750	3,300	4,400 + 5,830	4,400 + 5,830	5,830
			Number	3	4	3	4	4	3+3*	4	3	3+3*	4	c	4	3+4*	3 + 4 *	4
	ria	Diameter, D	( <del>L</del> )	155	135	155	117	117	157	59	151	157	59	151	59	178	158	117
	<b>Reservoir Site Criteria</b>	Height [1]	£)	30	30	30	20	30	30	10	30	30	10	30	10	40	40	30
	Res	Volume	(MG)	4.2	3.2	4.2	1.6	2.4	4.3	0.2	4.0	4.3	0.2	4.0	0.2	7.4	5.8	2.4
			Location	SBWRP	SBWRP	SBWRP	SBWRP	Intermediate Site	SBWRP	SBWRP	Northern Site	SBWRP	SBWRP	Northern Site	Intermediate Site	SBWRP	SBWRP	Intermediate Site
	ervoir		Operation	Recycled - Distribution	Advanced - Transmission	Recycled - Distribution	Advanced - Transmission	Advanced - Transmission	Recycled - Dist./Trans.	Advanced - Transmission	Recycled - Dist./Trans.	Recycled - Dist./Forebay	Advanced - Transmission	Recycled - Dist./Trans.	Advanced - Transmission	Recycled - Dist./Trans.	Recycled - Dist./Trans.	Recycled - Dist./Trans.
	Pump Station & Reservoir	<b>Pump Station</b>	No.	1-1	1-2	2-1	2-2	2-3	3-1	3-2	3-3	4-1	4-2	4-3	4-4	5-1	6-1	6-2
	Pump	Reservoir F	No.	1-1	1-2	2-1	2-2	2-3	3-1	3-2	3-3	4-1	4-2	4-3	4-4	5-1	6-1	6-2
		ď	Item	1	2	3	4	2	9	7	∞	6	10	11	12	13	14	15

[2] Sizing Spacing Size Add to Length
Small PS (ft) = 8 0 to 100 HP 10

Medium PS (ft) = 10 150 to 250 HP 15

Large PS (ft) = 12 300 to 550 HP 20

Very Large PS (ft) = 14 600 to 1000 HP 25

\*For combined pumps, use larger size and total number of pumps for length sizing criteria and add width. Size 0 to 0.2 MG 0.3 to 2.0 MG 2.1 to 4.5 MG 4.6 to 8.0 MG Height 10 20 30 40 [1] Height = height of water column. Freeboard is excluded.
 SmallReservoir Water Column (ft) =
 Medium Reservoir Water Column (ft) =
 Large Reservoir Water Column (ft) =
 Very Large Reservoir Water Column (ft) = = Intermediate/Northern Sites

Elect Space Add to Length

## ACTUAL COMBINED SITES COMBINATIONS - INTERMEDIATE Location of Intermediate Sites = approximately at Highland Ave

						Most Likely	Largest
		Screen	Out	×	×	×	×
a			(Ac)		1.1	0.7	1.1
linimum Combined Site	ы инпензионя	Dia +70	w (ft)		187	154	187
Minimu (Alt	(AIL.	Dia+W+120	r (ft)		261	203	265
<b>v</b>			(Ac)		1.3	0.7	1.4
inimum Combined Site	A) DIMENSIONS	Dia + 70	W (ft)		187	129	187
Minim	(AIL)	Dia+L+110	L (ft)		307	249	322
			(Ac)	0.61			
Minimum Reservoir (only)	Illensions	D + 70	( <del>L</del>	153			
Minimum R	אונפ חו			173			
		06 + Q	(£)				
ion	EI OA III		No. Operation	Advanced - Distribution	Advanced - Transmission	Advanced - Transmission	Recycled - Dist./Trans.
Duma Ctation 9. Decousir	אבאותווו מ עבא	Jump Station	No.		2-3	4-4	6-2
G		Reservoir Pump Station	No.	1-3 or 5-3	2-3	4-4	9-9
			ltem	1	2	3	4

### ACTUAL COMBINED SITES COMBINATIONS - NORTHERN Location of Intermediate Sites = approximately at 40th Street

			Most Likely, Largest
	Screen	Out	
te		(Ac)	1.5
inimum Combined Sit (Alt. B) Dimensions	Dia +70	W (ft)	221
Minir (A	Dia+W+120	L (ft)	287
		(Ac)	1.5
inimum Combined Site (Alt. A) Dimensions	Dia + 70	W (ft)	221
Minimu (Alt.	Dia+L+110	L (ft)	303
ervoir		No. Operation	3-3 or 4-3 3-3 or 4-3 Recycled - Dist./Trans.
Pump Station & Reservo	Reservoir Pump Station	No.	3-3 or 4-3
Pum	Reservoir	No.	3-3 or 4-3
		Item	1



### **APPENDIX D**



Table D-1
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **Pipeline Alignment Costs**

ripeline Alignment Costs				
Option 1.1 / 1.2	Qty.	Unit	Unit Cost	Total
30" Advanced Pipeline (open)	38,635	LF	\$450	\$17,385,750
8" Distribution Pipeline (paved)	93,400	LF	\$120	\$11,208,000
10" Distribution Pipeline (paved)	14,300	LF	\$150	\$2,145,000
Bore & Jack Tunnel (54")	645	LF	\$2,160	\$1,393,200
Construction Contingency (30%)				\$9,639,585
Construction Subtotal				\$41,771,535
Admin, Design, CM, Legal (30%)				\$12,531,461
Class 4 Estimate Contingency (-15% / +30%; use +15	5%)			\$6,265,730
Project Subtotal				\$60,568,726
Escalation to Midpoint Constuction (March 2015 - 3	years at 4% p	er year =	12.5%)	\$7,571,091
ESCALATED PROJECT COST TOTAL				\$68,139,816
Option 1.3 / 1.4	Qty.	Unit	Unit Cost	Total
30" Advanced Pipeline (open)	38,635	LF	\$450	\$17,385,750
20" Recycled Pipeline (open)	38,570	LF	\$300	\$17,383,730
8" Distribution Pipeline (paved)	93,400	LF	\$120	\$11,371,000
10" Distribution Pipeline (paved)	14,300	LF	\$150 \$150	\$2,145,000
Bore & Jack Tunnel (84")	645	LF	\$3,360	\$2,143,000
Construction Contingency (30%)	043	LI	\$3,300	\$13,343,085
Construction Subtotal				\$57,820,035
Admin, Design, CM, Legal (30%)				\$17,346,011
Class 4 Estimate Contingency (-15% / +30%; use +15	(%)			\$8,673,005
Project Subtotal	70)			\$83,839,051
Escalation to Midpoint Constuction (March 2015 - 3	vears at 4% n	er vear =	12 5%)	\$10,479,881
ESCALATED PROJECT COST TOTAL	years at 470 p	ci yeai -	12.570)	\$94,318,932
ESCALATED PROJECT COST TOTAL				33 <b>4</b> ,316,332
Option 1.5 / 1.6	Qty.	Unit	Unit Cost	Total
36" Advanced Pipeline (open)	38,635	LF	\$540	\$20,862,900
12" Brine Pipeline (open)	38,570	LF	\$180	\$6,942,600
8" Distribution Pipeline (paved)	93,400	LF	\$120	\$11,208,000
10" Distribution Pipeline (paved)	14,300	LF	\$150	\$2,145,000
Bore & Jack Tunnel (72")	645	LF	\$2,880	\$1,857,600
Construction Contingency (30%)				\$12,904,830
Construction Subtotal				\$55,920,930
Admin, Design, CM, Legal (30%)				\$16,776,279
Class 4 Estimate Contingency (-15% / +30%; use +15	5%)			\$8,388,140
Project Subtotal				\$81,085,349
Escalation to Midpoint Constuction (March 2015 - 3	years at 4% p	er year =	12.5%)	\$10,135,669
ESCALATED PROJECT COST TOTAL				\$91,221,017

Table D-1
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **Pipeline Alignment Costs**

Pipeline Alignment Costs				
Option 2.1 / 2.2	Qty.	Unit	Unit Cost	Total
30" Advanced Pipeline (paved)	42,400	LF	\$600	\$25,440,000
8" Distribution Pipeline (paved)	80,400	LF	\$120	\$9,648,000
10" Distribution Pipeline (paved)	9,500	LF	\$150	\$1,425,000
Bore & Jack Tunnel (54")	500	LF	\$2,160	\$1,080,000
Construction Contingency (30%)				\$11,277,900
Construction Subtotal				\$48,870,900
Admin, Design, CM, Legal (30%)				\$14,661,270
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$7,330,635
Project Subtotal				\$70,862,805
Escalation to Midpoint Constuction (March 2015 - 3 years	at 4% per yea	ar = 12.59	%)	\$8,857,851
ESCALATED PROJECT COST TOTAL				\$79,720,656
Option 2.3 / 2.4	Qty.	Unit	<b>Unit Cost</b>	Total
30" Advanced Pipeline (paved)	42,400	LF	\$600	\$25,440,000
20" Recycled Pipeline (paved)	42,400	LF	\$400	\$16,960,000
8" Distribution Pipeline (paved)	80,400	LF	\$120	\$9,648,000
10" Distribution Pipeline (paved)	9,500	LF	\$150	\$1,425,000
Bore & Jack Tunnel (84")	500	LF	\$3,360	\$1,680,000
Construction Contingency (30%)				\$16,545,900
Construction Subtotal				\$71,698,900
Admin, Design, CM, Legal (30%)				\$21,509,670
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$10,754,835
Project Subtotal				\$103,963,405
Escalation to Midpoint Constuction (March 2015 - 3 years	at 4% per yea	ar = 12.59	%)	\$12,995,426
ESCALATED PROJECT COST TOTAL				\$116,958,831
Option 2.5 / 2.6	Qty.	Unit	<b>Unit Cost</b>	Total
36" Advanced Pipeline (paved)	42,400	LF	\$720	\$30,528,000
12" Brine Pipeline (paved)	42,400	LF	\$240	\$10,176,000
8" Distribution Pipeline (paved)	80,400	LF	\$120	\$9,648,000
10" Distribution Pipeline (paved)	9,500	LF	\$150	\$1,425,000
Bore & Jack Tunnel (72")	500	LF	\$2,880	\$1,440,000
Construction Contingency (30%)				\$15,965,100
Construction Subtotal				\$69,182,100
Admin, Design, CM, Legal (30%)				\$20,754,630
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$10,377,315
Project Subtotal				\$100,314,045
Escalation to Midpoint Constuction (March 2015 - 3 years	at 4% per yea	ar = 12.59	%)	\$12,539,256
ESCALATED PROJECT COST TOTAL				\$112,853,301

Table D-1 City of San Bernardino Municipal Water Department **Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis** 

Pipeline Alignment Costs				
Option 3.1 / 3.2	Qty.	Unit	Unit Cost	Total
30" Advanced Pipeline (paved)	42,170	LF	\$600	\$25,302,000
8" Distribution Pipeline (paved)	74,000	LF	\$120	\$8,880,000
10" Distribution Pipeline (paved)	11,100	LF	\$150	\$1,665,000
Bore & Jack Tunnel (54")	570	LF	\$2,160	\$1,231,200
Construction Contingency (30%)				\$11,123,460
Construction Subtotal				\$48,201,660
Admin, Design, CM, Legal (30%)				\$14,460,498
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$7,230,249
Project Subtotal				\$69,892,407
Escalation to Midpoint Constuction (March 2015 - 3 years	s at 4% per y	ear = 12.	5%)	\$8,736,551
ESCALATED PROJECT COST TOTAL				\$78,628,958
Option 3.3 / 3.4	Qty.	Unit	Unit Cost	Total
30" Advanced Pipeline (paved)	42,170	LF	\$600	\$25,302,000
20" Recycled Pipeline (paved)	42,170	LF	\$400	\$16,868,000
8" Distribution Pipeline (paved)	74,000	LF	\$120	\$8,880,000
10" Distribution Pipeline (paved)	11,100	LF	\$150	\$1,665,000
Bore & Jack Tunnel (84")	570	LF	\$3,360	\$1,915,200
Construction Contingency (30%)			7-7	\$16,389,060
Construction Subtotal				\$71,019,260
Admin, Design, CM, Legal (30%)				\$21,305,778
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$10,652,889
Project Subtotal				\$102,977,927
Escalation to Midpoint Constuction (March 2015 - 3 years	s at 4% per y	ear = 12.	5%)	\$12,872,241
ESCALATED PROJECT COST TOTAL	· · ·		·	\$115,850,168
Option 3.5 / 3.6	Qty.	Unit	Unit Cost	Total
36" Advanced Pipeline (paved)	42,170	LF	\$720	\$30,362,400
12" Brine Pipeline (paved)	42,170	LF	\$240	\$10,120,800
8" Distribution Pipeline (paved)	74,000	LF	\$120	\$8,880,000
10" Distribution Pipeline (paved)	11,100	LF	\$150	\$1,665,000
Bore & Jack Tunnel (60")	570	LF	\$2,400	\$1,368,000
Construction Contingency (30%)				\$15,718,860
Construction Subtotal				\$68,115,060
Admin, Design, CM, Legal (30%)				\$20,434,518
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$10,217,259
Project Subtotal				\$98,766,837
Escalation to Midpoint Constuction (March 2015 - 3 year	s at 4% per y	ear = 12.	5%)	\$12,345,855
ESCALATED PROJECT COST TOTAL				\$111,112,692

Table D-1
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **Pipeline Alignment Costs**

Option 4.3 / 4.4	Qty.	Unit	<b>Unit Cost</b>	Total
30" Advanced Pipeline (open)	38,570	LF	\$450	\$17,356,500
20" Recycled Pipeline (paved)	42,170	LF	\$400	\$16,868,000
8" Distribution Pipeline (paved)	74,000	LF	\$120	\$8,880,000
10" Distribution Pipeline (paved)	11,100	LF	\$150	\$1,665,000
Bore & Jack Tunnel (54")	710	LF	\$2,160	\$1,533,600
Bore & Jack Tunnel (48")	570	LF	\$1,920	\$1,094,400
Construction Contingency (30%)				\$14,219,250
Construction Subtotal				\$61,616,750
Admin, Design, CM, Legal (30%)				\$18,485,025
Class 4 Estimate Contingency (-15% / +30%; use +1	5%)			\$9,242,513
Project Subtotal				\$89,344,288
Escalation to Midpoint Constuction (March 2015 -	3 years at 4% p	er year =	12.5%)	\$11,168,036
ESCALATED PROJECT COST TOTAL				\$100,512,323

### **Unit Cost Parameters**

	<b>Unit Cost</b>	Unit	
Pipeline (open)	\$15 \$	\$/inch-dia/L	F
Pipeline (paved)	\$20 \$	\$/inch-dia/L	F
Bore & Jack Tunnel	\$40 \$	\$/inch-dia/L	F
	Dia. (inch)	Open	Paved
Pipeline	4	\$60	\$80
Pipeline	6	\$90	\$120
Pipeline	8	\$120	\$160
Pipeline	10	\$150	\$200
Pipeline	12	\$180	\$240
Pipeline	20	\$300	\$400
Pipeline	30	\$450	\$600
Pipeline	36	\$540	\$720
Bore & Jack	48	\$1,920	
Bore & Jack	54	\$2,160	
Bore & Jack	60	\$2,400	
Bore & Jack	72	\$2,880	
Bore & Jack	84	\$3,360	
Pipeline O&M Costs	1% (	of Capital Co	osts

Table D-2
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

**ESCALATED PROJECT COST TOTAL** 

Pump Station/Tank Costs				
Pump Station / Tank Site A				
Option A.1 / A.5 (Reservoir No. 1-3 or 5-2)	Qty.	Unit	Unit Cost	Total
0.8 MG Reservoir (D = 83', Ht = 20'), above ground	0.8	MG	\$1,500,000	\$1,200,000
Construction Contingency (30%)	0.0		ψ 2,500,000	\$360,000
Construction Subtotal				\$1,560,000
Property Acquisition	1.1	AC	\$500,000	\$550,000
Admin, Design, CM, Legal (30%)			, ,	\$468,000
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$234,000
Project Subtotal				\$2,812,000
Escalation to Midpoint Constuction (March 2015 - 3 years at	4% per year =	12.5%)		\$351,500
ESCALATED PROJECT COST TOTAL	, ,	,		\$3,163,500
Option A.2 (Reservoir No. 2-3 and Pump Station 2-3)	Qty.	Unit	Unit Cost	Total
2.4 MG Reservoir (D = 117', Ht = 30'), above ground	2.4	MG	\$1,500,000	\$3,600,000
Pump Station (4 Pumps, 3300 gpm each, 400 HP each)	1,600	HP	\$5,400	\$8,640,000
Construction Contingency (30%)				\$3,672,000
Construction Subtotal				\$15,912,000
Property Acquisition	1.1	AC	\$500,000	\$550,000
Admin, Design, CM, Legal (30%)				\$4,773,600
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$2,386,800
Project Subtotal				\$23,622,400
Escalation to Midpoint Constuction (March 2015 - 3 years at ESCALATED PROJECT COST TOTAL	4% per year =	12.5%)		\$2,952,800 <b>\$26,575,200</b>
Option A.4 (Reservoir No. 4-4 and Pump Station 4-4)	Qty.	Unit	<b>Unit Cost</b>	Total
0.2 MG Reservoir (D = 59', Ht = 10'), above ground	0.2	MG	\$1,500,000	\$300,000
Pump Station (4 Pumps, 3300 gpm each, 400 HP each)	1,600	HP	\$5,400	\$8,640,000
Construction Contingency (30%)				\$2,682,000
Construction Subtotal				\$11,622,000
Property Acquisition	1.1	AC	\$500,000	\$550,000
Admin, Design, CM, Legal (30%)				\$3,486,600
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$1,743,300
Project Subtotal				\$17,401,900
Escalation to Midpoint Constuction (March 2015 - 3 years at	4% per year =	12.5%)		\$2,175,238
ESCALATED PROJECT COST TOTAL				\$19,577,138
Option A.6 (Reservoir No. 6-2 and Pump Station 6-2)	Qty.	Unit	<b>Unit Cost</b>	Total
2.4 MG Reservoir (D = 117', Ht = 30'), above ground	2.4	MG	\$1,500,000	\$3,600,000
Pump Station (4 Pumps, 5830 gpm each, 600 HP each)	2,400	HP	\$4,400	\$10,560,000
Construction Contingency (30%)				\$4,248,000
Construction Subtotal				\$18,408,000
Property Acquisition	1.1	AC	\$500,000	\$550,000
Admin, Design, CM, Legal (30%)				\$5,522,400
Class 4 Estimate Contingency (-15% / +30%; use +15%)				62 764 200
B : . C				\$2,761,200
Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at				\$2,761,200 \$27,241,600 \$3,405,200

\$30,646,800

Table D-2
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

Pump Station / Tank Site B				
Option B.1 / B.5 (Reservoir No. 1-3 or 5-2)	Qty.	Unit	<b>Unit Cost</b>	Total
0.8 MG Reservoir (D = 83', Ht = 20'), below ground	0.8	MG	\$2,200,000	\$1,760,000
Construction Contingency (30%)				\$528,000
Construction Subtotal				\$2,288,000
Admin, Design, CM, Legal (30%)				\$686,400
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$343,200
Project Subtotal				\$3,317,600
Escalation to Midpoint Constuction (March 2015 - 3 years a	it 4% per year	= 12.5%)		\$414,700
ESCALATED PROJECT COST TOTAL				\$3,732,300

Option B.2 (Reservoir No. 2-3 and Pump Station 2-3)	Qty.	Unit	Unit Cost	Total
2.4 MG Reservoir (D = 117', Ht = 30'), below ground	2.4	MG	\$2,200,000	\$5,280,000
Pump Station (4 Pumps, 3300 gpm each, 400 HP each)	1,600	HP	\$5,400	\$8,640,000
Construction Contingency (30%)				\$4,176,000
Construction Subtotal				\$18,096,000
Admin, Design, CM, Legal (30%)				\$5,428,800
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$2,714,400
Project Subtotal				\$26,239,200
Escalation to Midpoint Constuction (March 2015 - 3 years at	4% per year	= 12.5%)		\$3,279,900
ESCALATED PROJECT COST TOTAL				\$29,519,100

Option B.4 (Reservoir No. 4-4 and Pump Station 4-4)	Qty.	Unit	<b>Unit Cost</b>	Total
0.2 MG Reservoir (D = 59', Ht = 10'), below ground	0.2	MG	\$2,200,000	\$440,000
Pump Station (4 Pumps, 3300 gpm each, 400 HP each)	1,600	HP	\$5,400	\$8,640,000
Construction Contingency (30%)				\$2,724,000
Construction Subtotal				\$11,804,000
Admin, Design, CM, Legal (30%)				\$3,541,200
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$1,770,600
Project Subtotal				\$17,115,800
Escalation to Midpoint Constuction (March 2015 - 3 years at	4% per year	= 12.5%)		\$2,139,475
ESCALATED PROJECT COST TOTAL			<u> </u>	\$19,255,275

Option B.6 (Reservoir No. 6-2 and Pump Station 6-2)	Qty.	Unit	Unit Cost	Total
2.4 MG Reservoir (D = 117', Ht = 30'), below ground	2.4	MG	\$2,200,000	\$5,280,000
Pump Station (4 Pumps, 5830 gpm each, 600 HP each)	2,400	HP	\$4,400	\$10,560,000
Construction Contingency (30%)				\$4,752,000
Construction Subtotal				\$20,592,000
Admin, Design, CM, Legal (30%)				\$6,177,600
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$3,088,800
Project Subtotal				\$29,858,400
Escalation to Midpoint Constuction (March 2015 - 3 years at	t 4% per year	= 12.5%)		\$3,732,300
ESCALATED PROJECT COST TOTAL				\$33,590,700

Table D-2
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

Pump Station / Tank Site C				
Option C.1 / C.5 (Reservoir No. 1-3 or 5-2)	Qty.	Unit	<b>Unit Cost</b>	Total
0.8 MG Reservoir (D = 83', Ht = 20'), above ground	0.8	MG	\$1,500,000	\$1,200,000
Construction Contingency (30%)				\$360,000
Construction Subtotal				\$1,560,000
Admin, Design, CM, Legal (30%)				\$468,000
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$234,000
Project Subtotal				\$2,262,000
Escalation to Midpoint Constuction (March 2015 - 3 years at	t 4% per year =	12.5%)		\$282,750
ESCALATED PROJECT COST TOTAL				\$2,544,750

Option C.2 (Reservoir No. 2-3 and Pump Station 2-3)	Qty.	Unit	<b>Unit Cost</b>	Total
2.4 MG Reservoir (D = 117', Ht = 30'), above ground	2.4	MG	\$1,500,000	\$3,600,000
Pump Station (4 Pumps, 3300 gpm each, 400 HP each)	1,600	HP	\$5,400	\$8,640,000
Construction Contingency (30%)				\$3,672,000
Construction Subtotal				\$15,912,000
Admin, Design, CM, Legal (30%)				\$4,773,600
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$2,386,800
Project Subtotal				\$23,072,400
Escalation to Midpoint Constuction (March 2015 - 3 years at	4% per year =	12.5%)		\$2,884,050
ESCALATED PROJECT COST TOTAL				\$25,956,450

Option C.4 (Reservoir No. 4-4 and Pump Station 4-4)	Qty.	Unit	Unit Cost	Total
0.2 MG Reservoir (D = 59', Ht = 10'), above ground	0.2	MG	\$1,500,000	\$300,000
Pump Station (4 Pumps, 3300 gpm each, 400 HP each)	1,600	HP	\$5,400	\$8,640,000
Construction Contingency (30%)				\$2,682,000
Construction Subtotal				\$11,622,000
Admin, Design, CM, Legal (30%)				\$3,486,600
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$1,743,300
Project Subtotal				\$16,851,900
Escalation to Midpoint Constuction (March 2015 - 3 years at 4	% per year =	12.5%)		\$2,106,488
ESCALATED PROJECT COST TOTAL			_	\$18,958,388

Option C.6 (Reservoir No. 6-2 and Pump Station 6-2)	Qty.	Unit	Unit Cost	Total
2.4 MG Reservoir (D = 117', Ht = 30'), above ground	2.4	MG	\$1,500,000	\$3,600,000
Pump Station (4 Pumps, 5830 gpm each, 600 HP each)	2,400	HP	\$4,400	\$10,560,000
Construction Contingency (30%)				\$4,248,000
Construction Subtotal				\$18,408,000
Admin, Design, CM, Legal (30%)				\$5,522,400
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$2,761,200
Project Subtotal				\$26,691,600
Escalation to Midpoint Constuction (March 2015 - 3 years at 4	l% per year =	12.5%)		\$3,336,450
ESCALATED PROJECT COST TOTAL				\$30,028,050

Table D-2
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

**ESCALATED PROJECT COST TOTAL** 

Pump Station/Tank Costs				
Pump Station / Tank Site D				
Option D.3 / D.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)	Qty.	Unit	Unit Cost	Total
4.0 MG Reservoir (D = 151', Ht = 30'), below ground	4.0	MG	\$2,200,000	\$8,800,000
Pump Station (3 Pumps, 1750 gpm each, 100 HP each)	300	HP	\$8,000	\$2,400,000
Construction Contingency (30%)			. ,	\$3,360,000
Construction Subtotal				\$14,560,000
Admin, Design, CM, Legal (30%)				\$4,368,000
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$2,184,000
Project Subtotal				\$21,112,000
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)	)			\$2,639,000
ESCALATED PROJECT COST TOTAL				\$23,751,000
Pump Station / Tank Site E				
Option E.3 / E.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)	Qty.	Unit	Unit Cost	Total
4.0 MG Reservoir (D = 151', Ht = 30'), below ground	4.0	MG	\$2,200,000	\$8,800,000
Pump Station (3 Pumps, 1750 gpm each, 100 HP each)	300	HP	\$8,000	\$2,400,000
Relocate Park Facilities	1	LS	\$200,000	\$200,000
Construction Contingency (30%)				\$3,420,000
Construction Subtotal				\$14,820,000
Admin, Design, CM, Legal (30%)				\$4,446,000
Class 4 Estimate Contingency (-15% / +30%; use +15%)				\$2,223,000
Project Subtotal				\$21,489,000
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)				\$2,686,125
ESCALATED PROJECT COST TOTAL				\$24,175,125
B 0: 1: /= 1 0:: =				
Pump Station / Tank Site F	01:	1114	11-14-04	Takal
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)	Qty.	Unit	Unit Cost	Total
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground	4.0	MG	\$1,500,000	\$6,000,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each)	4.0 300	MG HP	\$1,500,000 \$8,000	\$6,000,000 \$2,400,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading	4.0	MG	\$1,500,000	\$6,000,000 \$2,400,000 \$300,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)	4.0 300	MG HP	\$1,500,000 \$8,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%) Construction Subtotal	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%) Construction Subtotal Property Acquisition	4.0 300	MG HP	\$1,500,000 \$8,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%)	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$3,393,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$2,118,688
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$2,118,688
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G	4.0 300 1	MG HP LS	\$1,500,000 \$8,000 \$300,000 \$500,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$2,118,688 \$19,068,188
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)	4.0 300 1 1.1	MG HP LS AC	\$1,500,000 \$8,000 \$300,000 \$500,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$2,118,688 \$19,068,188
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)  4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)  4.0 MG Reservoir (D = 151', Ht = 30'), above ground	4.0 300 1 1.1 4.0	MG HP LS AC	\$1,500,000 \$8,000 \$300,000 \$500,000 Unit Cost \$1,500,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)  4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%) Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%) ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP)	4.0 300 1 1.1 Qty. 4.0 300	MG HP LS AC Unit MG HP	\$1,500,000 \$8,000 \$300,000 \$500,000 <b>Unit Cost</b> \$1,500,000 \$8,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line	4.0 300 1 1.1 2ty. 4.0 300 3,300	MG HP LS AC Unit MG HP LF	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$825,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)  4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3)  4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line Extra Grading	4.0 300 1 1.1 Qty. 4.0 300	MG HP LS AC Unit MG HP	\$1,500,000 \$8,000 \$300,000 \$500,000 <b>Unit Cost</b> \$1,500,000 \$8,000	\$6,000,000 \$2,400,000 \$300,000 \$1,310,000 \$550,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$3300,000
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line	4.0 300 1 1.1 2ty. 4.0 300 3,300	MG HP LS AC Unit MG HP LF	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$2,400,000 \$300,000 \$2,857,500
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line Extra Grading Construction Contingency (30%)	4.0 300 1 1.1 2ty. 4.0 300 3,300	MG HP LS AC Unit MG HP LF	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$2,400,000 \$300,000 \$2,857,500 \$12,382,500
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition	4.0 300 1 1.1 4.0 300 3,300 1	MG HP LS AC	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$2,400,000 \$300,000 \$2,857,500
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line Extra Grading Construction Contingency (30%) Construction Subtotal	4.0 300 1 1.1 4.0 300 3,300 1	MG HP LS AC	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$2,400,000 \$2,857,500 \$12,382,500 \$550,000 \$3,714,750
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)  Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line Extra Grading Construction Contingency (30%)  Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%)	4.0 300 1 1.1 4.0 300 3,300 1	MG HP LS AC	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$16,949,500 \$2,118,688 \$19,068,188 Total \$6,000,000 \$2,400,000 \$2,400,000 \$2,857,500 \$12,382,500 \$550,000 \$3,714,750 \$1,857,375
Option F.3 / F.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground Pump Station (3 Pumps, 1750 gpm each, 100 HP each) Extra Grading Construction Contingency (30%) Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%) Class 4 Estimate Contingency (-15% / +30%; use +15%) Project Subtotal Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL  Pump Station / Tank Site G Option G.3 / G.4 (Reservoir No. 3-3 or 4-3 and Pump Station 3-3 or 4-3) 4.0 MG Reservoir (D = 151', Ht = 30'), above ground No Pump Station (but add 300 HP to Pump Station at SBWRP) Electrical Power Line Extra Grading Construction Contingency (30%) Construction Subtotal Property Acquisition Admin, Design, CM, Legal (30%)	4.0 300 1 1.1 1.1 4.0 300 3,300 1	MG HP LS AC	\$1,500,000 \$8,000 \$300,000 \$500,000 \$500,000 \$1,500,000 \$8,000 \$250 \$300,000	\$6,000,000 \$2,400,000 \$300,000 \$2,610,000 \$11,310,000 \$550,000 \$3,393,000 \$1,696,500 \$2,118,688 \$19,068,188  Total \$6,000,000 \$2,400,000 \$22,400,000 \$22,400,000 \$22,857,500 \$12,382,500 \$550,000 \$3,714,750

\$20,817,703

Table D-2
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **Unit Cost Parameters**

	<b>Unit Cost</b>	Unit	
Pump Station, 300 HP	\$8,000 \$/HP		
Pump Station, 1600 HP	\$5,400 \$/HP		
Pump Station, 2400 HP	\$4,400 \$/HP		
	НР	Cost	
Pump Station, 300 HP	300	\$2,400,000	
Pump Station, 1600 HP	1,600	\$8,640,000	
Pump Station, 2400 HP	2,400	\$10,560,000	
	Unit Cost	Unit	
Reservoir, above ground (0.8 to 4.0 MG)	\$1,500,000	MG	
Reservoir, below ground (0.8 to 4.0 MG)	\$2,200,000	MG	
Property	\$500,000	Acre	
Relocate Park Facilities	\$200,000	LS	
Extra Grading	\$300,000	LS	
Electrical Power Line	\$250	LF	

Pump Station O&M Costs Pump Station Energy Cost 1% of Capital Costs see separate sheet

Table D-3a
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **Conveyance Scenario Facilities**

CS1 (Reservoir 1-1 & 1-2 and Pump Station 1-1 & 1-2)	Qty.	Unit	Unit Cost	Total
4.2 MG Recycled Reservoir (D=155', Ht=30'), above ground	4.2	MG	\$1,500,000	\$6,300,000
Recycled Pump Station (3 pumps - 4,400 gpm / 250 HP each)	750	HP	\$6,000	\$4,500,000
3.2 MG Advanced Reservoir (D=135', Ht=30'), above ground	3.2	MG	\$1,500,000	\$4,800,000
Advanced Pump Station (4 pumps - 3,300 gpm / 600 HP each)	2,400	HP	\$4,400	\$10,560,000
Construction Contingency (30%)				\$7,848,000
Construction Subtotal				\$34,008,000
Admin, Design, CM, Legal (30%)				\$10,202,400
Class 5 Estimate Contingency (-20% / +30%; use +30%)				\$10,202,400
Project Subtotal				\$54,412,800
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)				\$6,801,600
ESCALATED PROJECT COST TOTAL				\$61,214,400
CS2 (Reservoir 2-1 & 2-2 and Pump Station 2-1 & 2-2)	Qty.	Unit	Unit Cost	Total
4.2 MG Recycled Reservoir (D=155', Ht=30'), above ground	4.2	MG	\$1,500,000	\$6,300,000
Recycled Pump Station (3 pumps - 4,400 gpm / 250 HP each)	750	HP	\$6,000	\$4,500,000
1.6 MG Advanced Reservoir (D=117', Ht=20'), above ground	1.6	MG	\$1,500,000	\$2,400,000
Advanced Pump Station (4 pumps - 3,300 gpm / 250 HP each)	1,000	HP	\$5,800	\$5,800,000
Construction Contingency (30%)				\$5,700,000
Construction Subtotal				\$24,700,000
Admin, Design, CM, Legal (30%)				\$7,410,000
Class 5 Estimate Contingency (-20% / +30%; use +30%)				\$7,410,000
Project Subtotal				\$39,520,000
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)				\$4,940,000
ESCALATED PROJECT COST TOTAL				\$44,460,000
CS3 (Reservoir 3-1 & 3-2 and Pump Station 3-1 & 3-2)	Qty.	Unit	<b>Unit Cost</b>	Total
4.3 MG Recycled Reservoir (D=157', Ht=30'), above ground	4.3	MG	\$1,500,000	\$6,450,000
Recycled Pump Station (3 pumps - 4,400 gpm / 250 HP each + 3 pumps - 2,500 gpm / 450 HP each)	2,100	HP	\$4,800	\$10,080,000
0.2 MG Advanced Reservoir (D=59', Ht=10'), above ground	0.2	MG	\$1,500,000	\$300,000
Advanced Pump Station (4 pumps - 3,300 gpm / 600 HP each)	2,400	HP	\$4,400	\$10,560,000
Construction Contingency (30%)				\$8,217,000
Construction Subtotal				\$35,607,000
Admin, Design, CM, Legal (30%)				\$10,682,100
Class 5 Estimate Contingency (-20% / +30%; use +30%)				\$10,682,100
Project Subtotal		·		\$56,971,200
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)				\$7,121,400
ESCALATED PROJECT COST TOTAL				\$64,092,600

### City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

### **Conveyance Scenario Facilities**

Pump Station O&M Costs

Pump Station Energy Cost

CS4 (Reservoir 4-1 & 4-2 and Pump Station 4-1 & 4-2)	Qty.	Unit	Unit Cost	Total
4.3 MG Recycled Reservoir (D=157', Ht=30'), above ground	4.3	MG	\$1,500,000	\$6,450,000
Recycled Pump Station (3 pumps - 4,400 gpm / 250 HP each + 3 pumps - 2,500 gpm / 450 HP each)	2,100	HP	\$4,800	\$10,080,000
0.2 MG Advanced Reservoir (D=59', Ht=10'), above ground	0.2	MG	\$1,500,000	\$300,000
Advanced Pump Station (4 pumps - 4,400 gpm / 250 HP each)	1,000	HP	\$5,800	\$5,800,000
Construction Contingency (30%)				\$6,789,000
Construction Subtotal				\$29,419,000
Admin, Design, CM, Legal (30%)				\$8,825,700
Class 5 Estimate Contingency (-20% / +30%; use +30%)				\$8,825,700
Project Subtotal				\$47,070,400
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)				\$5,883,800
ESCALATED PROJECT COST TOTAL				\$52,954,200
	٥.			<b>-</b> 1
CS5 (Reservoir 5-1 and Pump Station 5-1)	Qty.	Unit	Unit Cost	Total
7.4 MG Recycled Reservoir (D=178', Ht=40'), above ground	7.4	MG	\$1,500,000	\$11,100,000
Recycled Pump Station (3 pumps - 4,400 gpm / 250 HP each + 4 pumps - 5,830 gpm / 1,000 HP)	4,750	HP	\$3,200	\$15,200,000
Construction Contingency (30%)				\$7,890,000
Construction Subtotal				\$34,190,000
Admin, Design, CM, Legal (30%)				\$10,257,000 \$10,257,000
Class 5 Estimate Contingency (-20% / +30%; use +30%)				
Project Subtotal  Figure 10 Midpoint Construction (March 2015 - 2 years at 49/ per year = 12.59/)				\$54,704,000 \$6,838,000
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)  ESCALATED PROJECT COST TOTAL				\$61,542,000
ESCALATED HOSE COST TOTAL				<b>701,342,000</b>
CS6 (Reservoir 6-1 and Pump Station 6-1)	Qty.	Unit	Unit Cost	Total
5.8 MG Recycled Reservoir (D=158', Ht=40'), above ground	5.8	MG	\$1,500,000	\$8,700,000
Recycled Pump Station (3 pumps - 4,400 gpm / 250 HP each + 4 pumps - 5,830 gpm / 450 HP each)  Construction Contingency (30%)	2,550	HP	\$4,200	\$10,710,000 \$5,823,000
Construction Subtotal				\$25,233,000
Admin, Design, CM, Legal (30%)				\$7,569,900
Class 5 Estimate Contingency (-20% / +30%; use +30%)				\$7,569,900
Project Subtotal				\$40,372,800
Escalation to Midpoint Constuction (March 2015 - 3 years at 4% per year = 12.5%)				\$5,046,600
ESCALATED PROJECT COST TOTAL				\$45,419,400
Unit Cost Parameters	Unit Cost	Unit		
Pump Station, 750 HP	\$6,000			
Pump Station, 1000 HP	\$5,800	-		
Pump Station, 2100 HP	\$4,800	-		
Pump Station, 2400 HP	\$4,400	-		
Pump Station, 2550 HP	\$4,200	-		
Pump Station, 4750 HP	\$3,200			
Duran Chabina 750 HD	HP	Cost		
Pump Station, 750 HP	750	\$4,500,000		
Pump Station, 1000 HP	1,000	\$5,800,000		
Pump Station, 2100 HP	2,100	\$10,080,000		
Pump Station, 2400 HP	2,400	\$10,560,000		
Pump Station, 2550 HP	2,550	\$10,710,000		
Pump Station, 4750 HP	4,750	\$15,200,000		
	Unit Cost	Unit		
Reservoir, above ground (0.2 to 7.5 MG)	\$1,500,000	MG		
Reservoir, below ground (0.2 to 7.5 MG)	\$2,200,000	MG		

1% of Capital Costs

see separate sheet

Table D-3b
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

## **Conveyance Scenario Costs**

<u>Cost Scenario</u>	<b>Total Cost</b>
Conveyance Scenario 1	\$131,898,966
CS1 Facilities, Pipeline Alignment Option 1.1, PS/Tank Site C.1	
Conveyance Scenario 2	\$138,556,266
CS2 Facilities, Pipeline Alignment Option 1.2, PS/Tank Site C.2	
Conveyance Scenario 3	\$177,479,720
CS3 Facilities, Pipeline Alignment Option 1.3, PS/Tank Site F.3	
Conveyance Scenario 4	\$185,299,707
CS4 Facilities, Pipeline Alignment Option 1.4, PS/Tank Site F.4 + C.4	
Conveyance Scenario 5	\$155,307,767
CS5 Facilities, Pipeline Alignment Option 1.5, PS/Tank Site C.5	
Conveyance Scenario 6	\$166,668,467
CS6 Facilities, Pipeline Alignment Option 1.6, PS/Tank Site C.6	

Table D-3c
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **Operation & Maintenance Costs**

Cost Scenario Conveyance Scenario 1	Total Cost
CS1 Facilities, Pipeline Alignment Option 1.1, PS/Tank Site C.1 Energy Costs O&M Costs Total	\$1,207,120 \$1,318,990 \$2,526,110
Conveyance Scenario 2  CS2 Facilities, Pipeline Alignment Option 1.2, PS/Tank Site C.2  Energy Costs  O&M Costs  Total	\$1,208,596 <u>\$1,385,563</u> \$2,594,159
Conveyance Scenario 3  CS3 Facilities, Pipeline Alignment Option 1.3, PS/Tank Site F.3  Energy Costs  O&M Costs  Total	\$1,314,155 <u>\$1,774,797</u> \$3,088,952
Conveyance Scenario 4  CS4 Facilities, Pipeline Alignment Option 1.4, PS/Tank Site F.4 + C.4  Energy Costs  O&M Costs  Total	\$1,779,368 <u>\$1,852,997</u> \$3,632,365
Conveyance Scenario 5  CS5 Facilities, Pipeline Alignment Option 1.5, PS/Tank Site C.5  Energy Costs  O&M Costs  Total	\$1,932,401 <u>\$1,553,078</u> \$3,485,479
Conveyance Scenario 6  CS6 Facilities, Pipeline Alignment Option 1.6, PS/Tank Site C.6  Energy Costs  O&M Costs  Total	\$1,933,877 <u>\$1,666,685</u> \$3,600,562



Table D-3d City of San Bernardino MWD Recycled/Advanced Water Conveyance System Alternatives Engineering Study

OVERALL CONVEYANCE SCENARIO COSTS

O&M COSTS
CAPITAL COSTS

Conveyance Scenario 1	CAPITAL COSTS Quantity Unit	c <b>osts</b> <u>\$/Unit</u>	Total Cost	O&M COSTS Quantity Unit	\$/Unit	Total Cost	COST PER ACRE-FOOT Present Worth (20 year, 6% = )	(= %9 '.	11.47
Tertiary Treatment Advanced Treatment	E E		\$ 6,300,000	1 mgd	66,000	\$ 138,600	Capital O&M	\$ 246,098,966	
Pipelines - Alignment Option 1	1 LS	\$ 68,139,816		1 LS \$	681,398				
PS/Tank Site Option C PS/Tank at SBWRP	1 LS	\$ 2,544,750 \$ 61,214,400	\$ 2,544,750 \$ 61,214,400	1 LS 5	25,448 612,144	\$ 25,448 \$ 612,144	Total Flow (mgd)	\$ 358,798,301 16.3	18256 AF/yr
Recharge Basins/Convert Recycle Sites	1 LS		\$ 8,500,000		365,000		Cost per Acre-foot	\$ 1,414	:
Energy Costs (Pump Station/ Lanks - O&M) Reduced RIX Cost (O&M) TOTAL			\$ 246.098.966	1 LS \$	1,318,990 (842,000)	\$ 1,318,990 \$ (842,000) \$ 9.825,579			
	STSOCIVE	SESC		ST302 M.80	•		TOOS 380 A SEC ESCO.		
Conveyance Scenario 2	Quantity Unit	\$/Unit	Total Cost	Quantity Unit	\$/Unit	Total Cost	Present Worth (20 year, 6% = )	( = %9 )	11.47
Tertiary Treatment	m ]		\$ 6,300,000	mgd	000'99	\$ 138,600	_	\$ 252,756,266	
Advanced Treatment Dipolines - Alignment Ontion 1	14.2 mgd 1 I S	5 7,000,000	\$ 99,400,000 \$ 68,139,816	14.2 mgd \$	530,000	_	O&M Present Worth O&M	\$ 9,781,759 \$ 112 196 772	
Pipelines - Augminent Option 1 PS/Tank Site Option C	1 LS				259,565	\$ 259,565		\$ 364,953,038	
PS/Tank at SBWRP	1 LS	\$ 44,460,000			444,600			16.3	18256 AF/yr
Recharge Basins/Convert Recycle Sites Fineray Corts (Pirmy Station/Tanks - O&M)	1 LS	\$ 8,500,000	\$ 8,500,000	1 LS \$	365,000	\$ 365,000	Cost per Acre-foot	\$ 1,435	
Energy Costs (Pump Station) rains - Owivi) Reduced RIX Cost (O&M)					(842,000)				
TOTAL			\$ 252,756,266			\$ 9,781,759			
	CAPITAL COST	COSTS		O&M COSTS			COST PER ACRE-FOOT		
Conveyance Scenario 3	Quantity Unit		Total Cost	Quantity Unit	\$/Unit	Total Cost	Present Worth (20 year, 6% = )	( = %9 ;	11.47
Tertiary Treatment	_		\$ 27,300,000	1 mgd	000′99		Capital	\$ 312,679,720	
Advanced Treatment	14.2 mgd			14.2 mgd \$	230,000	7	0&M		
Pipelines - Alignment Option 1 PS الاعتاد و التعالم ا	1 LS	\$ 94,318,932	\$ 94,318,932	1 LS S	943,189	\$ 943,189	Present Worth O&M	\$ 118,170,274	
PS/Tank at SBWRP	1 LS		\$ 64,092,600	1 LS \$	640,926		Total Flow (mgd)		26096 AF/yr
Recharge Basins/Convert Recycle Sites	1 LS		\$ 8,500,000		365,000		Cost per Acre-foot	\$ 1,173	
Energy Costs (Pump Station/Tanks - O&M)				1 LS \$	1,314,155				
Keduced KIX Cost (O&IVI) TOTAL			\$ 312,679,720		(1,278,000)	\$ (1,278,000) \$ 10,302,552			
					•				
A circumo Communication	CAPITAL COSTS	COSTS		õ	+:0175	+500  c+01	COST PER ACRE-FOOT	( - /6)	77
Conveyance Scenario 4 Tertiary Treatment	Quantity Unit			9.1 mgd \$	66.000	10tal COST 5 600.600	Present Worth (20 year, 8% = ) Capital	, 6% = ) \$ 320.499.707	11.4/
Advanced Treatment	14.2 mgd	\$ 7,000,000		14.2 mgd \$	530,000	7	O&M	\$ 10,845,965	
Pipelines - Alignment Option 1	1 LS		\$ 94,318,932		943,189		Present Worth O&M	\$ 124,403,219	
PS/Tank Site Option C + F	1 LS	\$ 38,026,575	\$ 38,026,575	1 LS \$	380,266	\$ 380,266	Total Present Worth	\$ 444,902,926	26096 45/47
Recharge Basins/Convert Recycle Sites	1 LS		\$ 8,500,000		365,000		Cost per Acre-foot	\$ 1,213	14/10/00/2
Energy Costs (Pump Station/Tanks - O&M)					1,779,368		-	•	
Reduced RIX Cost (O&M) TOTAL			\$ 320,499,707		(1,278,000)	\$ (1,278,000) \$ 10,845,965			
	ST3CO INTIGAC	3 H3 G		31300 8400			1007 1004 010 1200		
Conveyance Scenario 5	Quantity Unit	\$/Unit	Total Cost	Quantity Unit	\$/Unit	Total Cost	Present Worth (20 year, 6% = )	(= %9 = )	11.47
Tertiary Treatment (Remote Site + 30%)			\$ 35,490,000		85,800	\$ 780,780	Capital	\$ 328,517,767	
Advanced Treatment (Remote Site +30%) Dipolipes - Alimment Option 1	14.2 mgd	\$ 9,100,000	\$ 129,220,000	14.2 mgd \$	689,000	\$ 9,783,800	O&M Present Worth O&M	\$ 13,071,059	
PS/Tank Site Option C	1 LS	\$ 2,544,750	\$ 2,544,750	1 LS \$	25,448		Total Present Worth	\$ 478,442,810	
PS/Tank at SBWRP	1 LS	9	\$ 61,542,000		615,420	•	Total Flow (mgd)		26096 AF/yr
Recharge Basins/Convert Recycle Sites	1 LS	\$ 8,500,000	\$ 8,500,000	1 LS \$	365,000	\$ 365,000	Cost per Acre-foot	\$ 1,318	
Energy Costs (Pump Station) rains - Owivi) Reduced RIX Cost (O&M)					(1,344,000)	\$ 1,332,401			
TOTAL			\$ 328,517,767			٠.			
	CAPITAL COSTS	COSTS		O&M COSTS			COST PER ACRE-FOOT		
Conveyance Scenario 6	Quantity Unit		-	nit	<u>\$/Unit</u>	Tot	: Worth (20 yea	., 6% = )	11.47
Tertiary Treatment (Remote Site +30%) Advanced Treatment (Remote Site +30%)	9.1 mgd 14.2 mgd	\$ 3,900,000	\$ 35,490,000	9.1 mgd \$	85,800	\$ 780,780	Capital O&M	\$ 339,878,467	
Pipelines - Alignment Option 1	1 LS	01			912,210		nt Worth O&M	\$ 151,245,045	
PS/Tank Site Option C	1 LS		\$ 30,028,050		300,281		Total Present Worth	\$ 491,123,512	
PS/Tank at SBWRP Recharge Rasins/Convert Recycle Sites	1 LS	\$ 45,419,400	\$ 45,419,400	1 LS \$	365,000	\$ 454,194 \$ 365,000	Total Flow (mgd)	23.3	26096 AF/yr
Fine Station (Pumb Station Tanks - O&M)	3				1,933,877	1,933,877	non-lan vice		
Reduced RIX Cost (O&M)					(1,344,000)				
TOTAL			\$ 339,878,467		0,	\$ 13,186,142			



Table D-4
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **CONVEYANCE SCENARIO 1 - ENERGY COSTS**

	FACILITY	ENERGY USE / COSTS		
Pipeline 1-1				
Capacity:	14.2 mgd	Energy Use =	None	
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr	
Diameter:	30 inch			
Length (min):	39,280 feet			
Length (max):	42,900 feet			
Pressure (min):	15 psi			
Pressure (min):	250 psi			
Pump Station 1-1				
Capacity:	12.6 mgd	Energy Demand Charges =	\$3,429.30 \$/mo	
Pressure:	80 psi	Yearly Energy Demand Charges =	\$41,151.60 \$/yr	
Efficiency:	80%	, ,,		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year	
	3960 x Eff (%)	Energy TOU =	3,335,553 kWh/yr	
HP =	510	Average Energy TOU Cost =	0.06785 \$/kWh	
		Yearly TOU Energy Cost =	\$226,333.45 \$/yr	
		Yearly Energy Cost =	\$267,485 \$/yr	
Pump Station 1-2				
Capacity:	14.2 mgd	Energy Demand Charges =	\$11,767.36 \$/mo	
Pressure:	250 psi	Yearly Energy Demand Charges =	\$141,208.35 \$/yr	
Efficiency:	80%			
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year	
	3960 x Eff (%)	Energy TOU =	11,747,234 kWh/yr	
HP =	1798	Average Energy TOU Cost =	0.06785 \$/kWh	
		Yearly TOU Energy Cost =	\$797,106.90 \$/yr	
		Yearly Energy Cost =	\$938,315 \$/yr	
Storage Tank 1-1:				
Capacity:	4.2 MG	Energy TOU =	2,000 kWh/yr	
		Average Energy TOU Cost =	0.22000 \$/kWh	
		Yearly TOU Energy Cost =	\$440 \$/yr	
Storage Tank 1-2:				
Capacity:	3.2 MG	Energy TOU =	2,000 kWh/yr	
		Average Energy TOU Cost =	0.22000 \$/kWh	
		Yearly TOU Energy Cost =	\$440 \$/yr	
Storage Tank 1-3:				
Capacity:	0.8 MG	Energy TOU =	2,000 kWh/yr	
		Average Energy TOU Cost =	0.22000 \$/kWh	
		Yearly TOU Energy Cost =	\$440 \$/yr	
Total Yearly Energy	Costs for Conveyane Scenario 1		\$1,207,120	

Table D-4
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **CONVEYANCE SCENARIO 2 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pipeline 2-1			
Capacity:	14.2 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	30 inch		
Length (min):	24,730 feet		
Length (max):	28,170 feet		
Pressure (min):	30 psi		
Pressure (min):	100 psi		
Pipeline 2-2			
Capacity:	14.2 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	30 inch		
Length (min):	14,550 feet		
Length (max):	16,610 feet		
Pressure (min):	15 psi		
Pressure (min):	150 psi		
Pump Station 2-1			
Capacity:	12.6 mgd	Energy Demand Charges =	\$3,429.30 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$41,151.60 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	3,335,553 kWh/yr
HP =	510	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$226,333.45 \$/yr
		Yearly Energy Cost =	\$267,485 \$/yr
Pump Station 2-2			
Capacity:	14.2 mgd	Energy Demand Charges =	\$4,780.71 \$/mo
Pressure:	100 psi	Yearly Energy Demand Charges =	\$57,368.51 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	4,698,893 kWh/yr
HP =	719	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$318,842.76 \$/yr
		Yearly Energy Cost =	\$376,211 \$/yr

City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

### **CONVEYANCE SCENARIO 2 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pump Station 2-3			
Capacity:	14.2 mgd	Energy Demand Charges =	\$7,109.59 \$/mo
Pressure:	150 psi	Yearly Energy Demand Charges =	\$85,315.12 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	7,048,340 kWh/yr
HP =	1079	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$478,264.14 \$/yr
		Yearly Energy Cost =	\$563,579 \$/yr
Storage Tank 2-1:			
Capacity:	4.2 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 2-2:			
Capacity:	1.6 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 2-3:			
Capacity:	2.4 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Total Yearly Energy	Costs for Conveyane Scenario	<u> </u> 	\$1,208,596

Table D-4
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **CONVEYANCE SCENARIO 3 - ENERGY COSTS**

FACILITY		ENERGY USE / COSTS	
Pipeline 3-1			
Capacity:	7.0 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0
Diameter:	20 inch		
Length (min):	36,020 feet		
Length (max):	38,750 feet		
Pressure (min):	30 psi		
Pressure (min):	250 psi		
Pipeline 3-2			
Capacity:	5.0 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	16 inch		
Length (min):	3,260 feet		
Length (max):	6,040 feet		
Pressure (min):	15 psi		
Pressure (min):	80 psi		
Pipeline 3-3			
Capacity:	14.2 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	30 inch		
Length (min):	39,280 feet		
Length (max):	42,900 feet		
Pressure (min):	15 psi		
Pressure (min):	250 psi		
Pump Station 3-1			
Capacity:	12.6 mgd	Energy Demand Charges =	\$3,429.30 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$41,151.60 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	3,335,553 kWh/yr
HP =	510	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$226,333.45 \$/yr
		Yearly Energy Cost =	\$267,485 \$/yr

City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

### **CONVEYANCE SCENARIO 3 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pump Station 3-2			
Capacity:	14.2 mgd	Energy Demand Charges =	\$11,767.36 \$/mo
Pressure:	250 psi	Yearly Energy Demand Charges =	\$141,208.35 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	11,747,234 kWh/yr
HP =	1798	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$797,106.90 \$/yr
		Yearly Energy Cost =	\$938,315 \$/yr
Pump Station 3-3			
Capacity:	5.0 mgd	Energy Demand Charges =	\$1,434.99 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$17,219.85 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	1,323,632 kWh/yr
HP =	203	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$89,814.86 \$/yr
		Yearly Energy Cost =	\$107,035 \$/yr
Storage Tank 3-1:			
Capacity:	4.3 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 3-2:			
Capacity:	0.2 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 3-3:			
Capacity:	4.0 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Total Yearly Energy	Costs for Conveyane Scenario	) 3:	\$1,314,155

Table D-4
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **CONVEYANCE SCENARIO 4 - ENERGY COSTS**

FACIL	ITY		ENERGY USE / C	OSTS
Pipeline 4-1				
Capacity:	7.0 mgd	Energy Use =	None	
Velocity:	6 fps	Total Energy Cost =		\$0 \$/yr
Diameter:	20 inch			
Length (min):	36,020 feet			
Length (max):	38,750 feet			
Pressure (min):	30 psi			
Pressure (min):	250 psi			
Pipeline 4-2				
Capacity:	5.0 mgd	Energy Use =	None	
Velocity:	6 fps	Total Energy Cost =		\$0
Diameter:	16 inch			
Length (min):	3,260 feet			
Length (max):	6,040 feet			
Pressure (min):	15 psi			
Pressure (min):	80 psi			
Pipeline 4-3				
Capacity:	14.2 mgd	Energy Use =	None	
Velocity:	6 fps	Total Energy Cost =		\$0
Diameter:	30 inch			
Length (min):	24,730 feet			
Length (max):	28,170 feet			
Pressure (min):	30 psi			
Pressure (min):	100 psi			
Pipeline 4-4				
Capacity:	14.2 mgd	Energy Use =	None	
Velocity:	6 fps	Total Energy Cost =		\$0
Diameter:	30 inch			
Length (min):	14,550 feet			
Length (max):	16,610 feet			
Pressure (min):	15 psi			
Pressure (min):	150 psi			

City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

### **CONVEYANCE SCENARIO 4 - ENERGY COSTS**

	FACILITY	ENERGY USE / COSTS	
Pump Station 4-1A			
Capacity:	12.6 mgd	Energy Demand Charges =	\$3,429.30 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$41,151.60 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	3,335,553 kWh/yr
HP =	510	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$226,333.45 \$/yr
		Yearly Energy Cost =	\$267,485 \$/yr
Pump Station 4-1B			
Capacity:	7.0 mgd	Energy Demand Charges =	\$5,863.15 \$/mo
Pressure:	250 psi	Yearly Energy Demand Charges =	\$70,357.78 \$/yr
Efficiency:	80%		•
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	5,790,890 kWh/yr
HP =	886	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$392,940.02 \$/yr
		Yearly Energy Cost =	\$463,298 \$/yr
Pump Station 4-2			
Capacity:	14.2 mgd	Energy Demand Charges =	\$4,780.71 \$/mo
Pressure:	100 psi	Yearly Energy Demand Charges =	\$57,368.51 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	4,698,893 kWh/yr
HP =	719	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$318,842.76 \$/yr
		Yearly Energy Cost =	\$376,211 \$/yr
Pump Station 4-3			
Capacity:	5.0 mgd	Energy Demand Charges =	\$1,434.99 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$17,219.85 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	1,323,632 kWh/yr
HP =	203	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$89,814.86 \$/yr
		Yearly Energy Cost =	\$107,035 \$/yr

City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

### **CONVEYANCE SCENARIO 4 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pump Station 4-4			
Capacity:	14.2 mgd	Energy Demand Charges =	\$7,109.59 \$/mo
Pressure:	150 psi	Yearly Energy Demand Charges =	\$85,315.12 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	7,048,340 kWh/yr
HP =	1079	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$478,264.14 \$/yr
		Yearly Energy Cost =	\$563,579 \$/yr
Storage Tank 4-1:			
Capacity:	4.3 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 4-2:			
Capacity:	0.2 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 4-3:			
Capacity:	4.0 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 4-4:			
Capacity:	0.2 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Total Yearly Energy	Costs for Conveyane Scenario		\$1,779,368

Table D-4
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **CONVEYANCE SCENARIO 5 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pipeline 5-1			
Capacity:	25.2 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	36 inch		
Length (min):	39,280 feet		
Length (max):	42,900 feet		
Pressure (min):	, 15 psi		
Pressure (min):	250 psi		
Pipeline 5-2			
Capacity:	2.5 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	12 inch	3, 222	1 - 1,,
Length (min):	39,280 feet		
Length (max):	42,900 feet		
Pressure (min):	5 psi		
Pressure (min):	15 psi		
Pump Station 5-1A			
Capacity:	12.6 mgd	Energy Demand Charges =	\$3,429.30 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$41,151.60 \$/yr
Efficiency:	80%	rearry Energy Demand enarges =	φ+1,131.00 γ, γι
Linciency.	8076		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	3,335,553 kWh/yr
HP =	510	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$226,333.45 \$/yr
		Yearly Energy Cost =	\$267,485 \$/yr
Pump Station 5-1B			
Capacity:	25.2 mgd	Energy Demand Charges =	\$20,787.69 \$/mo
Pressure:	250 psi	Yearly Energy Demand Charges =	\$249,452.29 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	20,847,203 kWh/yr
HP =	3190	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$1,414,584.07 \$/yr
		Yearly Energy Cost =	\$1,664,036 \$/yr
Storage Tank 5-1:			
Capacity:	7.4 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr

City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

## **CONVEYANCE SCENARIO 5 - ENERGY COSTS**

FACII	LITY	ENE	RGY USE / COSTS	
Storage Tank 5-2: Capacity:	0.8 MG	Energy TOU = Average Energy TOU Cost = Yearly TOU Energy Cost =	2,000 kWh/yr 0.22000 \$/kWh \$440 \$/yr	
Total Yearly Energy Costs	for Conveyane Scenar	, ,,	\$1,932,401	

Table D-4
City of San Bernardino Municipal Water Department
Clean Water Factory Project
Recycled/Advanced Water Conveyance System
Engineering Analysis

### **CONVEYANCE SCENARIO 6 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pipeline 6-1			
Capacity:	25.2 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	36 inch		
Length (min):	24,730 feet		
Length (max):	28,170 feet		
Pressure (min):	30 psi		
Pressure (min):	100 psi		
Pipeline 6-2			
Capacity:	25.2 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	36 inch		
Length (min):	14,550 feet		
Length (max):	16,610 feet		
Pressure (min):	15 psi		
Pressure (min):	150 psi		
Pipeline 6-3			
Capacity:	2.5 mgd	Energy Use =	None
Velocity:	6 fps	Total Energy Cost =	\$0 \$/yr
Diameter:	12 inch		
Length (min):	39,280 feet		
Length (max):	42,900 feet		
Pressure (min):	5 psi		
Pressure (min):	15 psi		
Pump Station 6-1A			
Capacity:	12.6 mgd	Energy Demand Charges =	\$3,429.30 \$/mo
Pressure:	80 psi	Yearly Energy Demand Charges =	\$41,151.60 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	3,335,553 kWh/yr
HP =	510	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$226,333.45 \$/yr
		Yearly Energy Cost =	\$267,485 \$/yr

City of San Bernardino Municipal Water Department Clean Water Factory Project Recycled/Advanced Water Conveyance System Engineering Analysis

### **CONVEYANCE SCENARIO 6 - ENERGY COSTS**

	FACILITY	ENE	RGY USE / COSTS
Pump Station 6-1B			
Capacity:	25.2 mgd	Energy Demand Charges =	\$8,388.84 \$/mo
Pressure:	100 psi	Yearly Energy Demand Charges =	\$100,666.08 \$/yr
Efficiency:	80%		
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	8,338,881 kWh/yr
HP =	1276	Average Energy TOU Cost =	0.06785 \$/kWh
	1270	Yearly TOU Energy Cost =	\$565,833.63 \$/yr
		Yearly Energy Cost =	\$666,500 \$/yr
Pump Station 6-2			
Capacity:	25.2 mgd	Energy Demand Charges =	\$12,521.79 \$/mo
Pressure:	150 psi	Yearly Energy Demand Charges =	\$150,261.48 \$/yr
Efficiency:	80%	, , ,	
HP =	Q (gpm) x TDH (ft)	Energy TOU =	HP x 0.746 x 24 hrs/day x 365 days/year
	3960 x Eff (%)	Energy TOU =	12,508,322 kWh/yr
HP =	1914	Average Energy TOU Cost =	0.06785 \$/kWh
		Yearly TOU Energy Cost =	\$848,750.44 \$/yr
		Yearly Energy Cost =	\$999,012 \$/yr
Storage Tank 6-1:			
Capacity:	5.8 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Storage Tank 6-2:			
Capacity:	2.4 MG	Energy TOU =	2,000 kWh/yr
		Average Energy TOU Cost =	0.22000 \$/kWh
		Yearly TOU Energy Cost =	\$440 \$/yr
Total Yearly Energy	/ Costs for Conveyane Scenario	<u> </u> o6:	\$1,933,877

## **APPENDIX E**



TABLE E-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

ALIGNMENT OPTION 1 - DISTRIBUTION PIPELINES

	I	<del>                                     </del>				1		_	1	1						1											1	1			_	1	1				
Length (ft)	2,598						374	2,269				5,726														3,342				1,024						1,368	
Diam Actual (in)	9				:	:	10	8	:	:	-	8	-	-	-	:	-	-	-	-	-		-			10		:	-	8		1	:	-		8	
Min Diam Req'd (in)	5.0		-	-	1	1	8.1	7.3	1	:	1	3.7	1	1	1	;	!	1	1	1	1		1	-	-	9.6		1	:	4.8		1	:	!		5.0	
Max Allowable Velocity (ft/s)	6.0		-	-	1	;	6.0	0.9	1	;	-	0.9	-	!	1	;	1	!	1	1	1		-	-	-	6.0		!	:	0.9		1	:	!		0.9	
Peak Hour Dmd (cfs)	0.830		1.733	0.099	0.131	0.210	2.173	1.733	0.099	0.131	0.210	0.440	0.304	0.233	0.183	0.108	0.120	0.169	0.211	0.104	0.464	0.257	0.093	0.135	0.607	2.990		0.304	0.464	0.768		0.233	0.211	0.104	0.257	0.806	
Peak Hour Dmd (gpm)	373		778	44	59	94	975	778	44	59	94	197	137	105	82	49	54	76	94	47	208	116	42	61	273	1,342		13/	208	345		105	94	47	116	362	
Potential Direct Use Customer(s) Name	CalTrans (I-215)		San Bernardino Public Golf Course	Leland Nursery & Patio Supply	Norton Space Academy	Mill Community Park	SUBTOTAL	San Bernardino Public Golf Course	Leland Nursery & Patio Supply	Norton Space Academy	Mill Community Park	SUBTOTAL	Pioneer Memorial Cemetery	San Benardino County Gov Center	Law Library for San Bernardino	California Theater	Norman F Feldheym Public Library	Municipal Baseball Park	Meadowbrook Recreation Park	Meadowbrook Park	Secombe Lake State Recreation Area4	Burbank Elementary	Residential	Conrand MS and Harding School	Juanita Blakely Jones Elementary	SUBTOTAL	:	Pioneer Memorial Cemetery	Secombe Lake State Recreation Area4	SUBTOTAL		San Benardino County Gov Center	Meadowbrook Recreation Park	Meadowbrook Park	Burbank Elementary	SUBTOTAL	
Potential Direct Use Customer(s) ID No.	CT-1		GC-1	N-1	SC-1	PK-1		GC-1	N-1	SC-1	PK-1		C-1	PB-2	PB-3	PB-4	PB-5	PK-2	PK-3	PK-4	PK-5	SC-2	SC-3	SC-4	SC-5		,	[:-]	PK-5			PB-2	PK-3	PK-4	SC-2		
Street(s)	Orange Show Rd		Orange Show Rd					Orange Show Rd	Orange Show Rd	Waterman Ave	Central Ave		5th St															Sierra Way				Sierra Way					
Distribution Segment Number	1-1		2-1					2-2	2-3				3-1														ć	3-7				3-3					

SAN BERNARDINO MUNICIPAL WATER DEPARTMENT CLEAN WATER FACTORY PROJECT RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

**TABLE E-1** 

ALIGNMENT OPTION 1 - DISTRIBUTION PIPELINES

Distribution segment		Potential Direct Use		Peak Hour Dmd	Реак ноиг ита	Max Allowable	Min Diam Req'd		
Number	Street(s)	Customer(s) ID No.	Potential Direct Use Customer(s) Name	(mdg)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
3-4	3rd St	PB-2	San Benardino County Gov Center	105	0.233	0.9	2.7	8	1,042
3-5	Sierra Way	PK-3	Meadowbrook Recreation Park	94	0.211	:	1	-	
		SC-2	Burbank Elementary	116	0.257	-	1	-	
				210	0.468	6.0	3.8	8	1,361
3-6	Rialto Ave	PK-3	Meadowbrook Recreation Park	94	0.211	6.0	2.5	8	889
3-7	Sierra Way	SC-2	Burbank Elementary	116	0.257	6.0	2.8	∞	2,774
3-8	5th St	PB-3	Law Library for San Bernardino	82	0.183	-	1	1	
		PB-4	California Theater	49	0.108	-	1	1	
		PB-5	Norman F Feldheym Public Library	54	0.120	-	ł	-	
		PK-2	Municipal Baseball Park	92	0.169	-	1		
		SC-3	Residential	42	0.093	:	1	1	
		SC-4	Conrand MS and Harding School	61	0.135	:	1	1	
		SC-5	Juanita Blakely Jones Elementary	273	0.607	:	1	-	
			SUBTOTAL	989	1.416	0.9	9.9	8	2,726
3-9	E St	PK-2	Municipal Baseball Park	76	0.169	6.0	2.3	∞	4,052
2.10	1+b C+	2 00	Norman E Eoldhaum Dublic Library	E.A.	0.120				
07-0	36 136			t (	0.120	1		1	
		SC-3	Residential	47	0.093	:	:	:	
		SC-4	Conrand MS and Harding School	61	0.135	-	1	!	
		SC-5	Juanita Blakely Jones Elementary	273	0.607	-	1	1	
			SUBTOTAL	429	0.956	6.0	5.4	8	681
3-11	FSt	SC-4	Conrand MS and Harding School	61	0.135	:	;	:	
		SC-5	Juanita Blakely Jones Elementary	273	0.607	-	1	-	
			SUBTOTAL	333	0.743	0.9	4.8	8	1,382
3-12	HSt	SC-3	Residential	42	0.093	0.9	1.7	8	1,852
,				· ·					
T-4	Sth St	3C-b	Anderson Elementary	99	0.148	1	1	1	
	Pedley Rd	SC-7	Center for Individual Development	66	0.221	:	1	:	
		SC-8	Monterey Elementary	94	0.210	:	;	1	
		PK-6	Palm Field Park	33	0.074	-	1	-	
		N-2	Community Gardens	100	0.224		-		
		SC-11	School	255	0.569		-		
		SC-12	Curtis Middle School	404	0.900	1	1	:	

TABLE E-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

ALIGNMENT OPTION 1 - DISTRIBUTION PIPELINES

	ĺ												1	1									1				1			 			_
Length (ft)	2,889			851			6,146								2,118				1,010			831						278	719			8,007	
Diam Actual (in)	10	1	1	8	-	-	8		-		1	1	1	1	10	-			8		1	8			1	1	1	8	8	;	1	8	
Min Diam Req'd (in)	8.5	:	1	3.0	-	-	6.7	-	-	-	1	:	1	:	8.7	-	-	-	5.4		:	5.2			:	:	:	6.8	3.2	1	-	4.2	
Max Allowable Velocity (ft/s)	6.0	1	1	6.0	1	1	6.0	-	1	-	1	1	1	1	6.0	1	-	-	0.9		1	6.0			1	1	1	6.0	6.0	1	1	6.0	
Peak Hour Dmd (cfs)	2.346	0.074	0.224	0.298	0.569	0.900	1.469	0.076	0.601	0.210	0.327	0.295	0.271	0.673	2.454	0.076	0.210	0.673	0.959	0.210	0.673	0.884		0.601	0.327	0.295	0.271	1.495	0.327	0.295	0.271	0.566	
Peak Hour Dmd (gpm)	1,053	33	100	134	255	404	629	34	270	94	147	132	122	302	1,102	34	94	302	431	94	302	397		270	147	132	122	671	147	132	122	254	
Potential Direct Use Customer(s) Name	SUBTOTAL	Palm Field Park	Community Gardens	SUBTOTAL	School	Curtis Middle School	SUBTOTAL	Lorton's Fresh Squeezed Juices	Residential Community	E Neal Roberts Elementary	Bradley Elementary	Lincoln School	Riley School	Sierra High School	SUBTOTAL	Lorton's Fresh Squeezed Juices	E Neal Roberts Elementary	Sierra High School	SUBTOTAL	E Neal Roberts Elementary	Sierra High School	SUBTOTAL		Residential Community	Bradley Elementary	Lincoln School	Riley School	SUBTOTAL	Bradley Elementary	Lincoln School	Riley School	SUBTOTAL	
Potential Direct Use Customer(s) ID No.		PK-6	N-2		SC-11	SC-12		N-3	PK-7	SC-10	SC-13	SC-14	SC-15	SC-9		N-3	SC-10	SC-9		SC-10	6-DS			PK-7	SC-13	SC-14	SC-15		SC-13	SC-14	SC-15		
Street(s)		6th St			6th St	Pedley Rd	9th St	Baseline St								La Junita St				Olive St				Crestview Ave					Baseline St	Baseline St			
Distribution Segment Number		4-2			4-3			5-1								5-2				5-3				5-4					2-2	2-6			

TABLE E-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

ALIGNMENT OPTION 1 - DISTRIBUTION PIPELINES

Street(s)	Customer(s) ID No.	Potential Direct Use Customer(s) Name	(mdg)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
Highland Ave	C-2	Mountain View Cemetery	389	0.867	;	1	:	
	CT-2	Caltrans (I-210)	80	0.179	;	1	-	
	PB-7	Mountain View Avenue Median (South of I-210)	27	0.059	-	-	:	
	SC-17	San Bernardino High School	539	1.200	-	-	:	
	SC-18	Arrowview Middle School	265	0.590	-	-		
	SC-19	School	106	0.236	;	1	-	
	SC-20	Wilson Elementary School	61	0.136	;	1	:	
		SUBTOTAL	1,466	3.267	6.0	10.0	10	2,671
				1				
Waterman Ave		Caltrans (I-210)	80	0.179	1	!	-	
	SC-20	Wilson Elementary School	61	0.136	1	1	1	
		SUBTOTAL	142	0.315	0.9	3.1	8	2,344
0 100			3	0	,	c c	c	L
28th St	SC-20	Wilson Elementary School	61	0.136	0.9	2.0	∞	635
Waterman Ave	CT-2	Caltrans (I-210)	80	0.179	6.0	2.3	8	788
Highland Ave	PB-7	Mountain View Avenue Median (South of I-210)	27	0.059				
	SC-17	San Bernardino High School	539	1.200	-	1	-	
	SC-18	Arrowview Middle School	265	0.590		-	-	
	SC-19	School	106	0.236		-		
		SUBTOTAL	936	2.085	6.0	8.0	8	3,977
D St	SC-19	School	106	0.236	0.9	2.7	8	1,607
Highland Ave	V. 7.	Arrowwiew Middle School	265	0 5 0	1			
6.51	SC-19	School	106	0.236	1	1	1	
		SUBTOTAL	371	0.826	0.9	5.0	8	3,695
Highland Ave	PK-8	Fiscalini Field	98	0.191	-	1	-	
	SC-16	Pacific High School	736	1.639	-	1	-	
		SUBTOTAL	1,192	2.656	6.0	9.0	10	120
Perris Hill Park Rd	d SC-16	Pacific High School	736	1.639	6.0	7.1	8	2,378
Highland Ave	PK-8	Fiscalini Field	98	0.191	0.9	2.4	8	1,943

TABLE E-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

ALIGNMENT OPTION 1 - DISTRIBUTION PIPELINES

Length (ft)										2,793			3,919	695				3,813						3,012					5,704	3,037
										2,7			3,9	39				3,8						3,6					2'2	3,0
Diam Actual (in)										10	:	1	∞	8	1	1	1	<b>∞</b>	1	1				8	1	1			8	∞
iviin Diam Keq'd (in)	1	1		-	1					9.5	1	1	2.8	2.3	1	1	1	2.9	1	1			1	5.9	1	1	-		4.9	2.3
Velocity (ft/s)	-	-			-					6.0	:	1	6.0	6.0	:	;	-	6.0	;	-			-	6.0	-	-			6.0	6.0
Peak Hour Dmd (cfs)	0.179	2.049	0.099	0.019	0.093	0.085	0.136	0.136	0.162	2.958	0.179	0.085	0.264	0.179	0.019	0.093	0.162	0.274	0.361	0.021	0.278	0.174	0.304	1.138	0.021	0.278	0.174	0.304	0.777	0.174
Peak Hour Dmd (gpm)	08	919	44	8	42	38	61	61	73	1,328	80	38	118	80	8	42	73	123	162	10	125	78	137	511	10	125	78	137	349	78
Potential Direct Use Customer(s) Name	Caltrans (I-210)	Arrowhead Country Club	Mountain View Avenue Median (North of I-210)	St Sierra Park	Harper Field	Horine Park	Parkside Elementary School	Golden Valley Middle School	Arrowhead Elementary	SUBTOTAL	Caltrans (I-210)	Horine Park	SUBTOTAL	Caltrans (I-210)	St Sierra Park	Harper Field	Arrowhead Elementary	SUBTOTAL	Wildwood Park	Community Park	Hillside Elementary	Our Lady of the Assumption Catholic School	North Park Elementary	SUBTOTAL	Community Park	Hillside Elementary	Our Lady of the Assumption Catholic School	North Park Elementary	SUBTOTAL	Our Lady of the Assumption Catholic School
Potential Direct Use Customer(s) ID No.	CT-2	GC-2	PB-8	PK-11	PK-12	PK-17	SC-21	SC-22	SC-23		CT-2	PK-17		CT-2	PK-11	PK-12	SC-23		PK-15	PK-16	SC-24	SC-25	SC-26		PK-16	SC-24	SC-25	SC-26		SC-25
Street(s)	Parkdale Dr										Waterman Ave			Waterman Ave	Parkdale Dr				40th St						40th St	Eletric Ave				48th St
Distribution Segment Number	8-1										8-2			8-3	8-4				9-1						9-2					9-3

TABLE E-1
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

ALIGNMENT OPTION 1 - DISTRIBUTION PIPELINES

Distribution Segment		Potential Direct Use		Peak Hour Dmd	Peak Hour Dmd	Max Allowable	Min Diam Req'd		
Number	Street(s)	Customer(s) ID No.	Potential Direct Use Customer(s) Name	(gpm)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
9-4	Eletric Ave	SC-24	Hillside Elementary	125	0.278	1	+	-	
	Northpark Blvd	SC-26	North Park Elementary	137	0.304				
			SUBTOTAL	261	0.582	6.0	4.2	8	5,205
10-1	40th St	PK-13	Harrison Canyon Park	43	0.095	-	-	-	
	Harrison St	PK-14	Hampshire Floodway Park	31	690'0	1	1	:	
	39th St		SUBTOTAL	74	0.164	0.9	2.2	8	3,236

TABLE E-2
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

5J         373         0.830         6.0         5.0           Golf Course         778         1.733             Golf Course         44         0.099             demy         59         0.131             demy         59         0.131             park         94         0.210             soff Course         778         1.733         6.0         7.3           sic Supply         44         0.099             soff Course         778         1.733         6.0         7.3           demy         59         0.131              demy         44         0.099              demy         44         0.099              demy         44         0.099              demy         44         0.099              demy         44         0.029              d	2-1	Orange Show Rd  Orange Show Rd  Orange Show Rd  Waterman Ave	CT-1 GC-1	בסוטוונסו בווענו כמע לכמוכוועוומו אסווע	(mag)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
Corange Show Red   GCC1   Sin Bernardino Public Golf Course   778   1.733	2-1	Orange Show Rd  Orange Show Rd  Orange Show Rd  Waterman Ave	GC-1	CalTrans (I-215)	373	0.830	6.0	5.0	8	1,647
Change Show Rd   QC1   Sin Benatrino Public Colf Course   N28   1733	2-1	Orange Show Rd  Orange Show Rd  Orange Show Rd  Waterman Ave	GC-1							
Notice Sizes & Paint Sign No.   10   10   10   10   10   10   10   1	2-2	Orange Show Rd Orange Show Rd Waterman Ave		San Bernardino Public Golf Course	778	1.733	-	1	-	
PK-1   Mill Community Park   91 0.131	2-2	Orange Show Rd Orange Show Rd Waterman Ave	N-1	Leland Nursery & Patio Supply	44	0.099	-	;	-	
Congestion Red   PPC1   Milloranding Park   594   22173   660   8-11	2-2	Orange Show Rd Orange Show Rd Waterman Ave	SC-1	Norton Space Academy	59	0.131	-	:	-	
Mill St         SCT         Support         513         6.0         8.1           Corange Stow Md         GC1         San Bernardino Public Colf Courge         778         1,733         6.0         7.3           Valenman Ave         SC2.1         Norton Supply         44         0.099             Multi-Community Park         Morton State Academy         59         0.210             Multi-Community Park         197         0.440         6.0         3.7           Multi-Community Park         116         0.257         6.0         2.8           Athol St         Pk.1         Multi-Community Park         116         0.257         6.0         2.8           Athol St         Pk.2         Multi-Community Park         116         0.257         6.0         2.8           Athol St         Pk.2         Multi-Community Park         94         0.210         2.2         2.8           Athol St         Pk.2         Multi-Community Park         94         0.213          2.2           Rathol Ave         Pk.2         Multi-Community Park         94         0.213          2.3           Rathol Ave         Pk.3         Me	2-2	Orange Show Rd Orange Show Rd Waterman Ave	PK-1	Mill Community Park	94	0.210	1	:	1	
Orange Show Rd         GC:1         San Bernardino Public Golf Course         7778         1.733         6.0         7.3           Wasterman Ave         SC:1         Norton Space Academy         44         0.099             Wasternan Ave         SC:1         Norton Space Academy         59         0.131             Mulli St         SC:2         Burbank Bremetiary         116         0.210             Mill St         SC:2         Burbank Bremetiary         116         0.210              Mill St         SC:2         Burbank Bremetiary         116         0.219              Mill St         SC:2         Burbank Bremetiary         76         0.159         6.0         2.3            Relatio Ave         PR-2         Mondown Councer         76         0.159              Find Albert St         Mondown Councer         Recidential         49         0.109              Find Albert St         SC-3         Law Unbrank For Stellage Stool         123	2-2	Orange Show Rd Orange Show Rd Waterman Ave		SUBTOTAL	975	2.173	0.9	8.1	10	374
Orange Show Rd         GC:1         San Bernardino Public Cofi Cuarse         778         1,733         6.0         73           Wasternan Ave         SC:1         Nation Stage Region Stagety         44         0.099             Vasternan Ave         SC:1         Nation Stage Academy         59         0.131             Central Ave         Pk:1         Mill Community Jark         94         0.210             Althol St         Pk:2         But bank Elementary         115         0.257         6.0         2.8           Althol St         Pk:2         Municipal Baseball Park         76         0.169         6.0         2.3           Risito Ave         Pk:2         Municipal Baseball Park         76         0.159         6.0         2.3           Athol St         Pk:2         Municipal Baseball Park         76         0.159         6.0         2.3           Risito Ave         Pk:2         Municipal Baseball Park         76         0.129         6.0         2.3           Risito Ave         Pk:2         Municipal Baseball Park         11         0.129         6.0         2.3           Risito Ave         Pk:2         Municipal Ba	2-2	Orange Show Rd Orange Show Rd Waterman Ave								
Orange Show Rd         N.1         Leland Nursen's R Patio Supply         44         0.099             Waterman Ave         SC-1         Norton Space Academy         59         0.131             Central Ave         PK-2         Mill Community Park         59         0.210             Athol St         SC-2         Burthank Elementary         116         0.257         6.0         2.8           Athol St         PK-2         Municipal Baseball Park         76         0.169         6.0         2.3           Rialto Ave         PK-3         Municipal Baseball Park         76         0.159         6.0         2.3           Sth St         PR-2         Manadowbrook Recreation Park         76         0.159         6.0         2.3           Sth St         PB-3         Lab Banadrino County Gov Center         105         0.233             Sth St         PB-4         Lw Library Center         105         0.133             Sth St         PB-3         Lw Library Center         105         0.133             Str 3         Los Library Center         105         0.133<	2-3	Orange Show Rd Waterman Ave	GC-1	San Bernardino Public Golf Course	778	1.733	6.0	7.3	8	2,269
Will State St	5-3	Urange Snow Rd Waterman Ave	2	C		000				
Waterman Ave         SF-1         Nortice Acade Acade Name (Application Application A		Waterman Ave	N-1	Leiand Nursery & Patio Supply	444	0.099	:	:	:	
Central Ave         PK-1         Mill Community Park         94         0.210            Mill St         SC2         Burbank Elementary         115         0.240         6.0         3.7           Athol St         EK-2         Burbank Elementary         116         0.257         6.0         2.3           Realto Ave         PK-3         Municipal Baseball Park         76         0.169         6.0         2.3           Realto Ave         PK-3         Meadowbrook Recreation Park         94         0.211         6.0         2.3           Fib St         PB-3         Law Ubrary for San Benardino County Gov Center         105         0.133             PB-4         Contrand Ms and Hadding School         6.1         0.133             Sc-3         Law Ubrary for San Benardino County Gov Center         6.1         0.135             Mountain View Ave         PB-5         San Benardino County Gov Center         105         0.233         6.0         2.7           Mountain View Ave         PB-5         San Benardino County Gov Center         10480              Sch St         DB-5         Law Library for San Benardino County Gov Ce			SC-1	Norton Space Academy	59	0.131	-	:	:	
Athol St         SC2         Burbank Elementary         116         0.440         6.0         2.8           Athol St         SC2         Burbank Elementary         116         0.257         6.0         2.8           Athol St         Pk2         Municipal Baseball Park         76         0.169         6.0         2.3           Rial Lo Ave         Pk3         Meadowbrook Recreation Park         76         0.169         6.0         2.3           Sth St         Pb-3         Law Ubray Cox Center         105         0.233             P B-3         Law Ubray Cox Center         105         0.138             P B-3         Law Ubray Cox Center         49         0.120             P B-5         Norman Feldheym Public Library         54         0.120             SC-3         Law Ubray Feldheym Public Library         54         0.120             SC-3         Law Ubray Feldheym Public Library         54         0.120             SC-5         Juanita Blakely Jones Elementary         273         0.607             Mountain View Ave         PB-3		Central Ave	PK-1	Mill Community Park	94	0.210	!	-	1	
Athol St         Eurbank Elementary         116         0.257         6.0         2.8           Athol St         PK-2         Municipal Baseball Park         76         0.169         6.0         2.3           Rialto Ave         PK-3         Municipal Baseball Park         76         0.11         6.0         2.3           Sth St         PB-2         San Benardino County Gov Center         105         0.233          2.5           PB-3         Law Library for San Bernardino         82         0.183              PB-4         Law Library for San Bernardino         82         0.183              PB-5         Law Library for San Bernardino         82         0.183              SC-3         Law Library for San Bernardino County Gov Center         61         0.033             Mountain View Ave         PB-2         Juanta Blaeky Jones Elementary         273         0.007             SC-4         Law Library for San Bernardino County Gov Center         105         0.138             Sh St         PB-4         Law Library for San Bernardino County Gov Center				SUBTOTAL	197	0.440	6.0	3.7	8	5,726
Athol St         FK-2         Burbank Elementary         116         0.257         6.0         2.8           Athol St         FK-2         Municipal Baseball Park         76         0.169         6.0         2.3           Rialto Ave         FK-3         Municipal Baseball Park         76         0.169         6.0         2.3           Sth St         FR3         Meadovubrook Recreation Park         94         0.211         6.0         2.5           PB-3         Law Library for San Bernardino County Gov Center         105         0.233             PB-3         Law Library for San Bernardino County Gov Center         82         0.138             PB-4         Contrand MS and Harding School         61         0.138              SC-3         Contrand MS and Harding School         61         0.135              Mountain View Ave         PB-2         San Bernardino County Gov Center         1.05         0.138             Sth St         PB-3         Law Library for San Bernardino County Gov Center         1.05         0.138             PB-4         Noman F Fedderman Polic										
Athol St         PK-2         Municipal Baseball Park         76         0.169         6.0         2.3           Rialto Ave         PK-3         Meadowbrook Recreation Park         94         0.211         6.0         2.5           5th St         PB-3         San Benardino County Gov Center         105         0.233             Callonal Theater         82         0.183              PB-5         Law Ubrary for San Benardino County Gov Center         82         0.138             Sth St         PB-5         Norman Feddheym Public Library         54         0.108             SC-3         Conrand MS and Harding School         61         0.135             Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.138             Sth St         PB-3         Law Ubrary for San Benardino County Gov Center         105         0.138             Sth St         PB-3         Law Ubrary for San Benardino County Gov Center         54         0.108             Sth St         PB-3         Law Ubrary for San Benardino County Gov Ce	3-1	Mill St	SC-2	Burbank Elementary	116	0.257	0.9	2.8	8	988
Athol St         PR-2         Municipal Baseball Park         76         0.169         6.0         2.3           Rialto Ave         PR-3         Meadowbrook Recreation Park         94         0.211         6.0         2.5           5th St         PB-3         Law Library for San Bernardino County Gov Center         105         0.233             PB-3         Law Library for San Bernardino County Gov Center         82         0.183             PB-3         Law Library for San Bernardino County Gov Center         82         0.138             PB-3         Norman Federhead         42         0.138              SC-3         Conrand MS and Harding School         61         0.135              Mountain View Ave         PB-3         Law Library for San Bernardino County Gov Center         105         0.233         6.0         2.7           Sth St         PB-3         Law Library for San Bernardino County Gov Center         49         0.108             Sth St         PB-3         Law Library for San Bernardino County Gov Center         50         0.033             Sc-3										
Sth Str         PR-3         Meadowbrook Recreation Park         94         0.211         6.0         2.5           5th St         San Benardino County Gov Center         105         0.233             PB-3         Law Library To San Benardino County Gov Center         49         0.183             PB-4         Law Library To San Benardino County Gov Center         54         0.130             PB-5         Norman F Feldheym Public Library         54         0.130              SC-3         Conrand MS and Harding School         61         0.135              Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7           Sth St         PB-3         Law Library for San Bernardino         82         0.138             Sth St         PB-3         Law Library for San Bernardino         82         0.138             Sth St         PB-3         Law Library for San Bernardino         54         0.138             Sc-3         Norman F Feldtheym Public Library         54 <t< td=""><td>4-1</td><td>Athol St</td><td>PK-2</td><td>Municipal Baseball Park</td><td>92</td><td>0.169</td><td>0.9</td><td>2.3</td><td>8</td><td>1,397</td></t<>	4-1	Athol St	PK-2	Municipal Baseball Park	92	0.169	0.9	2.3	8	1,397
Rialto Ave         PK-3         Meadowbrook Recreation Park         94         0.211         6.0         2.5           5th St         PB-2         San Benardino County Gov Center         105         0.233             PB-3         Law Library for San Benardino         82         0.183             PB-4         Calfronia Theater         49         0.108             PB-5         Norman F Feldreym Public Library         54         0.120             SC-3         Conrand MS and Harding School         61         0.135              SC-4         Conrand MS and Harding School         61         0.135              Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7           Mountain View Ave         PB-3         San Benardino County Gov Center         105         0.138             PB-4         Norman F Feldreym Public Library         54         0.108             PB-4         Norman F Feldreym Public Library         54         0.138										
Sth St         PB-2         San Benardino County Gov Center         105         0.233             PB-3         Law Library for San Benardino         82         0.183              PB-4         California Theater         49         0.108              PB-5         Norman F Feldreym Public Library         54         0.120              SC-3         Conrand MS and Harding School         41         0.093              SC-5         Juanita Blakely Jones Elementary         273         0.607              Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7           PB-3         Law Library for San Bernardino         82         0.183             PB-3         Law Library for San Bernardino         82         0.183             SC-3         Norman F Feldreym Public Library         54         0.120             SC-3         Locarand MS and Harding School         61         0.135	5-1	Rialto Ave	PK-3	Meadowbrook Recreation Park	94	0.211	0.9	2.5	8	763
5th St         PB-2         San Benardino County Gov Center         105         0.233             PB-3         Law Library for San Benardino         82         0.1383             PB-4         California Theater         42         0.108             PB-5         Norman F Feldneym Public Library         54         0.109             SC-3         Conrand MS and Harding School         61         0.135             SC-4         Conrand MS and Harding School         61         0.135             Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7           PB-3         Law Library for San Benardino         82         0.138             PB-4         California Theater         49         0.108             PB-5         Norman F Feldheym Public Library         54         0.108             SC-3         Fish         Conrand MS and Harding School         61             SC-3         Law Library for San Benardino         54         0.										
PB-3         Law Library for San Bernardino         82         0.183             PB-4         Collifornia Theater         49         0.108             PB-5         Norman F Feldheym Public Library         54         0.120             SC-3         Residential         42         0.093              SC-3         Luanita Blakely Jones Elementary         273         0.607              Mountain View Ave         PB-2         Juanita Blakely Jones Elementary         273         0.607              Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7            PB-4         Norman F Feldheym Public Library         54         0.108              PB-4         Norman F Feldheym Public Library         54         0.120              SC-3         Juanita Blakely Jones Elementary         273         0.043              SC-4         Norman F Feldheym Public Library         54         0.120	6-1	5th St	PB-2	San Benardino County Gov Center	105	0.233	:	:	1	
PB-4         California Theater         49         0.108             PB-5         Normann F Felchleym Public Library         54         0.120             SC-3         Conrand Residential         42         0.033             SC-4         Conrand MS and Harding School         61         0.135             SC-5         Juanita Blakely Jones Elementary         273         0.607              Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         5.7            PB-3         Law Library for San Bernardino         82         0.183               PB-4         Norman F Feldheym Public Library         54         0.108			PB-3	Law Library for San Bernardino	82	0.183	-	-	-	
PB-5   Norman F Feldheym Public Library   54   0.120         SC-3   Conrand MS and Harding School   61   0.135         SC-4   Conrand MS and Harding School   61   0.135         SC-5   Juanita Blakely Jones Elementary   273   0.607         Mountain View Ave   PB-2   San Benardino County Gov Center   105   0.138         Sth St   PB-3   Law Library for San Bernardino   82   0.138         Sc-3   Norman F Feldheym Public Library   54   0.108         Residential   SC-4   Conrand MS and Harding School   61   0.135         SC-4   Conrand MS and Harding School   61   0.136         SC-4   Conrand MS and Harding School   61   0.137         SC-4   Library Harding School   61   0.137         SC-5   Juanita Blakely Jones Elementary   550   1.247   600   62			PB-4	California Theater	49	0.108	-	-	-	
SC-3         Residential         42         0.093			PB-5	Norman F Feldheym Public Library	54	0.120	-	-	-	
SC-4         Conrand MS and Harding School         61         0.135              SC-5         Juanita Blakely Jones Elementary         273         0.607			SC-3	Residential	42	0.093	-	-	-	
SC-5         Juanita Blakely Jones Elementary         273         0.607			SC-4	Conrand MS and Harding School	61	0.135	-	;	-	
Sub De Dont All Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         6.7         6.7           Sth St         PB-3         Law Library for San Bernardino         82         0.183             PB-4         California Theater         49         0.108              PB-5         Norman F Feldheym Public Library         54         0.120              SC-3         Residential         42         0.093               SC-4         Conrand MS and Harding School         61         0.135              SC-5         Juanita Blakely Jones Elementary         273         0.607              SC-5         Juanita Blakely Jones Elementary         560         1.247         6.0         6.0			SC-5	Juanita Blakely Jones Elementary	273	0.607	-	-	-	
Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7           5th St         PB-3         Law Library for San Bernardino         82         0.183             PB-4         California Theater         49         0.108              PB-5         Norman F Feldheym Public Library         54         0.120              SC-3         Residential         42         0.093              SC-4         Conrand MS and Harding School         61         0.135             SC-5         Juanita Blakely Jones Elementary         273         0.607             SC-5         Juanita Blakely Jones Elementary         560         1.247         6.0         6.0				SUBTOTAL	664	1.480	0.9	6.7	8	683
Mountain View Ave         PB-2         San Benardino County Gov Center         105         0.233         6.0         2.7         PB-2           5th St         PB-3         Law Library for San Bernardino         82         0.183               PB-4         Norman F Feldheym Public Library         54         0.108               SC-3         Residential         42         0.093               SC-4         Conrand MS and Harding School         61         0.135              SC-5         Juanita Blakely Jones Elementary         273         0.607              SC-5         Juanita Blakely Jones Elementary         560         1.247         6.0         6.0         6.0										
5th St         PB-3         Law Library for San Bernardino         82         0.183              PB-4         California Theater         49         0.108               PB-5         Norman F Feldheym Public Library         54         0.120              SC-3         Residential         42         0.093              SC-4         Conrand MS and Harding School         61         0.135              SC-5         Juanita Blakely Jones Elementary         273         0.607              SC-5         Juanita Blakely Jones Elementary         560         1.247         6.0         6.0         6.0	6-2	Mountain View Ave	PB-2	San Benardino County Gov Center	105	0.233	6.0	2.7	8	1,022
Stn St         PB-3         Law Library for Safi Bernardino         82         0.183 <td>C</td> <td>75 77 1</td> <td>6</td> <td></td> <td>C</td> <td>7</td> <td></td> <td></td> <td></td> <td></td>	C	75 77 1	6		C	7				
California Theater         49         0.108              Norman F Feldheym Public Library         54         0.120              Residential         42         0.093              Conrand MS and Harding School         61         0.135              Juanita Blakely Jones Elementary         273         0.607              SUBTOTAL         560         1.247         6.0         6.2	0-3	) S III S	PB-3	Law Library for San Bernardino	82	U.183	:		!	
Norman F Feldheym Public Library         54         0.120			PB-4	California Theater	49	0.108	-	-	1	
Residential         42         0.093			PB-5	Norman F Feldheym Public Library	54	0.120	-	-	1	
Conrand MS and Harding School         61         0.135			SC-3	Residential	42	0.093	1	-	1	
Juanita Blakely Jones Elementary         273         0.607             SUBTOTAL         560         1.247         6.0         6.2			SC-4	Conrand MS and Harding School	61	0.135	1	-	1	
560 1.247 6.0 6.2			SC-5	Juanita Blakely Jones Elementary	273	09:0	1	-	1	
				SUBTOTAL	095	1.247	0.9	6.2	8	2,722

TABLE E-2
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

Segment Number         Strain           6-4         F           6-5         5t           7-1         5t           Ped         Ped	F St F St 5 th St H St 5 th St 5 edley Rd	Customer(s) ID No. PB-5 SC-4 SC-5 SC-5	Potential Direct Use Customer(s) Name	(mdg)			•		
	F St th St H St dley Rd	PB-5 SC-4 SC-5 SC-3			(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
	th St H St th St dley Rd	SC-5 SC-5 SC-3	Norman F Feldheym Public Library	54	0.120	-		-	
	th St H St th St dley Rd	SC-5 SC-3	Conrand MS and Harding School	61	0.135	ł	1	1	
	th St H St ith St Jley Rd	SC-3	Juanita Blakely Jones Elementary	273	09:0	1	;	1	
	th St th St dley Rd	SC-3	SUBTOTAL	387	0.863	6.0	5.1	8	1,360
	th St H St th St alley Rd	SC-3							
	H St th St Jley Rd		Residential	42	0.093	0.9	1.7	8	1,700
	th St illey Rd								
	th St Iley Rd								
Ped	lley Rd	N-2	Community Gardens	100	0.224	:	:	1	
		PK-6	Palm Field Park	33	0.074	-	-	1	
		SC-11	School	255	0.569	-	-	1	
		SC-12	Curtis Middle School	404	0.900	-	-	1	
		9-DS	Anderson Elementary	99	0.148		-	-	
		SC-7	Center for Individual Development	66	0.221	-		-	
		SC-8	Monterey Elementary	94	0.210	-	-	1	
			SUBTOTAL	1,053	2.346	6.0	8.5	10	6,231
7-2 6t	6th St	N-2	Community Gardens	100	0.224	:	:	!	
		PK-6	Palm Field Park	33	0.074	1	1	1	
			SUBTOTAL	134	0.298	6.0	3.0	8	851
<b>7-3</b> 6t	6th St	SC-11	School	255	0.569	1	-	1	
Ped	Pedley Rd	SC-12	Curtis Middle School	404	0.900	;	;	1	
16	9th St		SUBTOTAL	629	1.469	0.9	6.7	8	6,146
0 1	Darolina C+	77.73	المرطيع ماميينا	127	0.305				
		SC-15	Riley School	122	0.271	1	1	,	
			SUBTOTAL	254	0.566	6.0	4.2	8	4,488
9-1 La Ju	La Junita St	N-3	Lorton's Fresh Squeezed Juices	34	0.076	-		-	
		PK-7	Residential Community	270	0.601	-		-	
		SC-10	E Neal Roberts Elementary	94	0.210	-		1	
		SC-9	Sierra High School	302	0.673	-	-	1	
			SUBTOTAL	701	1.561	0.9	6.9	8	1,288
9-2 Oli	Olive St	SC-10	E Neal Roberts Elementary	94	0.210	1	1	1	
		SC-9	Sierra High School	302	0.673	1	1	1	
			SUBTOTAL	397	0.884	6.0	5.2	8	831

TABLE E-2
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

11-1 Highland Ave 11-2 Waternman Ave 11-3 28th St 11-4 Waternman Ave	C-2 CT-2 CT-2 PB-7 SC-17 SC-19 SC-19 SC-20	San Bernardino County Medical Center Heliport  Mountain View Cemetery  Caltrans (I-210)	(8piii)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
	C-2 CT-2 PB-7 SC-17 SC-18 SC-19 SC-20	Mountain View Cemetery Caltrans (I-210)	134	0.298	6.0	3.0	8	1,830
	C-2 CT-2 PB-7 SC-17 SC-19 SC-19 SC-20	Mountain View Cemetery Caltrans (I-210)						
	CT-2 PB-7 SC-17 SC-18 SC-19 SC-20	Caltrans (I-210)	389	0.867	:	:	1	
	SC-17 SC-18 SC-19 SC-20 CC-20		80	0.179		-	-	
	SC-17 SC-18 SC-19 SC-20 CT-2	Mountain View Avenue Median (South of I-210)	27	0.059				
	SC-18 SC-19 SC-20 CT-2	San Bernardino High School	539	1.200	-	:	1	
	SC-19 SC-20 CT-2	Arrowview Middle School	265	0.590	:	:	ŀ	
	SC-20	School	106	0.236	1	1	ı	
	CT-2	Wilson Elementary School	61	0.136	-	:	1	
	CT-2	SUBTOTAL	1,466	3.267	0.9	10.0	10	1,888
	00.00	Caltrans (I-210)	80	0.179	-	:	1	
28th St Waternman Av	25-20	Wilson Elementary School	61	0.136	-	1	ı	
Waternman Av		SUBTOTAL	142	0.315	6.0	3.1	8	2,351
Waternman Av								
Waternman Av	SC-20	Wilson Elementary School	61	0.136	0:9	2.0	8	658
Waternman AV	,	(0.00)	G	0	Ċ.	ď	c	1
	7-10	Caltrans (I-Z10)	80	0.179	0.0	7.3	×	/88
	PB-7	Mountain View Avenue Median (South of I-210)	27	0.059	-	;	1	
	SC-17	San Bernardino High School	539	1.200	:	1	ŀ	
	SC-18	Arrowview Middle School	265	0.590		-		
	SC-19	School	106	0.236				
		SUBTOTAL	986	2.085	0.9	8.0	8	3,982
11-6 DSt	SC-19	School	106	0.236	6.0	2.7	∞	1,607
11-7 Highland Ave	SC-18	Arrowview Middle School	265	0.590	-	;	1	
G St	SC-19	School	106	0.236	1	:	1	
		SUBTOTAL	371	0.826	0.9	5.0	8	3,722
T Highland Ave	PK-8	Fiscalini Field	98	0.191	1	1	ı	
	PK-9	Perris Hill Park	215	0.478	1	1	1	
	SC-16	Pacific High School	736	1.639	1	1	ı	
		SUBTOTAL	1,036	2.308	6.0	8.4	10	1,028
12-2 Perris Hill Park Rd	SC-16	Pacific High School	736	1.639	6.0	7.1	8	2,349
12-3 Highland Ave	PK-8	Fiscalini Field	98	0.191	6.0	2.4	8	1,810

TABLE E-2
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

13-1     30th St     CT-2       13-2     Waterman Ave     PK-17       14-1     Parkdale Dr     PK-11       14-2     Parkdale Dr     PK-11       14-2     Parkdale Dr     PK-12       15-1     Mountain View Ave, Electric Ave     PK-12       15-1     A0th St     PK-16       15-2     40th St     PK-16       15-2     40th St     PK-16       15-3     Electric Ave     SC-25       15-3     48th St     SC-25       15-3     48th St     SC-25       15-4     Electric Ave     SC-25       15-3     Electric Ave     SC-25       15-4     Electric Ave     SC-25       15-3     Electric Ave     SC-25       15-4     Electric Ave     SC-25       15-3     A8th St     SC-25       15-4     Brownhoark Blvd     SC-25	Caltrans (I-210) Horine Park SUBTOTAL Horine Park  Asierra Park Harper Field Parkside Elementary School	80 38 <b>118</b>	(2)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
Waterman Ave         PK-17           Waterman Ave         PK-17           Parkdale Dr         PK-11           Parkdale Dr         PK-12           SC-21         SC-22           SC-23         SC-23           Federton         PK-12           Edgerton         PK-12           Pershing Ave         PK-15           Pershing Ave         SC-23           SC-24         SC-24           SC-25         SC-26           SC-26         SC-26           SC-27         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26           SC-29         SC-26           SC-29         SC-26           SC-29         SC-26           SC-29         SC-26           SC-29         SC-2	SUBTOTAL SUBTOTAL Horine Park  St Sierra Park Harper Field Parkside Elementary School	38 <b>118</b>	0.179	1	, +		
Waterman Ave         PK-17           Parkdale Dr         PK-11           Parkdale Dr         PK-12           SC-21         SC-22           SC-23         SC-23           Perkdale Dr         PK-11           Regerton         PK-12           Pershing Ave         PK-12           A0th St         PK-15           PR-16         SC-24           SC-26         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26           SC-29         SC-26           SC-29         SC-26           SC-29         SC-26           SC-26         SC-26	SUBTOTAL  Horine Park  St Sierra Park  Harper Field  Parkside Elementary School	118	0.085	1	1	1	
Waterman Ave         PK-17           Parkdale Dr         PK-11           Parkdale Dr         PK-12           SC-21         SC-22           SC-23         SC-23           SC-23         SC-23           Federton         PK-11           Pershing Ave         PK-12           A0th St         PK-16           SC-24         SC-25           SC-25         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26           SC-26         SC-26           SC-27         SC-26           SC-28         SC-26           SC-29         SC-26 <td>Horine Park St Sierra Park Harper Field Parkside Elementary School</td> <td></td> <td>0.264</td> <td>6.0</td> <td>2.8</td> <td>8</td> <td>1,882</td>	Horine Park St Sierra Park Harper Field Parkside Elementary School		0.264	6.0	2.8	8	1,882
Parkdale Dr   PK-11	St Sierra Park Harper Field Parkside Elementary School	38	0.085	6.0	1.6	8	778
Parkdale Dr   PK-11	St Sierra Park Harper Field Parkside Elementary School						
PK-12   SC-21   SC-22   SC-23   SC-23   SC-23   SC-23   SC-23   SC-24   SC-24   SC-25   SC-25   SC-26   SC-2	Harper Field Parkside Elementary School	8	0.019	1	1	1	
SC-21         SC-22         SC-22         SC-23         SC-24         SC-24         SC-24         SC-25         SC-25         SC-26         SC-26 <td< td=""><td>Parkside Elementary School</td><td>42</td><td>0.093</td><td>-</td><td></td><td></td><td></td></td<>	Parkside Elementary School	42	0.093	-			
SC-22         SC-23         SC-24         SC-24         SC-24         SC-25         SC-26         SC-26         SC-26         SC-26         SC-26         SC-25         SC-26         SC-25         SC-26         SC-26 <td< td=""><td></td><td>61</td><td>0.136</td><td>-</td><td></td><td>-</td><td></td></td<>		61	0.136	-		-	
Parkdale Dr	Golden Valley Middle School	61	0.136	-		-	
Mountain View Ave, Electric Ave   PK-11	Arrowhead Elementary	73	0.162	-			
Mountain View Ave, Electric Ave   PK-11	SUBTOTAL	245	0.547	6.0	4.1	8	1,867
Mountain View Ave, Electric Ave   PK-11     Edgerton	Jac G. casoci 2.+2	٥	0.00				
Mountain View Ave, Electric Ave   PK-12     Edgerton   SC-23     A0th St   PK-15     A0th St   SC-24     SC-26     SC-26     A0th St   SC-26     A0th St   SC-26     A8th St   SC-25     A0th St   SC-25     A8th St   SC-25     A0th St   SC-25	of ordinal Palik	0 ;	0.019	ł	ł	<b>!</b>	
## A0th St	Arrowhood Flomonton	42	0.093	:	:	:	
## A0th St PK-15  ## A0th St PK-16  ## A0th St SC-24  ## A0th St SC-26  ## Electric Ave SC-25  ## A8th St SC-25	Allowilead Elementary	73	0.102	1 0	;	1 0	
40th St PK-15 PK-16 SC-24 SC-25 SC-25 SC-26 A0th St PK-16 Electric Ave SC-25 SC-26 Northpark Blvd SC-26	SUBIOIAL	123	0.274	0.0	6.3	xo	3,803
PK-16 SC-24 SC-25 SC-25 SC-26 A0th St Electric Ave SC-25 SC-26	Wildwood Park	162	0.361	:	;	:	
SC-24   SC-25   SC-26   SC-26   SC-26   SC-26   SC-26   SC-24   SC-24   SC-25   SC-26   SC-2	Community Park	10	0.021	1	;	1	
SC-25   SC-26	Hillside Elementary	125	0.278				
A0th St   PK-16     Electric Ave   SC-24     Electric Ave   SC-24     SC-25     SC-26     A8th St   SC-25     A8th St   SC-25     And the st   SC-26     And t	Our Lady of the Assumption Catholic School	78	0.174	1		-	
40th St PK-16  Electric Ave SC-24  SC-25  SC-26  A8th St SC-25  A8th St SC-25  A8th St SC-25  Northpark Blvd SC-26	North Park Elementary	137	0.304	1		-	
Hoth St PK-16 Electric Ave SC-24 SC-25 SC-26 SC-26 A8th St SC-25 Electric Ave SC-25 Northpark Blvd SC-26	SUBTOTAL	511	1.138	6.0	5.9	8	1,884
## A0th St PK-16    Electric Ave SC-24   SC-25   SC-25   SC-26   SC-26   SC-26   SC-26   SC-25   SC-25   SC-25   SC-25   SC-25   SC-25   SC-26   SC-26							
Electric Ave SC-24 SC-25 SC-26 SC-26 SC-26 SC-26 SC-26 SC-26 SC-26 SC-25 SC-25 SC-25 SC-25 SC-25	Community Park	10	0.021	1	-	1	
SC-25 SC-26 SC-26 48th St Electric Ave SC-25 Northpark Blvd SC-26	Hillside Elementary	125	0.278	1		-	
SC-26 48th St SC-25 Electric Ave SC-24 Northpark Blvd SC-26	Our Lady of the Assumption Catholic School	78	0.174	1	1	ı	
48th St SC-25 Electric Ave SC-24 Northpark Blvd SC-26	North Park Elementary	137	0.304	1	-	-	
48th St SC-25  Electric Ave SC-24  Northpark Blvd SC-26	SUBTOTAL	349	727.0	0.9	4.9	8	5,714
Electric Ave Northbark Blvd	Our Lady of the Assumption Catholic School	78	0.174	6.0	2.3	8	3,037
Electric Ave Northbark Blvd		, r					
	HIIISIGE EIEMENTARY	125	0.278	:	:	:	
	North Park Elementary	137	0.304	-	:	-	
	SUBTOTAL	261	0.582	6.0	4.2	8	5,215
		Ç	1000				
	Harrison Canyon Park	43	0.095	:	:	:	
Harrison St PK-14	Hampsnire Floodway Park	31	690.0	1 ;	1	1	

TABLE E-3
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

Number Stree 2-1 Orange 3 Orange 2-2 Orange 3	Street(s) Orange Show Rd Orange Show Rd Orange Show Rd	Customer(s) ID No.	Potential Direct Use Customer(s) Name	(mdg)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
	Show	CT-1	(1-715)	273					
	Show		Valitatis (1-41-)	3/3	0.830	0.9	5.0	8	1,647
	Show								
	Show Rd	GC-1	San Bernardino Public Golf Course	778	1.733	-	-	-	
	Show Rd	N-1	Leland Nursery & Patio Supply	44	0.099		-	-	
	Show Rd	SC-1	Norton Space Academy	29	0.131		:	-	
	Show Rd	PK-1	Mill Community Park	94	0.210	-	;	:	
	Show Rd		SUBTOTAL	975	2.173	6.0	8.1	10	374
	Show Rd								
		GC-1	San Bernardino Public Golf Course	778	1.733	6.0	7.3	∞	2,269
	Orange Show Rd	N-1	Leland Nursery & Patio Supply	44	0.099	1	;	!	
	Waterman Ave	SC-1	Norton Space Academy	59	0.131	1	1	1	
Centra	Central Ave	PK-1	Mill Community Park	94	0.210	:	;	:	
			SUBTOTAL	197	0.440	6.0	3.7	8	5,726
							,	,	
3-1 Mil	Mill St	SC-2	Burbank Elementary	116	0.257	6.0	2.8	8	886
4-1 Ath	Athol St	PK-2	Municipal Baseball Park	76	0.169	6.0	2.3	8	1,397
5-1 Rialto	Rialto Ave	PK-3	Meadowbrook Recreation Park	94	0.211	6.0	2.5	8	763
6-1 5th	5th St	PB-2	San Benardino County Gov Center	105	0.233	:	;	:	
		PB-3	Law Library for San Bernardino	82	0.183	-	:	:	
		PB-4	California Theater	49	0.108	-	;	:	
		PB-5	Norman F Feldheym Public Library	54	0.120	-	:	:	
		SC-3	Residential	42	0.093	-	:	-	
		SC-4	Conrand MS and Harding School	61	0.135	-	-	-	
		SC-5	Juanita Blakely Jones Elementary	273	0.607	-	-	-	
			SUBTOTAL	664	1.480	6.0	6.7	∞	683
6-2 Mountain	Mountain View Ave	PB-2	San Benardino County Goy Center	105	0.233	6.0	2.7	∞	1.022
6-3 5th	5th St	PB-3	Law Library for San Bernardino	82	0.183		-		
		PB-4	California Theater	49	0.108		-	-	
		PB-5	Norman F Feldheym Public Library	54	0.120				
		SC-3	Residential	42	0.093	-	-	-	
		SC-4	Conrand MS and Harding School	61	0.135	:	;	:	
		SC-5	Juanita Blakely Jones Elementary	273	0.607	1	;	:	
			SUBTOTAL	560	1.247	6.0	6.2	8	2,722

7/20/2012

TABLE E-3
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

Distribution segment	(0)+00+3	Potential Direct Use	om of A Character 2 and 1 to a late at a late	Peak Hour Dmd	Peak Hour Dmd	Max Allowable	Min Diam Req'd	(ai) louto & carolin	(4) 4to a c 1
Number	(shaans	customer(s) ID No.	Potential Direct Ose Customer(s) Name	(Rpm)	(CIS)	veiocity (it/s)	(un)	Diam Actual (m)	rengin (iii)
6-4	F St	PB-5	Norman F Feldheym Public Library	54	0.120				
		SC-4	Conrand MS and Harding School	61	0.135	-	-	-	
		SC-5	Juanita Blakely Jones Elementary	273	0.607	:	-	:	
			SUBTOTAL	387	0.863	6.0	5.1	8	1,360
9-2	5th St	SC-3	Residential	42	0.093	0.9	1.7	8	1,700
	H St								
7-1	5th St	N-2	Community Gardens	100	0.224	-	-	-	
	Pedley Rd	PK-6	Palm Field Park	33	0.074	:	-	:	
		SC-11	School	255	0.569	:	-	-	
		SC-12	Curtis Middle School	404	0.900	:	1	:	
		9-DS	Anderson Elementary	99	0.148	:	1	1	
		SC-7	Center for Individual Development	66	0.221	:	;	1	
		8-OS	Monterey Elementary	94	0.210	-		-	
			SUBTOTAL	1,053	2.346	0.9	8.5	10	6,231
7-2	6th St	N-2	Community Gardens	100	0.224				
		PK-6	Palm Field Park	33	0.074	-		-	
			SUBTOTAL	134	0.298	0.9	3.0	8	851
7-3	6th St	SC-11	School	255	0.569	:	:	-	
	Pedley Rd	SC-12	Curtis Middle School	404	0.900	:	-	-	
	9th St		SUBTOTAL	629	1.469	0.9	6.7	8	6,146
8-1	Baseline St	SC-14	Lincoln School	132	0.295	:	-	-	
		SC-15	Riley School	122	0.271	:	-	-	
			SUBTOTAL	254	0.566	0.9	4.2	8	4,488
9-1	La Junita St	N-3	Lorton's Fresh Squeezed Juices	34	0.076	:	;	:	
	Gilbert St	PB-6	San Bernardino County Medical Center Heliport	134	0.298	:	:	-	
		PK-7	Residential Community	270	0.601	:	-	-	
		SC-10	E Neal Roberts Elementary	94	0.210	-	-	-	
		SC-13	Bradley Elementary	147	0.327	-	-	-	
		SC-9	Sierra High School	302	0.673	-	-	-	
			SUBTOTAL	981	2.186	6.0	8.2	10	1,592
6-6	Crestview Ave	PB-6	San Bernardino County Medical Center Heliport	134	0.298	1	;	1	
		SC-13	Bradley Elementary	147	0.327	;	1	1	
			SUBTOTAL	281	0.625	6.0	4.4	œ	705

7/20/2012

TABLE E-3
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

Distribution Segment Number	Street(s)	Potential Direct Use Customer(s) ID No.	Potential Direct Use Customer(s) Name	Peak Hour Dmd (gpm)	Peak Hour Dmd (cfs)	Max Allowable Velocity (ft/s)	Min Diam Req'd (in)	Diam Actual (in)	Length (ft)
6-3	Gilbert St	PB-6	San Bernardino County Medical Center Heliport	134	0.298	6.0	3.0	8	3,126
9-4	La Junita St	N-3	Lorton's Fresh Squeezed Juices	34	0.076	-	1	;	
		SC-10	E Neal Roberts Elementary	94	0.210	1	1	1	
		SC-9	Sierra High School	302	0.673	;	;	:	
			SUBTOTAL	431	0.959	6.0	5.4	8	1,288
9-5	Olive St	SC-10	E Neal Roberts Elementary	94	0.210		-		
		SC-9	Sierra High School	302	0.673		-		
			SUBTOTAL	397	0.884	6.0	5.2	8	831
10-1	Highland Ave	PB-7	Mountain View Avenue Median (South of I-210)	27	0.059	1	1	1	
		SC-17	San Bernardino High School	539	1.200	-	1	-	
		SC-18	Arrowview Middle School	265	0.590	-	-	-	
		SC-19	School	106	0.236	-	1	-	
			SUBTOTAL	986	2.085	6.0	8.0	8	3,982
10-2	D St	SC-19	School	106	0.236	6.0	2.7	8	1,607
10-3	Highland Ave	SC-18	Arrowview Middle School	265	0.590	:	1	1	
	G St	SC-19	School	106	0.236	-	1	-	
			SUBTOTAL	371	0.826	6.0	5.0	8	3,722
11-1	Highland Ave	PK-8	Fiscalini Field	98	0.191	:	;	:	
		PK-9	Perris Hill Park	215	0.478	:	;	:	
		SC-16	Pacific High School	736	1.639	;	;	:	
			SUBTOTAL	1,036	2.308	6.0	8.4	10	2,916
11-2	Derric Hill Dark Rd	SC-16	Dacific High School	736	1 639	9	7.1	α	2 349
7.11	בפונס וווו בפוע אים	25-25	ן מכווכר וופון סכווססו	007	CCO:T	2:	T:,	o	2,545
11-3	Highland Ave	PK-8	Fiscalini Field	98	0.191	6.0	2.4	8	1,810
12-1	28th St	SC-20	Wilson Elementary School	61	0.136	6.0	2.0	8	658
7		7 7 2		c	0				
13-1	Parkdale Dr	PK-11	St Sierra Park	∞	0.019	:	;	:	
		PK-12	Harper Field	42	0.093	1	1	;	
		SC-23	Arrowhead Elementary	73	0.162	1	1	1	
			SUBTOTAL	123	0.274	6.0	2.9	8	3,803

TABLE E-3
SAN BERNARDINO MUNICIPAL WATER DEPARTMENT
CLEAN WATER FACTORY PROJECT
RECYCLED/ADVANCED CONVEYANCE SYSTEM ENGINEERING ANALYSIS

Distribution Segment	:	Potential Direct Use		Peak Hour Dmd	Peak Hour Dmd	Max Allowable	Min Diam Req'd		
Number	Street(s)	Customer(s) ID No.	Potential Direct Use Customer(s) Name	(gpm)	(cfs)	Velocity (ft/s)	(in)	Diam Actual (in)	Length (ft)
14-1	Parkdale Dr	GC-2	Arrowhead Country Club	919	2.049	6.0	7.9	8	1,189
15-1	40th St	PK-16	Community Park	10	0.021			-	
		SC-24	Hillside Elementary	125	0.278				
		SC-25	Our Lady of the Assumption Catholic School	28	0.174		-	:	
		SC-26	North Park Elementary	137	0.304			:	
			SUBTOTAL	349	0.777	0'9	4.9	8	5,714
15-2	48th St	SC-25	Our Lady of the Assumption Catholic School	78	0.174	6.0	2.3	8	3,037
15-3	Electric Ave	SC-24	Hillside Elementary	125	0.278				
	Northpark Blvd	SC-26	North Park Elementary	137	0.304			-	
			SUBTOTAL	261	0.582	0'9	4.2	8	5,215
16-1	40th St	PK-13	Harrison Canyon Park	43	0.095				
	Harrison St	PK-14	Hampshire Floodway Park	31	690:0		-	:	
	39th St		SUBTOTAL	74	0.164	0'9	2.2	8	3,184

## **APPENDIX F**



### DRAWING NUMBER THESE CONSTRUCTION CRITERIA APPLY TO HOUSE SEWER LATERALS THAT CROSS ABOVE A WATER MAIN, BUT NOT TO THOSE THAT CROSS BELOW A WATER LINE. 1. NO PIPE JOINTS SHALL BE PERMITTED WITHIN ZONE D AND ZONE C. IF THAT CANNOT BE ACCOMPLISHED, THE NEW LINE SHALL BE ENCASED FOR THE FULL LENGTH OF THE RESPECTIVE ZONE. THE MATERIALS OF NEW LINES AT CROSSINGS SHALL BE CONSISTENT WITH OTHER NEW MATERIALS I.E., STEEL ON A STEEL LINE. REVISION DATE: 2/2/2012 WHEN INSTALLING NEW DOMESTIC WATER D.I.P. BELOW AN EXISTING HOUSE SEWER LATERAL, THE REQUIRED ZONE C LENGTH CAN BE THAT OF A TYPICAL 18—FOOT STICK. DO NOT LOCATE ANY PARALLEL DOMESTIC WATER LINE IN THIS AREA A WITHOUT STATE AND LOCAL HEALTH DEPARTMENT APPROVAL IF ANY WATER LINE IS TO BE CONSTRUCTED WITHIN ANY OF THE ABOVE INDICATED ZONES, SPECIAL CONSTRUCTION SHALL BE REQUIRED AS DESCRIBED BELOW. LOCATION OF NEW DOMESTIC TO EXISTING SEWER & RECLAIMED WATER LINES. PERPENDICULAR CROSSING ZONE C (NO JOINTS) USE D.I.P., WELDED CML & C STEEL, OR CLASS 200 P.V.C. - AWWA C900. USE D.I.P., WELDED CML & C STEEL, OR CLASS 200 P.V.C. - AWWA C900. USE D.I.P., WELDED CML & C STEEL, OR CLASS 200 P.V.C. - AWWA C900. ZONE D (NO JOINTS) PROHIBITED ZONE 2. NEW SEWER FORCE MAINS SHALL NOT BE PERMITTED IN ZONES A THROUGH D. RECLAIMED PROHIBITED SEWER DOMESTIC WATER (SEE GENERAL NOTE 3) PARALLEL CONSTRUCTION ZONE œ ZONE SITUATION: SONE PROHIBITED ZONE ₹ œi ပ်ဓ 'n 'n. R ဗ USE D.I.P., WELDED CML & C STEEL, OR CLASS 200 P.V.C. - AWWA C900 IF ANY SEWER OR RECLAIMED WATER PIPELINES ARE TO BE CONSTRUCTED WITHIN ANY OF THE ABOVE INDICATED ZONES, SPECIAL CONSTRUCTION SHALL BE REQUIRED AS DESCRIBED BELOW. PARALLEL CONSTRUCTION: THE HORIZONTAL DISTANCE BETWEEN DOMESTIC WATER AND RECLAIMED WATER LINES AND SEWER LINES SHALL BE AT LEAST 10 FEET, OUTSIDE OF PIPE. TO OUTSIDE OF PIPE. LOCATION OF NEW SEWER & RECLAIMED WATER LINES TO EXISTING DOMESTIC WATER LINE. DO NOT LOCATE ANY PARALLEL SEWER OR RECLAIMED WATER LINES IN THIS AREA WITHOUT A STATE AND LOCAL HEALTH DEPARTMENT APPROVAL. PERPENDICULAR CONSTRUCTION (CROSSING): WATER LINES SHALL BE AT LEAST ONE FOOT ABOVE SEWER AND RECLAIMED WATER LINES WHERE THESE LINES MUST CROSS. USE D.I.P., WELDED CML & C STEEL, CLASS 200 P.V.C. - AWWA C900 USE D.I.P., WELDED CML & C STEEL, CLASS 200 P.V.C. - AWWA C900 SPECIAL PROVISIONS: WHERE THE BASIC SEPARATION STANDARDS CANNOT BE ATTAINED ALTERNATIVE CONSTRUCTION CRITERIA ARE SHOWN BELOW: PERPENDICULAR CROSSING ZONE C (NO JOINTS) PROHIBITED ZONE ZONE D (NO JOINTS) RECLAIMED WATER WATER USE D.I.P. OR CLASS 200 P.V.C. - AWWA C900 USE V.C.P., CLASS 200 PVC, OR D.I.P. WITH COMPRESSION JOINTS. USE D.I.P. WITH MECHANICAL JOINTS OR CLASS 200 P.V.C. - AWWA C900 WATER BASIC SEPARATION STANDARDS PARALLEL CONSTRUCTION SOME PROHIBITED SEWER ZONE SITUATION ĸ mi ZONE ď ပ ۵ œ

SBMWD

WATER AND SEWER SEPARATION STANDARDS

W6.14

71-

2-7

DATE

RCE 58079

OHFIELD, P.E.

MATTHEW

**APPROVED** 

DATE

D.D.M. REVISION

JAN.

NONE

SCALE:

This page intentionally left blank